DECANT DAM 3
2000-F75-PID-PR-40022
FLUSHING WATER
75-8553-PW-PE16-355

FROM KALTAILS
DECANT WATER
DECANT CYANIDE WATER
75-XXXX-DCW-PEXX-250
TIP 03
355x250

DECANT DAM 3
2000-F75-PID-PR-40032
DECANT WATER
75-5001-PW-PE12W-250
250V101.05
250V701.06

75-8555-PW-PE12.5-355

DECANT DAM 3 & 4
2000-F75-PID-PR-40032
FLUSHING WATER
75-5001-PW-PE12.5-355
350VBF15L1 (45114)
350VC15S1 (45115)
PE12.5
350VE (45

350VC15S1 45117

FINAL TAILS PUMP 3
2000-F75-PID-PR-25008
FINAL TAILS
75-8064-TL-PE20W-560 / 75-5005-FT-PE20W-560
LINE A

FINAL TAILS PUMP 4
2000-F75-PID-PR-25008
FINAL TAILS
75-8063-TL-PE20W-560 / 75-5007-FT-PE20W-560
LINE C
PE20W RL
500 x 400

RL2 PE16
600x500
RL2 PE2
350VKG15C1 (45103)
23-8133-FT-RL2-500
500VKG15C1 (45102)
NOTE 2

FINAL TAILS PUMP 2
2000-F75-PID-PR-25008
FINAL TAILS
75-8062-TL-PE20W-560 / 75-XXXX-FT-PE20W-560
LINE B
PE20 RL2
550x500
TIP 06
400VKG15
(45101)
NOTE 1

POTABLE WATER
75-5120-POT-PE6-63
63 x
63 x 40
32V38102

250VBF

75-5004-PW-PE12W-250
PE12W RL
250VXXX WIER ISO GATE SLURRY VALVE
75-5004-PW-RL-250
PE20W RL
560 x 400

75-5002-PW-PE12W-250
PE12W RL
250VXXX WIER ISO GATE SLURRY VALVE
75-5002-PW-RL-250
400 x 250

75-5005-FT-RL-400
400VXXX WIER ISO GATE SLURRY VALVE

75-8554-PW-PE16-355

RL PE20W
500 x 400
TIP 19
75-5005-FT-PE20W-560
FIM II LINE A
FIM II BOOSTER STATION
2000-F75-PID-PR-40022

400 x 250
RL PE20W
500 x 400
75-5007-FT-RL-400
75-5007-FT-PE20W-560
FIM II LINE C
FIM II BOOSTER STATION
2000-F75-PID-PR-40022
TIP 17

75-8505-PW-PE20-355
75-8506-PW-PE20-355
350VKG15C1 (45104)
75-8008-FT-RL-400
400VXXX WIER ISO GATE SLURRY VALVE
75-5008-FT-RL-400
75-XXXX-FT-RL-400
400VXXX WIER ISO GATE SLURRY VALVE
LINE B

75-5006-FT-RL-400
75-5003-PW-PE12W-250
400VXXX WIER ISO GATE SLURRY VALVE

75-5003-PW-RL-250
400 x 250
250VXXX WIER ISO GATE SLURRY VALVE
RL PE12W

75-5001-PW-RL-250
400 x 250
250VXXX WIER ISO GATE SLURRY VALVE
RL PE12W

500 x 400
75-5008-FT-PE16W-560
RL PE16W

500 x 400
RL PE16W

20V301.01

LINE B
FINAL TAILS

350VBFE1L2 (45181)
350VCE15S1 (45182)
350VKG15C1 (45183)

RL4 PE20
500VKG15C1 (45107)
550x500
30-8552-FT-PE20-560
LINE A BYPASS
FIM II VALVE STATION No 1
2000-F75-PID-PR-40016
FINAL TAILS

PE20 RL4
550x500
500VKG15C1 (45106)
RL4 PE20
75-5005-FT-PE20-560
LINE A
FIM II BOOSTER PUMP No 2
2000-F75-PID-PR-40022
FINAL TAILS

PE20 RL4
550x500
500VKG15C1 (45108)
RL4 PE20
75-5007-FT-PE20-560
LINE C
FIM II BOOSTER PUMP No 1
2000-F75-PID-PR-40022
FINAL TAILS

RL4 PE20
500VKG15C1 (45109)
550x500
30-8551-FT-PE20-560
LINE C BYPASS
FIM II VALVE STATION No 1
2000-F75-PID-PR-40016
FINAL TAILS

350VKG15C1 (45188)
350VBFE1L2 (45184)
350VCE1S1 (45185)

FIM II TSF
75-5006-FT-PE16W-560
KALTAILS LINE A
KALTAILS BOOSTER STATION
75\PI\5302
75-5008-FT-PE16W-560
KALTAILS LINE B
KALTAILS BOOSTER STATION
75\PI\5302
75-5041-POT-PE6-040
75\PI\5010

1A

NOTE
1. VA
) BE PLARAD OPERATED. 2

LEGEND:
EXISTING
NEW
FUTURE
DECOMMISSIONED

Owner **GROWTH PROJECT**

DRAWING NO.
2000-F75-PID-PR-40021

REV	DATE	DESCRIPTION	DS CHECK	Initial TECH APP
2	16DEC25	APPROVED FOR CONSTRUCTION	CS	MJB
1A	11NOV25	ISSUED FOR INTERNAL AND CLIENT REVIEW	CS	TH
1	01MAY25	APPROVED FOR CONSTRUCTION	CS	TvB
0	05DEC24	APPROVED FOR CONSTRUCTION	CS	TvB

MK	DATE	REVISION	BY	CKD	APP
4	21 JULY 2019	GENERAL REVIS			
3	06 APRIL 2018	FIM LOM TAILIN			
2	15 NOV 2012	ISSUED FOR AS			
1		GENERAL REVIS			
0		ISSUED FOR CO			

REVISION	BY	CKD	ENG CHK	APP	REFERENCE DRAWINGS	DWG NO.
KATIONS	JM					
	JM					
	GAO	AG				
	MAL	AJC	JC	JE		
ON						

SCALE	NTS
DRAWN	MAL 1.10.09
DESIGNED	JC 1.2.10
CHECKED	AJC 28.1.10
APPROVED	JE 1.2.10
PROJ.APP	
PROJ. FILE #.	

SEDGMAN Limited A.B.N. 86 088 471 667 ISO 2006

SEDGMAN DRG No. 0251-2-2-0010 SEDGMAN JOB No. 0251

FIMISTON PLANT
WATER TREATMENT FIMISTON
KALTAILS TSF RECOMMISSIONING
PIPING & INSTRUMENTATION DIAGRAM - KEARNS CORNER

SIZE	DRAWING NUMBER	REV
A1	75\PI\5001	4

KALGOORLIE CONSOLIDATED GOLD MINES PTY. LTD. ABN 009 377 619 003

PLOT DATE: 22/02/18 - 09:43 - Cad File: P:\4251 - Kaltails Recommissioning\28.CAD\27\4251-2-2-0010.dwg [4251-2-2-0010] - Printed by: mark.lawson