33kV INCOMER 3
FROM PARKESTON POWER STATION
33kV OVERHEAD LINE FIM C
POLE FC69 (BY KCGM)

33kV OVERHEAD LINE
FIM C POLE FC69
RECLOSER

NSR
ENABLING WORKS
PRIMERO
PROJECT SCOPE

FROM PARKESTON
POWER STATION
33kV OVERHEAD LINE FIM C (EXISTING)
POLE FC60/3/3

NSR
ENABLING WORKS
PRIMERO
PROJECT SCOPE

33kV OVERHEAD LINE
FIM C POLE FC60/3/3
RECLOSER

F00-SR-001
PLANT 33kV HV DISTRIBUTION SWITCHROOM

F00-SW-010
PLANT 33kV HV DISTRIBUTION SWITCHBOARD

2000-F00-SLD-EL-10005

2000-F00-SLD-EL-10006

2000A

B20 B21 B22 B23 B24 B25 B26

36kV 2000A 3~E 31.5kA FOR 3s

630A

CONT'D FROM SHEET 2 DRG 2000-F00-SLD-EL-10011

F23-TR-016
33 / 11 kV
5000 kVA

F23-SR-001
FINAL TAILS PUMPS
11kV SWITCHROOM

630A
11kV 1250A 3E~
630A

F23-SW-016
FINAL TAILS PUMPS
11kV SWITCHBOARD
2000-F23-SLD-EL-10001

G 3~ F13-GE-120
415V 250kVA

F13-SR-005
MILL CHILLERS&REAG.
415V SWITCHROOM

F13-TR-020
33 / 0.433 kV
2500 kVA

400A 400A 4000A
415V 600A 3NE~
415V 4000A 3NE~

F13-SW-120
MILL CHILLERS & REAGENTS
415V ESSENTIAL SWB
2000-F13-SLD-EL-10711

F13-SW-020
MILL CHILLERS & REAGENTS
415V MCC
2000-F13-SLD-EL-10701

33kV SPARE
(3)

FULLY
EQUIPPED

33kV INCOMER
AND VT (3)

-

F24-TR-024
33 / 0.433 kV
1600 kVA

ENCLOSURE

2500A
415V 2500A 3NE~

F24-SW-024
SALINE WATER PUMPS
415V OUTDOOR MCC
2000-F24-SLD-EL-10501

G 3~ F21-GE-006
415V 1000kVA

F21-SR-001
CIL4
415V SWITCHROOM

F21-TR-006
33 / 0.433 kV
2500 kVA

ATS
1600A 4000A
415V 4000A 3NE~

F21-SW-006
CIL4
415V MCC 1
2000-F21-SLD-EL-10201

G 3~ F21-GE-007
415V 1000kVA

F21-TR-007
33 / 0.433 kV
2500 kVA

ATS
4000A 1600A
415V 4000A 3NE~

F21-SW-007
CIL4
415V MCC 2
2000-F21-SLD-EL-10251

G 3~ F72-GE-172
415V 400kVA

F72-SR-001
REAGENTS
415V SWITCHROOM

F72-TR-072
11 / 0.433 kV
1600 kVA

ATS
630A 630A 2500A
415V 630A 3NE~
415V 2500A 3NE~

F72-SW-172
REAGENTS
415V EMERGENCY SWB
2000-F72-SLD-EL-xxxx

F72-SW-072
REAGENTS
415V MCC
2000-F72-SLD-EL-xxxxx

G 3~ F23-GE-123
415V 400kVA

F23-SR-002
FINAL TAILS PUMPS
415V SWITCHROOM

F23-TR-023
33 / 0.433 kV
1000 kVA

ATS
630A 630A 1600A
415V 630A 3NE~
415V 1600A 3NE~

F23-SW-123
FINAL TAILS PUMPS
415V EMERGENCY SWB
2000-F23-SLD-EL-10211

F23-SW-023
FINAL TAILS PUMPS
415V MCC
2000-F23-SLD-EL-10201

NORTHERN STAR RESOURCES

Approved	☐
Approved as Noted	☒
Not Approved	☐
For Information Only	

ACCEPTANCE DOES NOT RELIEVE THE SUPPLIER / CONTRACTOR OF ITS RESPONSIBILITY OR LIABILITIES UNDER THE PURCHASE ORDER / CONTRACT

NOTES

1. FOR DETAILS OF 33kV PLANT HV DISTRIBUTION SWITCHBOARD THREE POSITION DISCONNECT/EARTH SWITCHES, BREAKERS AND BUS TIES REFER TO 2000-F00-SLD-EL-10002 .. -10006. FOR KEY INTERLOCKING, REFER TO KEY INTERLOCKING DIAGRAMS 2000-F00-SLD-EL-10051 .. -10055

2000-F00-SLD-EL-10012_Rev3

Overall sitewide 33kV distribution - single line diagram sheet 3

12:17PM ANTONY.DECAPRIO