


MCCB SHUNT TRIP COIL

ARC FLASH DETECTION TRIP

TRANSFORMER TEMPERATURE LV MCCB TRIP

EARTH LEAKAGE RELAY TRIP

SWITCHROOM EMERGENCY SHUTDOWN. RELAY ENERGISED IN NORMAL OPERATION. NORMALLY CLOSED CONTACT WILL BE OPEN

CIRCUIT BREAKER REMOTE OPEN RELAY 034


CIRCUIT BREAKER OPENED

CIRCUIT BREAKER REMOTE CLOSE RELAY 035

CIRCUIT BREAKER CLOSED

Q035 MCCB MOTORISED ACTUATOR 24VDC POWER SUPPLY

EARTH LEAKAGE RELAY 112, 193



CIRCUIT BREAKER OPENED RELAY 118, 176

CIRCUIT BREAKER OPENED INDICATION

CIRCUIT BREAKER CLOSED RELAY 106, 116, 177

CIRCUIT BREAKER CLOSED INDICATION

MCCB TRIPPED RELAY 178

CIRCUIT BREAKER TRIPPED

DCS 24VDC SUPPLY

MCCB SHUNT TRIP 24VDC OK DCS INPUT

ARC FLASH DETECTION SYSTEM ALARM DCS INPUT

CIRCUIT BREAKER OPENED DCS INPUT

CIRCUIT BREAKER CLOSED DCS INPUT

CIRCUIT BREAKER TRIPPED DCS INPUT

INCOMER SURGE DIVERTER OK DCS INPUT

48VDC FROM HV SWITCHBOARD

ARC FLASH DETECTION HV FEEDER TRIP

SWITCHROOM EMERGENCY SHUTDOWN HV FEEDER TRIP. RELAY ENERGISED IN NORMAL OPERATION. NORMALLY CLOSED CONTACT WILL BE OPEN

NOTES

1. REFER TO INCOMER SCHEMATIC DIAGRAM SHEET 1 FOR NOTES.

LEGEND

- 00/01/00 — DCS DIGITAL INPUT
- 00/02/00 — DCS DIGITAL OUTPUT
- MCC TERMINAL
- VSD TERMINAL
- FIELD TERMINAL
- DCS OR I/O TERMINAL
- MARSHALLING TERMINAL
- x — DEVICE TERMINAL
- cc — INDICATION LAMP (cc = COLOUR)

2000-F16-SCM-EL-10271_Rev2

F16-SW-008 - F16-SW-008 incomer - schematic and diagram sheet 2