F23-SR-601
FIM III BOOSTER STATION SWITCHROOM
2000-F23-DRG-EL-40001

F23PP651-VS — CAT6 — F23PP651VS-D1 — CAT6 — CAT6 — (NOTE 4) F23PW651VS-D1, F23PW652VS-D1, F23PW653VS-D1, F23PW654VS-D1 — CAT6 — CAT6 — 1 … n
F23PP652-VS — CAT6 — F23PP652VS-D1 — CAT6 — CAT6
FIM III BOOSTER STATION HV VSDs
FIM III BOOSTER STATION LV VSDs

F23-SW-602
FIM III BOOSTER STATION
LV MOTOR CONTROL CENTRE

INCOMER
2000-F23-SCM-EL-40011
BUS RS458
F23-GWY-602 — CAT6 — F23SW602-D1 — CAT6
F23-INC-602 INCOMER
F23-PM-602 POWER METER — CAT6 — F23PM602-D1 — CAT6
F23-AFD-602 ARC FLT. DET. SYS. — CAT6 — F23AFD602-D1 — CAT6

EOL 1 … EOL n — CAT6 — (NOTE 4) F23FN651-D1, F23FN652-D1, F23FN653-D1, F23FN654-D1, F23HY420-D1, F75PW665-D1
FIM III BOOSTER STATION DOL STARTER MODULES
(NOTE 1 &2)

F23-SW-601
FIM III BOOSTER STATION
HV SWITCHBOARD
CAT6 — F23SW601-D1, F23SW601-D2, F23SW601-D3, F23SW601-D4, F23SW601-D5, F23SW601-D6 (NOTE 4)
INCOMER PANEL A04 SEL751 RELAY
INCOMER PANEL A04 SEL735 PQM
VSD FEEDER PANEL A02 SEL751 RELAY
VSD FEEDER PANEL A03 SEL751 RELAY
TR FEEDER PANEL A05 SEL751 RELAY
SPARE FEEDER PANEL A06 SEL751 RELAY
(NOTE 1 &2)

F23-DCS-601
FIM III BOOSTER STATION
SWITCHROOM DCS PANEL
2000-F23-DRG-IC-40002
CAT6 — F23DCS601-D1, F23DCS601-D2
F23-FCS-415 NOTE 4
F23DCS601-D5, F23DCS601-D6, F23DCS601-D3, F23DCS601-D4, F23DCS601-D7, F23DCS601-D8
(NOTE 1 &2)

F23-BC-601 48VDC BATTERY CHARGER — F23BC601-D1
F23-HF-601 HARMONIC FILTER — F23HF601-D1
F23-UPS-601 SWITCHROOM 240VAC UPS — F23UPS601-D1

F23-FIP-601 FIRE PANEL

F23-COM-601
FIM III BOOSTER STATION SWITCHROOM
COMMUNICATIONS RACK
2000-F23-DRG-IC-40001
SM — 2C PATCH
F23-KVM-607 (KVM CONSOLE)
F23-ETH-603 (FIM III - D4 VNET 1)
F23-ETH-601 (CONTROL MODBUS)
F23-ETH-602 (CONTROL MODBUS)
STACK CABLES
HV & LV SWITCHROOM MODBUS CONNECTIONS DISTRIBUTED ACROSS 2 ETHERNET SWITCHES
F23-FOB-601
F23-ETH-606 (VNET IP2LAN DCS SWITCH)
F23-ETH-601 (FIM III - CONTROL MODBUS)
F23-ETH-604 (FIM III - WATER SERVICES)
F23-ETH-606 (FIM III D4 VNET 2)
F23-FOB-602
F23-ETH-604 (WATER SERVICES)
F23-ETH-604 (WATER SERVICES)
F75FOB557-F01 — TO FIM III TSF SWITCHBOARD 2 FOBOT 1 F75-FOB-557 REF. DRG. 2000-F75-SCM-EL-40121
F23-ETH-605 (CCTV SWITCH) — POE — CAT 6 — SD — F75SSD601-D1 — F75CAM601-D1 — F75-CAM-601 PTZ — DECANT DAM 4 CCTV CAMERA
TO SALINE DAM #3 LV SWITCHROOM FOBOT F75-FOB-403 REF DRG 2000-F00-TER-IC-20017 — F75FOB601-F01
(NOTE 1 &2)

F75-RTU-606
DECANT DAM 4 RTU PANEL
2000-F75-SCM-IC-40002
MOTOROLA ACE3600 RTU — SERIAL — SERIAL
DATA RADIO MDS S04 — LOW LOSS 50ohm CABLE CNT-400 — SURGE SUPPRESSOR IS-B-50-LN-C2 — LOW LOSS 50ohm CABLE CNT-400 — ANTENNA YB9-61
RADIO MODEM 4G — LOW LOSS 50ohm CABLE CNT-400 — SURGE SUPPRESSOR IS-B-50-LN-C2 — LOW LOSS 50ohm CABLE CNT-400 — ANTENNA CD8195-B
(NOTE 1 &2)
F75RTU606-D2, F75RTU606-D1
F75PW606VS-D1, F75PW607VS-D1, F75PW608VS-D1 — CAT6 — 1 … n
DECANT DAM 4 LV VSDs
F75PV414-D1
EOL — F23-SW-602 DECANT DAM 4 DOL STARTER MODULE

NOTES

1. REFER TO SPECIFIC COMMUNICATIONS TERMINATION DRAWINGS FOR EXTERNAL EQUIPMENT CONNECTION DETAIL.
2. COMMS CABINET, DCS PANEL, RTU PANEL, MCC & SWITCHBOARD HARDWARE/INTERCONNECTIONS (E.G. NIO NODE) & INTER-FOBOT PATCHING NOT SHOWN FOR CLARITY. REFER TO SPECIFIC COMMUNICATIONS TERMINATION DRGS FOR DETAIL.
3. CABLES RUN INDIVIDUALLY. REFER TO CABLE SCHEDULE 2000-F23-LST-EL-40003.
4. THE FCS NUMBER IS NOT DICTATED BY THE DCS EQUIPMENT NUMBER BUT BY THE DOMAIN / NETWORK IT SITS ON WITHIN THE DCS, WHICH IN THIS CASE IS DOMAIN 4, ADDRESS 15.

LEGEND

- FOB — FIBRE OPTIC BREAK OUT TRAY
- ETH — ETHERNET SWITCH; HIRSCHMANN = DCS NETWORKS; CISCO = ALL OTHER NETWORKS
- FCS — YOKOGAWA FIELD CONTROL UNIT
- xxxFCS4xx-NUxx (U/D) — YOKOGAWA NODE INTERFACE UNIT (DUAL OPTICAL ESB PORTS: U = UPLINK, D = DOWNLINK); TAG RELATED TO PARENT FCS
- GWY — COMMUNICATIONS GATEWAY ANYBUS ABC3028
- MC — FIBRE TO CAT6 MEDIA CONVERTER
- xxx — EQUIPMENT OR VENDOR PACKAGE PANELS AS NOTED WITHIN BLOCK.
- EOL — MCC MODULE DOL INTELLIGENT ELECTRONIC DEVICE/OVERLOAD
- UPS — UNINTERRUPTIBLE POWER SUPPLY
- VSD - VARIABLE SPEED DRIVE
- MULTI CORE FIBRE OPTIC CABLE OR DUPLEX PATCH LEAD
- CAT6 — CAT6 ETHERNET CABLE CONNECTION
- CCTV CAMERA — xxx-CAM-xxx PTZ — Z = FIXED (ZOOM ONLY); PTZ = PAN/TILT/ZOOM
- SD — COMMS SURGE DIVERTER DEVICE
- POE — POWER OVER ETHERNET PORT

AS BUILT

2000-F23-BLK-IC-40001_Rev6

FIM III booster station F23-SR-601 switchroom communications block diagram