415V FROM
F28-SW-009
2000-F28-SLD-EL-10201

R W B N E

415V FROM
F28-GE-109
2000-F28-SLD-EL-10211

E R W B N

EARTH BAR

F28-SW-109
415V ESSENTIAL SWITCHBOARD

F28-SD-109
415VAC SURGE DIVERTER
106kA

E20 F107 E21 L1 SD OK 1 3 24VDC
E40 E41 L2 SD OK 1 3
E60 E61 L3 SD OK 1 3 SD
100A 100A E81 N PE

LINE 227
2000-F28-SCM-EL-10221

E10 F112 E11 L1
E30 E31 L2
E50 E51 L3
2A 32A E71 N PE

LLI RD

E22 F113 E23 L1
E42 E43 L2
E62 E63 L3
2A 32A E83 N PE

LLI RD

E24 F118 E25 L1
E44 E45 L2
E64 E65 L3
2A 32A

K118
PHASE MONITOR RELAY
RM17TG00

LINE 204
2000-F28-SCM-EL-10221
2040 11 K1 12 2035
14 2055

LINE 203
2000-F28-SCM-EL-10221

LINE 205
2000-F28-SCM-EL-10221

Q131 400A

TERASAKI
TEMBREAK
PRO B MODEL
MCCB

CONT LINE 257

Q132 400A

TERASAKI
TEMBREAK
PRO B MODEL
MCCB

CONT LINE 277

415V 3NE~ 50Hz 400A 65kA for 1 sec

R
W
B
N

NOTES

1. SURGE DIVERTERS SHALL PROVIDE FEEDBACK TO DCS VIA VOLT-FREE CONTACTS. SURGE DIVERTER FUSES SHALL BE SIZED BY VENDOR TO SUIT DUTY.
2. MINIATURE CIRCUIT BREAKERS SHALL BE SIZED AND RATED TO SUIT ACB AND INCOMER REQUIREMENTS.
3. ALL TERMINATIONS ABOVE 50VAC SHALL BE TO IP2x OR ABOVE, IF NOT, TO HAVE A SEPARATE PERSPEX SHROUD FITTED AND SHALL BE LABELLED "DANGER xxxVAC".
4. WIRE NUMBER FERRULES ON TERMINAL STRIP SHALL BE PREFIXED WITH EQUIPMENT NUMBER e.g. F28SW109-0600. UNLESS OTHERWISE NOTED.
5. EACH WIRE SHALL BE IDENTIFIED AT BOTH ENDS WITH FERRULES.

LEGEND

- 00/01/00 — DCS DIGITAL INPUT
- 00/02/00 — DCS DIGITAL OUTPUT
- MCC TERMINAL
- VSD TERMINAL
- FIELD TERMINAL
- DCS OR I/O TERMINAL
- MARSHALLING TERMINAL
- x — DEVICE TERMINAL
- cc — INDICATION LAMP
  cc = COLOUR

2000-F28-SCM-EL-10220_Rev3

F28-SW-109 - F28-SW-109 415V essential switchboard incomer - schematic diagram sheet 1