


FIT72237
F72-PP-523/524 HYDROGEN PEROXIDE DOSING PUMPS FLOW INDICATING TRANSMITTER 24VDC POWER SUPPLY

FIT72227
F72-PP-521/523 HYDROGEN PEROXIDE DOSING PUMPS FLOW INDICATING TRANSMITTER 24VDC POWER SUPPLY

FIT72228
F72-PP-522/523 HYDROGEN PEROXIDE DOSING PUMPS FLOW INDICATING TRANSMITTER 24VDC POWER SUPPLY

FIT75610
F75-PW-82A/B KALTAILS TRANSFER PUMPS FLOW INDICATING TRANSMITTER 24VDC POWER SUPPLY

FIT75611
DECANT DAM #3 & #4 FLOW INDICATING TRANSMITTER 24VDC POWER SUPPLY

FIT75612
DECANT DAM #3 (F75-PW-74) FLOW INDICATING TRANSMITTER 24VDC POWER SUPPLY

LI772201B
F72-TK-511 HYDROGEN PEROXIDE STORAGE TANK LEVEL INDICATOR 24VDC POWER SUPPLY

NOTES

1. WIRE NUMBER FERRULES ON TERMINAL STRIP SHALL BE PREFIXED WITH EQUIPMENT NUMBER e.g. F72JB401-xxxx.
2. EACH WIRE SHALL BE IDENTIFIED AT BOTH ENDS WITH FERRULES.

LEGEND

0VDC TERMINAL

2000-F72-SCM-IC-10751_Rev0

F72-JB-401 hydrogen peroxide instrument junction box - schematic diagram

O:\CAD PROJECTS\235 NORTHERN STAR RESOURCES LTD\2351T KCGM GROWTH PROJECT\03 DELIVERABLES\IC\F72 - REAGENTS MIXING & STORAGE\2000-F72-SCM-IC-10751.DWG 23APR25 9:47AM SANDRA CULL