240VAC SUPPLY CIRCUIT R10
LINE 65

240VAC SUPPLY CIRCUIT W10
LINE 66

F75SW557-UPS1
HELIOS - CBI2420A
240VAC/24VDC, 20A UPS

F75SW557-UPS2
HELIOS - CBI2420A
240VAC/24VDC, 20A UPS

INPUT AC 240V

OUTPUT DC 24V 20A

UPS 1 BATTERY
VISION 6FM17-X
12V 17Ah
2 OFF

UPS 2 BATTERY
VISION 6FM17-X
12V 17Ah
2 OFF

MAIN
1073
1083
TO RTU DIGITAL INPUT
UPS 1 MAIN INPUT SUPPLY HEALTHY
2000-F75-TER-IC-40126

MAIN
1079
1089
TO RTU DIGITAL INPUT
UPS 2 MAIN INPUT SUPPLY HEALTHY
2000-F75-TER-IC-40128

BATTERY HEALTHY
1093
1103
TO RTU DIGITAL INPUT
UPS 1 BATTERY HEALTHY
2000-F75-TER-IC-40126

BATTERY HEALTHY
1099
1109
TO RTU DIGITAL INPUT
UPS 2 BATTERY HEALTHY
2000-F75-TER-IC-40128

1111
1116
1120
1127

F75SW557-RM
HELIOS
DRM40 20-40A
REDUNDANCY MODULE

IN1
IN2
DC 12-28V
20A
OUTPUT 40A

CB117 20A 1174 1184 1176

F75SW557-SD
TRANSTECH
TLP-SF20SL-24VDC
SURGE FILTER

24VDC TRANSIENT SURGE DIVERTER

CB120 20A 1204 (+24VDC) (0VDC) 1206

1200

CB123 6A 1231 1236

S123 DOOR
S124 DOOR
S125 DOOR

WH

1 PANEL LIGHTS

CB127 2A 1271 TO POWER METER LINE 21
2 POWER METER 24VDC POWER SUPPLY

CB129 2A 1291 TO CISCO NETWORK SWITCH LINE 168
3 CISCO NETWORK SWITCH 24VDC POWER SUPPLY

CB131 4A
4 SPARE

CB133 2A
5 SPARE

CB135 4A 1351 TS135 REF 1353 SWITCHBOARD VENTILATION FAN
6 SWITCHBOARD VENTILATION FAN 24VDC POWER SUPPLY

CB137 6A F75CP557-24VDC F75-CP-557 2000-F75-SCM-EL-40112 F75CP557-0VDC
7 F75-CP-557 FIM III UNDERDRAINAGE PUMP 2 CONTROL PANEL 24VDC POWER SUPPLY

CB139 6A F75CP558-24VDC F75-CP-558 2000-F75-SCM-EL-40113 F75CP558-0VDC
8 F75-CP-558 FIM III TOE DRAIN PUMP CONTROL PANEL 24VDC POWER SUPPLY

CB141 10A 1411 RTU SLOT 1 MARSHALLING STRIP
9 RTU SLOT 1 MARSHALLING STRIP 24VDC POWER SUPPLY

CB143 10A 1431 RTU SLOT 2 MARSHALLING STRIP
10 RTU SLOT 2 MARSHALLING STRIP 24VDC POWER SUPPLY

CB145 10A
11 SPARE

CB147 1A FIT75785-P1 FIT-75785 2000-F75-TER-IC-40129 FIT75785-P1
12 FIT-75785 MAGNETIC FLOW METER 24VDC POWER SUPPLY

24VDC SUPPLY CONT'D ON LINE 150

24VDC SUPPLY CONT'D FROM LINE 148

CB152 1A FIT75790-P1 FIT-75790 2000-F75-TER-IC-40127 FIT75790-P1
13 FIT-75790 MAGNETIC FLOW METER 24VDC POWER SUPPLY

CB154 1A
14 SPARE

CB156 4A
15 SPARE

CB158 4A
16 SPARE

F75-RTU-557
ACE3600 RTU
MOTOROLA
F7509A C/W V103AG

RTU BUS MOTHERBOARD AND 3 I/O SLOTS FRAME

MOTOROLA V251BQ
18-72V POWER SUPPLY

CB163 10A 1631
AUX IN
18-72VDC POWER SUPPLY
AUX IN
17

MOTOROLA ACE3640 F7502A
REMOTE TERMINAL UNIT
CPU
SERIAL 1
SERIAL 2
ETH1

MOTOROLA V245AF
MIXED I/O MODULE
16 DI, 4 DO, 4 AI
RTU I/O SLOT 1
2000-F75-TER-IC-40126 AND 40127

MOTOROLA V245AF
MIXED I/O MODULE
16 DI, 4 DO, 4 AI
RTU I/O SLOT 2
2000-F75-TER-IC-40128 AND 40129

MOTOROLA V20AC
SPARE BLANK
I/O MODULE

1813
Q023
1823
TO RTU DIGITAL INPUT
MCCB TRIPPED
2000-F75-TER-IC-40126

0VDC TERMINALS

1	●	F75SW557-1206
2	●	F75SW557-1206
3	●	F75SW557-1206
4	●	
5	●	
6	●	F75SW557-1206
7	●	F75CP557-0VDC
8	●	F75CP558-0VDC
9	●	F75SW557-1206
10	●	F75SW557-1206
11	●	
12	●	FIT75785-P1
13	●	FIT75790-P1
14	●	
15	●	
16	●	
17	●	F75SW557-1206

CISCO
ETHERNET SWITCH
IE3300

POWER METER LINE 23 — CAT6 — CAT6 — CAT6
1/3
1/4
1/5
1/6
1291
1206
24VDC SUPPLY LINE 129

NOTE 16
RUGGEDISED DUPLEX FO PATCH LEAD (YE)
SM / LC
LC / 2C
1/1
1/2
1/7
1/8
1/9
1/10

F75-FOB-557

12 X LC DUPLEX PORT FOBOT

F75FOB557-F01
SM
24C
TO F23-FOB-602
F23-COM-601
FIM III BOOSTER STATION
SWITCHROOM COMMUNICATIONS RACK
2000-F23-BLK-IC-40001

APPROVED FOR CONSTRUCTION

2000-F75-SCM-EL-40121_Rev0

FIM III tailings dam F75-SW-557 FIM III TSF switchboard 2 schematic diagram sheet 2