NOTES:

1. SOLENOID VALVE MOUNTED INSIDE CABINET AND TUBED TO THICKENER TURBIDITY ELEMENT.

PLANT AIR RECEIVER
2000-F24-PID-PR-10007
PLANT AIR

24-0671-IA-MSG2-200

25VB03S1 F17-13022

MSG3 / MSG2

17-1074-IA-MSG3-25 → 25VB03S1 F17-11496 → F17-CP-407 FLOTATION TAILINGS THICKENER UNDERFLOW PUMPS VALVE CONTROL PANEL

NOTE 1: FCV 17001, SVO 17019

17-2152-IA-MSG3-25 → SP HS-075 → 25VB03S1 F17-10892 → SP MC-001 SP@ BRIDGE OF THICKENER F17-TH-401

17-1169-IA-MSG3-25 → 25VB03S1 F17-10850 → F17SA416-CP FLOTATION TAILINGS FEED SAMPLER VALVE CONTROL PANEL

XV 17085, XV 17086, XV 17087

17-1575-IA-MSG3-25 → 25VB03S1 F17-11472 → SP MC-001 SP@ F17-SA-416 TOS RL 384.458

16-1499-IA-MSG3-25 → 25VB03S1 F16-11471 → SP MC-001 SP@ ST-10401 COLUMN A2 AT GRADE

200VGE1C1 F00-12992

16-1043-IA-MSG3-50 → 50VB03S1 F16-14156 → 50x25 25VB03S1 F16-11468 → SP MC-001 SP@ ST-10500 COLUMN M6 AT GRADE

16-0321-IA-MSG3-25 → 25VB03S1 F16-11469 → F16-CP-403 ROUGHER CELL FEED WATER VALVE CONTROL PANEL

FCV 16001

13-0663-IA-MSG3-50 → 50VB03S1 F13-13128

13-2364-IA-MSG3-50

13-2366-IA-MSG3-25 → 25VB03S1 F13-10416 → SP MC-001 SP@ F13-HP-402 GRADE LEVEL

13-2365-IA-MSG3-25 → 25VB03S1 F13-10415 → SP MC-001 SP@ F13-SC-403 TOS RL 380.000

13-2541-IA-MSG3-25 → 25VB03S1 F13-10640 → SP MC-001 SP@ F13-FD-407 TOS RL 381.000

13-2361-IA-MSG3-50

13-2372-IA-MSG3-25 → 25VB03S1 F13-10422 → SP MC-001 SP@ F13-SL-401/404 TOC RL 399.500

13-2371-IA-MSG3-25 → 25VB03S1 F13-10421 → SP MC-001 SP@ F13-FD-405 TOS RL 405.440

13-2370-IA-MSG3-25 → 25VB03S1 F13-10420 → SP MC-001 SP@ F13-BX-415 (NORTH) TOS RL 396.200

13-2369-IA-MSG3-25 → 25VB03S1 F13-10419 → SP MC-001 SP@ F13-SL-401/402 TOC RL 399.500

13-2368-IA-MSG3-50 → 50x25 25VB03S1 F13-10418 → SP MC-001 SP@ F13-SL-401/402 TOC RL 399.500

13-2367-IA-MSG3-25 → 25VB03S1 F13-10417 → SP MC-001 SP@ F13-BX-415 (SOUTH) TOS RL 396.200

13-2454-IA-MSG3-50 → 50x25 25VB03S1 F13-10128 → SP MC-001 SP@ F16-SA-401 TOS RL 397.30

13-2360-IA-MSG3-50

13-2455-IA-MSG3-50 → 50x25 25VB03S1 F13-10129 → SP MC-001 SP@ F13-BX-414 TOS RL 396.200

13-2363-IA-MSG3-25 → 25VB03S1 F13-10414 → SP MC-001 SP@ F13-SL-403/404 TOS RL 402.040

13-2362-IA-MSG3-25 → 25VB03S1 F13-11470 → SP MC-001 SP@ F13-SL-403/404 TOC RL 399.500

13-0675-IA-MSG3-50 → 50VB03S1 F13-14155 → 50x25 25VB03S1 F13-11950 → SP MC-001 OSA AREA SERVICE POINTS

MILL AIR RECEIVER
2000-F24-PID-PR-10011
PLANT AIR

16-0312-IA-MSG3-25 → ONSTREAM ANALYSER 2000-F16-PID-PR-10005 PLANT AIR

24-1027-IA-MSG2-80 → PROCESS WATER/REAGEMTS/ TRASH SCREENS AIR RECEIVER 2000-F24-PID-PR-10013 PLANT AIR

PI 16182 H L

PI 16182

PT 16182

25VB03S1 F16-11478

16-0683-IA-MSG2-100 → FLOTATION/ THICKENER AIR SERVICES 2000-F24-PID-PR-10024 PLANT AIR

SET AT 1034 KPag

PRV 16180

PI 16181

10

DN100

DN15 BSP

100x80

80VBE1C1 F16-11477

100x80

16-0682-IA-MSG2-80

80VCE1C1 F16-11474

80VBE1C1 F16-11475

100x80

F16-RA-402 FLOTATION/ THICKENER AIR RECEIVER

25 25

MT

DRAIN DRAIN

VENDOR PACKAGE

16-0684-IA-MSG2-80

80VBE1C1 F16-11476