NOTES:

1. REFER TO P&ID 2000-F75-PID-PR-25003 J-10 FOR TIE-IN.
2. HIGH POINT VALVE TO BE PLUGGED AND LOCKED CLOSED DURING OPERATION

FIRE WATER NETWORK
FIRE WATER
ENABLING WORKS 09-01
BL
GREENFIELDS
MSG2 A/G
PE16 U/G
75-0558-FW-MSG2-200
TIP 1057 NOTE 1
00-1399-FW-PE16-110
225x110
16-1400-FW-MSG2-100
00-1401-FW-PE16-110
17-1402-FW-MSG2-100
00-0566-FW-PE16-225
00-0272-FW-PE16-90
17-0271-FW-MSG2-80
80VGE1F1 F17-11509
PAL 24651
PAL 24653
80VGE1F1 F72-11511
72-0994-FW-MSG2-80
100x80
00-0944-FW-PE16-110
72-0606-FW-MSG2-100
00-0605-FW-PE16-110
13-1246-FW-MSG2-100
00-1245-FW-PE16-110
13-0569-FW-MSG2-100
225x110
00-0568-FW-PE16-225
13-0637-FW-MSG3-50
13-1819-FW-MSG3-50
50X25 F13-FHR-405
RECYCLE CRUSHING FIRE HOSE REEL 2
13-0559-FW-MSG3-50
50X25 F13-FHR-414
RECYCLE CRUSHING FIRE HOSE REEL 1
25VB03S1 F13-11524
50VB03S1 F13-11523
80VGE1F1 F13-11513
PAL 24656
PSL 24656
YV 24656
PI 24656A
PI 24656B
PRV 24657 SET @ 1200kPag 14.00
TO GRADE
13-1404-FW-MSG2-80
13-0561-FW-MSG2-80
13-0947-FW-MSG3-50
13-0946-FW-MSG3-25
13-0945-FW-MSG3-25
13-0560-FW-MSG2-80
13-1935-FW-MSG3-25 TO 13-1940-FW-MSG3-25
13-1945-FW-MSG3-25 TO 13-1950-FW-MSG3-25
RECYCLE CRUSHER D LUBE SPRINKLER SYSTEM
RECYCLE CRUSHER C LUBE SPRINKLER SYSTEM
RECYCLE CRUSHER ISOLATION GATES HYDRAULIC UNIT
RECYCLE CRUSHER D HYDRAULIC UNIT
RECYCLE CRUSHER C HYDRAULIC UNIT
SP-010 6 OFF
SP-010 1 OFF
FLAME DETECTED
YA 24658
YD 24658B IR
YD 24658A IR
F16-HYD-408 FLOTATION BLOWER AREA FIRE HYDRANT
F17-HYD-414 FLOTATION TAILINGS THICKENER & CHILLED WATER AREA FIRE HYDRANT
F72-HYD-406 FLOTATION TAILINGS THICKENER REAGENTS AREA FIRE HYDRANT
F13-HYD-418 COS STOCKPILE FIRE HYDRANT
F13-HYD-405 RECYCLE CRUSHERS C & D FIRE HYDRANT
THICKENER F17-TH-401 HYDRAULIC DRIVE SPRINKLER SYSTEM
FROTHER TANK PERIMETER SPRINKLERS (F72-TK-432)
PRV 24652 SET @ 1200kPag 14.00
PRV 24654 SET @ 1200kPag 14.00
TO GRADE
FLAME DETECTED
YA 24655
YD 24655 LHD
SP VC-006
SP FS-006
SP FS-010
SP VC-009 003 45 OFF
200VGE1F1 F13-11515
50VB01S1 F13-11517
50VB01S1 F13-11518
200VGE1F1 F13-11528
50VB01S1 F13-11529
13-1403-FW-MSG2-200
00-1405-FW-PE16-225
12-0638-FW-MSG2-200
FIRE WATER NETWORK 2000-F24-PID-PR-10022 FIRE WATER
00-0578-FW-PE16-110
12-0633-FW-MSG2-100
F12-HYD-404 STOCKPILE FEED CONVEYOR TAKEUP TOWER FIRE HYDRANT
13-0564-FW-MSG3-50
50x25 F13-FHR-403 COS FIRE HOSE REEL 1
NOTE 2
25VB03S1 F13-14446 LC
13-0636-FW-MSG3-50
50x25 F13-FHR-404 COS FIRE HOSE REEL 2
13-1432-FW-MSG3-50
50VB03S1 F13-11520
25VB03S1 F13-11522
PAL 24662
PSL 24662
YV 24662
PI 24662A
PI 24662B
PRV 24663 SET @ 1200kPag
TO GRADE
80VGE1F1 F13-11530
13-0563-FW-MSG2-80
13-1880-FW-MSG3-25 TO 13-1904-FW-MSG3-25
SP-010 28 OFF
SP-011 42 OFF
YD 24664 LHD
13-0200-FW-MSG2-200
FIRE WATER NETWORK 2000-F24-PID-PR-10023 FIRE WATER

EXISTING FIRE WATER
FIRE WATER NETWORK
FIRE WATER
TIP 1003
75-0598-FW-MSG2-100
100VGE1F1 F75-11660
00-0635-FW-PE16-110
75-0642-FW-MSG2-100
00-0685-FW-PE16-110
75-1816-FW-MSG2-100
F75-HYD-416 SALINE WATER PUMPS AREA FIRE HYDRANT