NOTES:

1. REFER TO STANDARD DRAWINGS FME-00-SP-402 FOR FLUSHING POINT, WASH DOWN CONNECTION AND PRESSURE GAUGE CONNECTION DETAILS.
2. CLIENT TO NOMINATE PROCESS WATER AND INSTRUMENT AIR TIE-IN POINTS ON SITE.
3. V868 IS FOR PROVISIONAL VALVE SPEC WEIR DELTA SERIES TYPE IS KNIFEGATE, KCGM TO CONFIRM.
4. OXYGEN INJECTION PUMP REMOVED AS PART OF Owner GROWTH UPGRADE. REFER TO P&ID 2000-F30-PID-PR-10007 FOR NEW OXYGEN INJECTION PUMP

TI 005 NOMINATE TIE IN POINT

INSTRUMENT AIR

NOTE 2

30-151-IA-MSG-025

TO KV30347 (NOTE 2)

TO KV30346 (NOTE 2)

OXYGEN

2000-F30-PID-PR-10012

30-150-OXY-SS-025

TI 006 NOMINATE TIE IN POINT

PROCESS WATER

NOTE 2

30-152-PW-XS2-25

25V301

25X15

HS I HS SY S ZAH ZAL IA KV ZSH ZSL

TYPICAL KV INSTRUMENT ARRANGEMENT WITH REMOTE SOLENOID

25V301 KV 30347 25V301 TI 004

250V868.176 250V868.174

100V868

30-161-CS-RL-100

30-TK-32A

TI 003

25V301 KV 30346 25V301

SP 150

30-156-CS-RL-250

250X200

250V868.175 250V868.177

100V868

30-157-CS-RL-100

IT 30344 IT 30344 M 200X150

F340B-F30TK32A-PP01

30-155-OXY-SS-015

15V331.156

FIT 30345 FT 30345 FIC 30345 FY 30345 ZT 30345 ZT 30345 PIT 30349 PI 30349 TT 30348 TIT 30348 TI 30348

COMET SCOPE

15V331

30-158-CS-RL-200

SP 153

PI 30802 PI 30801 PI 30800

15V301 15V301 15V301 15V301 15V301

15V731 15V331 15V731 15V331

250X200 REMOVABLE SPOOL (FLOWMETER)

25V301 100V868 25V301 25V301

SP 152 SP 151

MMS SCOPE

100V868

30-159-CS-RL-100

30-160-CS-RL-100

LEGEND

- EXISTING
- NON-EXISTENT
- STAGE 1 - NEW
- STAGE 1 - REMOVE
- STAGE 1 - DECOMMISSIONED (OTHERS)
- STAGE 2 - NEW
- STAGE 2 - REMOVE
- STAGE 2 - DECOMMISSIONED (OTHERS)

F340B-F30TK32A-PP01

FIM TK32A

OXYGEN INJECTION PUMP No.1

NOTE 4

30-TK32A

FIM TK32A