NOTES:

1. FOR TYPICAL INSTRUMENT DETAILS REFER TO DRG FME-30-PI-0701.
2. FOR TYPICAL PUMP GLAND WATER DETAILS REFER TO DRG 34-PI-0002.
3. TO BE READ IN CONJUNCTION WITH DWG NO. 35-PI-0444.
4. CONFIRMED NO ACTUATED DARTS LOCATED ON DART BOX. ONLY SINGLE MANUAL DART ISOLATION ON TANK B.
5. PIPI OVIDED TO PROVIDE SPACE FOR NE
6. FILT & 2 REMOVED DURING ENABLING WORKS

NOTES:

7. CONFIRMED FEED PREP CYCLONE F35-CY-02 UNDERFLOW IS DIRECTED TO FILTER FEED TANK B F35-TK-01B. REFER TO 2000-F34-PID-PR-10001 FOR MORE DETAIL ON STAGE 2 DECOMMISSIONED SCOPE OF WORK FOR F35-PP-64 & F35-CY-02, AS THIS IS DUPLICATED ON THIS DRAWING..
8. PIPE IS EXISTING, REFER TO NOTE 3.
9. FCV35761 TO BE REPURPOSED AS DCV35761 VIA FEEDBACK FROM DE/DIT35770 TO TARGET DESLIME CYCLONE FEED DENSITY TO 20%.
10. ROTATABLE ELBOW FOR TANK A BYPASS
11. REFER TO P&ID 2000-F35-PID-PR-10006 GOR GLAND WATER DESTINATIONS
12. VALVE FV35622 LOCATED ON LINE 602

LEGEND

—	EXISTING
▨	NON-EXISTENT
—	STAGE 1 - NEW
🟥	STAGE 1 - REMOVE
🟨	STAGE 1 - DECOMMISSIONED (OTHERS)
—	STAGE 2 - NEW
🟪	STAGE 2 - REMOVE
🟩	STAGE 2 - DECOMMISSIONED (OTHERS)