NOTES:

1. ALL SAMPLE POINTS TO HAVE MINIMAL STUB LENGTH TO SAMPLE VALVE.
2. VALVE IS ACTUATED VIA MANUAL 4-WAY VALVE LOCATED IN CONTROL PANEL.
3. TOTALISE FLOW ONLY WHEN BARREN VALVE IS OPEN.
4. INVERTED SUCTION TO WITHIN 50mm OF TANK BASE.
5. FLANGED ASME B16.5 CLASS 150.
6. CURRENT SETPOINT AND VOLTAGE LIMIT INPUTS FOR RECTIFIER OPERATION WHEN IN REMOTE/AUTOMATIC MODE. RECTIFIER WILL OPERATE IN 'DC CURRENT CONTROL' MODE ONLY WHEN IN REMOTE/AUTOMATIC. COMMUNICATION TO AND FROM DCS IS VIA MODBUS.
7. CONNECTION FOR PUMPS ARE AS2129 TABLE E.
8. MANUAL OPERATED VALVE WITH PROXIMITY SWITCHES.
9. NEW HCN AND NH_3 GAS DETECTION MONITORS TIE INTO EXISTING GAS DETECTION SIREN & BEACON LOGIC (UA66903A/B).

LEGEND:

SP2 NEW

SP2 DECOMMISSIONED

CIL4 ELECTROWINNING CELLS
2000-F66-PID-PR-10002
FUMES

DUCTING

INTENSIVE CYANIDE LEACH REACTOR
2000-F00-PID-PR-10101
PREGNANT ELUATE

00-3107-PE-PEDC1-110

PEDC1

SS1

100x80

66-3091-PE-SS1-80

DETAIL 8
HS 66421
XV 66421

80VBFD1S2 F66-12757

CAUSTIC RINGMAIN
2000-F72-PID-PR-10006
CAUSTIC

66-4088-NS-MS1-25-TI

25VBD1S1 F66-12758

TI

25VB03S1 F66-12759

25VBD1S1 FC

TIP 2060 STAGE 2 STAGE 1

50x25

DN80

DN100

66-3082-FD-SS1-80

66-4089-NS-MS1-25

TO GRADE

100-MECH-MS1

LIT 66422

LI 66422 HH H L LL

66-3099-PE-SS1-50

15VBD3S1 F66-12765

TO GRADE

50VBD1S1 F66-12776

FI 66423 H L

FIT 66423

FE 66423

DETAIL 9
HS 66429
XV 66429

100VBFD1S2 FL

MANUAL SAMPLING POINT

3°

66-3094-PE-SS1-150

25VB03S1 F66-12760

66-3095-PE-SS3-25

25VB03S1 F66-12761

SAMPLE BUCKET

TIP 2120 STAGE 2 STAGE 1

ELECTROWINNING FUME CARBON FILTER
2000-F66-PID-PR-10004
FUMES

DUCTING

66-3093-PE-SS1-100

66-3012-PE-MS1-200

200VBD1C1 F66-12775

NOTE 4

F66-TK-460
GRAVITY ELECTROWINNING TANK

150VBD1S1 F66-12777

66-3092-PE-SS1-150

50VBD3S1 F66-12778

150VBD1S1 F66-12779

150x100

NOTE 7

F66-PW-460
GRAVITY ELECTROWINNING PUMP

100x65

100VCD1S1 F66-12780

50VBD3S1 F66-12781

M

25VB03S1 F66-12784

25VB03S1 F66-12785

66-3058-PE-SS1-80

TO GRADE

25VB03S1 F66-12764

SP MC-001

HS 66454

DETAIL 11
HS 66454

SV 66454

DETAIL 9
HS 66430

XV 66430

100VBFD1S2 FL

MANUAL SAMPLING POINT

66-3034-BE-SS1-100

BARREN ELUATE TANK
2000-F66-PID-PR-60001
BARREN ELUATE

CIL4 ELECTROWINNING CELLS
RECIRCULATION SAMPLE
2000-F66-PID-PR-10001
PREGNANT ELUATE

66-4153-PE-SS1-25

F66-XM-493
ELECTROWINNING SAMPLER CABINET

66-3056-BE-SS3-25

25x15

FC

25VB03S1 F66-12783

25VB03S1 F66-12782

HS 66453

DETAIL 11
HS 66453

SV 66453

FC

CIL4 ELECTROWINNING CELLS
BARREN SAMPLE
2000-F66-PID-PR-10001
BARREN ELUATE

66-4154-BE-SS1-25

66-3057-PE-SS3-25

25x15

80VBD1S1 F66-12787

80VBD1S1 F66-12789

RECTIFIER 1

CURRENT IC 66431 II 66433 H L

VOLTAGE XC 66431 XI 66433 H L

NOTE 6

RECTIFIER 2

CURRENT IC 66432 II 66434 H L

VOLTAGE XC 66432 XI 66434 H L

NOTE 6

DUCTING

F66-XM-431
GRAVITY ELECTROWINNING CELL DUCTING

80VBD1S1 100x80 F66-12791

80VBD1S1 F66-12793

NOTE 8

HV 66460

80VBFD1S2 F66-12763

ZSO 66460

ZSC 66460

ZIO 66460

ZIC 66460

AE 66470A

HCN

AIT 66470

AI 66470A HH H

AI 66470B

NH_3

AE 66470B

UA 66903A

UA 66903B

NOTE 9

SIREN & BEACON

SIREN & BEACON

FSL 66464

FAL 66464

80VDD1S2 F66-12786

F66-EC-401
GRAVITY ELECTROWINNING CELL

F66-ER-401A
GRAVITY ELECTROWINNING CELL RECTIFIER 1

F66-ER-401B
GRAVITY ELECTROWINNING CELL RECTIFIER 2

80VDD1S2 F66-12790

FSL 66465

FAL 66465

25VB03S1 F66-12788

TO MEZZANINE FLOOR

25VB03S1 F66-12792

TO MEZZANINE FLOOR

VENDOR PACKAGE

GOLDROOM AIR HEADER
2000-F81-PID-PR-60011
PLANT AIR

66-3096-IA-MSG3-25

25VB03S1 F66-12771

DETAIL 12 NOTE 2
XV 66426
HS 66426

100VBFD1S2 FL

DETAIL 12 NOTE 2
XV 66428
HS 66428

100VBFD1S2 FL

SP MC-001

25VB03S1 F66-12796

SP MC-001

25VB03S1 F66-12797

9°

SCHEME WATER HEADER
2000-F66-PID-PR-10002
SCHEME WATER

66-3068-PSW-SS3-25

25VC01S1 F66-12806

66-3090-BE-SS1-100

SLUDGE DEWATERING CONE
2000-F66-PID-PR-10005
SLUDGE

ZIO 66463

ZSO 66463

ZIC 66463

ZSC 66463

NOTE 8

HV 66463

80VBFD1S2

SP MC-001

25VB03S1 F656-12768

66-3086-FD-SS1-80

BARREN ELUATE TANK
2000-F66-PID-PR-60001
FLOOR DRAINAGE

LAH 66424

66-3076-FD-SS1-80

25VB03S1 F66-12762

SP MC-001

LSH 66424

80x65

NOTE 5

F66-PS-481
ELECTROWINNING TANK AREA SUMP PUMP

ZIO 66461

ZSO 66461

ZIC 66461

ZSC 66461

NOTE 8

HV 66461

80VBFD1S2

SP MC-001

25VB03S1 F656-12770

CIL4 ELUATE CIRCULATION TANK 1
66-4165-FD-SS1-80
2000-F66-PID-PR-10001
FLOOR DRAINAGE

ZIO 66462

ZSO 66462

ZIC 66462

ZSC 66462

NOTE 8

HV 66462

80VBFD1S2

SP MC-001

25VB03S1 F656-12766

STAGE 1 STAGE 2

TIP 2124

STAGE 1 STAGE 2

TIP 2123

CIL4 ELUATE CIRCULATION TANK 2
66-4170-FD-SS1-80
2000-F66-PID-PR-10001
FLOOR DRAINAGE