LEGEND:

- EXISTING
- NEW
- FUTURE
- DECOMMISSIONED

NOTES:

1. LOCATED AT DECANT DAM 4.
2. ARRANGEMENT TO BE CONFIRMED PENDING FINIAL TSF DESIGN AND REQUIREMENTS.
3. DIFFERENTIAL FLOW CALCULATION FOR LEAK DETECTION.

UNDERDRAINAGE - FROM FIM III CELL 2/3

UNDERDRAINAGE - FROM FIM III CELL 2/3 LEAKAGE SUMP

UNDERDRAINAGE - FROM FIM III CELL 1

UNDERDRAINAGE - FROM FIM III CELL 1 LEAKAGE SUMP

VALVE PIT

TIP 13A / 13B / 13C / 13D / 13E / 13F / 13G / 13H / 13I / 13J

TIP 14A / 14B / 14C / 14D / 14E / 14F / 14G / 14H / 14I / 14J

OTHERS — Engineer — UG — AG

100VKGD1L1 (42580) … (42609)

25VBD1S1 (42586) … (42606)

100VBFD1L1 (42581) … (42605)

200VKGD1L1 (42586) … (42621)

25VBD3S1 (42588) … (42608)

200VBFD1L1 (42587) … (42623)

PE8 — RL1

DETAIL 14

HS 75795 / XV 75795 / 350VBFD1L1 FC

HS 75797 / XV 75797 / 100VBFD1L1 FC

HS 75796 / XV 75796 / 350VBFD1L1 FC

HS 75798 / XV 75798 / 100VBFD1L1 FC

75-8456-PW-PE8-355

75-8458-PW-PE8-110

75-8457-PW-PE8-355

75-8459-PW-PE8-110

LI 75789 (H / L / LL)

LIT 75789

LE 75789

SP HS-409

F75 PS-556 — FIM III UNDERDRAINAGE PUMP 1

F75 PS-557 — FIM III UNDERDRAINAGE PUMP 2

15VA01T1 (42566)

15VB03S1 (42565)

PI 75789

15VB03S1 (42564)

160x110

150VCE1S1 (42560)

150VBFE1L1 (42561)

75-8445-PW-PE125-160

25VB03S1 (42567)

DRAIN

FI 75789 / FQI 75789 (L / LL)

FIT 75789

FE 75789

150VDE1L2 (42562)

150VBFE1L1 (42563)

75-8446-PW-PE125-315

15VA01T1 (42556)

15VB03S1 (42555)

PI 75790

15VB03S1 (42554)

150VCE1S1 (42550)

150VBFE1L1 (42551)

75-8447-PW-PE125-160

25VB03S1 (42557)

DRAIN

FI 75790 / FQI 75790 (L / LL)

FIT 75790

FE 75790

150VDE1L2 (42552)

150VBFE1L1 (42553)

300VBFE1L1 (42568) NOTE 1

FI 75792 / FQI 75792 / FDI 75792 (L / H / L) NOTE 3

FIT 75792

FE 75792

NOTE 1

75-8448-PW-PE125-315

DECANT DAM 4 2000-F75-PID-PR-40004 FIM III UNDERDRAINAGE

APPROVED FOR CONSTRUCTION