FALL 30953
75\PI\5304

STOP

LOW SELECT BLOCK

PAHH 30936
PAL 30936
PAH 30936

TO KALTAILS GLAND WATER PUMP
75\PI\5304

ZSO 30932 NO
ZSC 30932
KV 30932

PAL 30934
PIC 30934
PIT 30934
50F30VB14

VSD

PIC 30936
PIT 30936
PSH 301002
150
50F30VB16

HX FDI 30940A NOTE 1 FDI 30940B NOTE 1
FI 30940
FIT 30940
FE 30940
FAL 30940
FAH 30940

KV 30938
ZSC 30938
ZSO 30938 NO

TI 03
PE | RL
560x400

KEARN'S CORNER
75\PI\5001
75-5006-FT-PE16W-560
KALTAILS LINE A

30-6001-FT-RL-400
400x250
400F30VKG72A
400x250
30-6001-FT-MH-400
400x300
400x250
F30PP78A
VENDOR PACKAGE
75\PI\5309
400x150
150F30VKG87A
400x150
30-6005-FT-MH-400
400x150
400F30VKG73A
30-6005-FT-RL-400
500x400
M
600x500
RL | PE
30-6009-FT-RL-500
30-6013-FT-PE25W-630
TO KALTAILS VALVE STATION
75\PI\5307

250F30VKG74A
RL
PE

250F30VKG76A
RL
PE
ZSC 30962
ZSO 30962
NC

150F30VKG75A
RL
PE
KV 30942
ZSC 30942
ZSO 30942
NC

175-6019-FT-PE16W-250
175-6017-PW-PE12W-250
175-6019-FT-PE16W-160

FLUSHING WATER
75\PI\5307
175-6017-PW-PE12W-250
250F30VBF47
250x50
50F30VB13

175-6089-FT-PE25W-160
175-6019-FT-PE16W-250
175-6021-FT-PE16W-250
175-6091-FT-PE25W-160
175-6023-FT-PE16W-90

175-6021-FT-PE16W-250
175-6017-PW-PE12W-250

SEAL WATER
75\PI\5304
175-6041-GW-SS-25

SEAL WATER
75\PI\5304
175-6043-GW-SS-25

PE
RL
250F30VKG76B
NC
ZSC 30963
ZSO 30963

FALL 30954
75\PI\5304

STOP

LOW SELECT BLOCK

PAHH 30937
PAH 30937
PAL 30937
PIC 30937
PIT 30937
PSH 301003
150
50F30VB17

175-6021-FT-PE16W-160

EXIST SCOUR PIT

PE
RL
250F30VKG74B

PAL 30935
PIC 30935
PIT 30935
50F30VB15

ZSO 30933 NO
ZSC 30933
KV 30933

ZSO 30939 NO
ZSC 30939
KV 30939

HX FDI 30941 NOTE 1
FI 30941
FIT 30941
FE 30941
FAL 30941
FAH 30941

TO KALTAILS GLAND WATER PUMP
75\PI\5304

TI 04
PE | RL
560x400

KEARN'S CORNER
75\PI\5001
75-5008-FT-PE16W-560
KALTAILS LINE B

400x250
400F30VKG72B
400x250
30-6003-FT-RL-400
30-6003-FT-MH-400
400x300
400x250
F30PP78B
VENDOR PACKAGE
75\PI\5309
400x150
150F30VKG87B
400x150
30-6007-FT-MH-400
400x150
400F30VKG73B
30-6007-FT-RL-400
500x400
M
600x500
RL | PE
30-6011-FT-RL-500
30-6015-FT-PE25W-630
TO KALTAILS VALVE STATION
75\PI\5307

150F30VKG75B
RL
PE
KV 30943
ZSC 30943
ZSO 30943
NC

90x50 50F30VB32
90x40
LSH 30944
LAHH 30944
LSL 30944
LIT 30944
175-6023-FT-MH-40

POTABLE WATER DISTRIBUTION
75\PI\5010
25F30VB35
25F30VC44
25F30VB36

BUND AREA
SUMP
F30PS72

VERFLOW TO PIPING CORRIDOR

LEGEND:
EXISTING
NEW
FUTURE
DECOMMISSIONED

NOTES:
1. DIFFERENTIAL FLOW CALCULATION FOR LEAK DETECTION.