Docusign Envelope ID: D3EAC8FF-146A-4610-AFF4-26203B4BB02C

F23-SR-601
FIM III BOOSTER STATION SWITCHROOM
2000-F23-DRG-EL-40001

F23PP651-VS — CAT6 — F23PP651VS-D1
F23PP652-VS — CAT6 — F23PP652VS-D1
FIM III BOOSTER STATION HV VSDs

(NOTE 4)
F23PW651VS-D1
F23PW652VS-D1
F23PW653VS-D1
F23PW654VS-D1
FIM III BOOSTER STATION LV VSDs

F23-SW-602
FIM III BOOSTER STATION
LV MOTOR CONTROL CENTRE

INCOMER
2000-F23-SCM-EL-40011
F23-GWY-602 — F23SW602-D1
BUS RS458
F23-INC-602 INCOMER
F23-PM-602 POWER METER — F23PM602-D1
F23-AFD-602 ARC FLT. DET. SYS. — F23AFD602-D1

F23-SW-601
FIM III BOOSTER STATION
HV SWITCHBOARD
F23SW601-D1
F23SW601-D2
F23SW601-D3
F23SW601-D4
F23SW601-D5
F23SW601-D6
(NOTE 4)
INCOMER PANEL A04 SEL751 RELAY
INCOMER PANEL A04 SEL735 PQM
VSD FEEDER PANEL A02 SEL751 RELAY
VSD FEEDER PANEL A03 SEL751 RELAY
TR FEEDER PANEL A05 SEL751 RELAY
SPARE FEEDER PANEL A06 SEL751 RELAY
(NOTE 1 &2)

EOL 1 … EOL n
(NOTE 4)
F23FN651-D1
F23FN652-D1
F23FN653-D1
F23FN654-D1
F23HY420-D1
F75PW665-D1
FIM III BOOSTER STATION DOL STARTER MODULES
(NOTE 1 &2)

F23-DCS-601
FIM III BOOSTER STATION SWITCHROOM DCS PANEL
2000-F23-DRG-IC-40002
F23DCS601-D1
F23DCS601-D2
F23-FCS-415 NOTE 4
F23DCS601-D5
F23DCS601-D6
F23DCS601-D3
F23DCS601-D4
F23DCS601-D7
F23DCS601-D8
(NOTE 1 &2)

F23BC601-D1 — F23-BC-601 48VDC BATTERY CHARGER
F23HF601-D1 — F23-HF-601 HARMONIC FILTER
F23UPS601-D1 — F23-UPS-601 SWITCHROOM 240VAC UPS

F75-RTU-606
DECANT DAM 4 RTU PANEL
2000-F75-SCM-IC-40002
MOTOROLA ACE3600 RTU
SERIAL
SERIAL
DATA RADIO MDS S04 — LOW LOSS 50ohm CABLE CNT-400 — SURGE SUPPRESSOR IS-B-50-LN-C2 — LOW LOSS 50ohm CABLE CNT-400 — ANTENNA YB9-61
RADIO MODEM 4G — LOW LOSS 50ohm CABLE CNT-400 — SURGE SUPPRESSOR IS-B-50-LN-C2 — LOW LOSS 50ohm CABLE CNT-400 — ANTENNA CD8195-B
(NOTE 1 &2)

F75RTU606-D2
F75RTU606-D1
F75PW606VS-D1
F75PW607VS-D1
F75PW608VS-D1
DECANT DAM 4 LV VSDs
F75PV414-D1
EOL
F23-SW-602 DECANT DAM 4 DOL STARTER MODULE

F23-COM-601
FIM III BOOSTER STATION SWITCHROOM COMMUNICATIONS RACK
2000-F23-DRG-IC-40001
F23-FIP-601 FIRE PANEL
F23-KVM-607 (KVM CONSOLE)
F23-ETH-603 (FIM III - D4 VNET 1)
F23-ETH-601 (CONTROL MODBUS)
F23-ETH-602 (CONTROL MODBUS)
STACK CABLES
HV & LV SWITCHROOM MODBUS CONNECTIONS DISTRIBUTED ACROSS 2 ETHERNET SWITCHES
F23-FOB-601
F23-ETH-606 (VNET IP2LAN DCS SWITCH)
F23-ETH-601 (FIM III - CONTROL MODBUS)
F23-ETH-604 (FIM III - WATER SERVICES)
F23-ETH-606 (FIM III D4 VNET 2)
F23-FOB-602
F23-ETH-604 (WATER SERVICES)
F23-ETH-604 (WATER SERVICES)
F75FOB557-F01 — TO FIM III TSF SWITCHBOARD 2 FOBOT 1 F75-FOB-557 REF. DRG. 2000-F75-SCM-EL-40121
(NOTE 1 &2)

DECANT DAM 4 CCTV CAMERA — F75-CAM-601 PTZ — F75CAM601-D1 — SD — F75SD601-D1 — CAT 6 — POE — F23-ETH-605 (CCTV SWITCH)
TO SALINE DAM #3 LV SWITCHROOM FOBOT F75-FOB-403 REF DRG 2000-F00-TER-IC-20017 — F75FOB601-F01

NOTES

1. REFER TO SPECIFIC COMMUNICATIONS TERMINATION DRAWINGS FOR EXTERNAL EQUIPMENT CONNECTION DETAIL.
2. COMMS CABINET, DCS PANEL, RTU PANEL, MCC & SWITCHBOARD HARDWARE/INTERCONNECTIONS (E.G. NIO NODE) & INTER-FOBOT PATCHING NOT SHOWN FOR CLARITY. REFER TO SPECIFIC COMMUNICATIONS TERMINATION DRGS FOR DETAIL.
3. CABLES RUN INDIVIDUALLY. REFER TO CABLE SCHEDULE 2000-F23-LST-EL-40003.
4. THE FCS NUMBER IS NOT DICTATED BY THE DCS EQUIPMENT NUMBER BUT BY THE DOMAIN / NETWORK IT SITS ON WITHIN THE DCS, WHICH IN THIS CASE IS DOMAIN 4, ADDRESS 15.

LEGEND

- FOB — FIBRE OPTIC BREAK OUT TRAY
- ETH — ETHERNET SWITCH HIRSCHMANN = DCS NETWORKS CISCO = ALL OTHER NETWORKS
- FCS — YOKOGAWA FIELD CONTROL UNIT
- xxxFCS4xx-NUxx (U/D) — YOKOGAWA NODE INTERFACE UNIT (DUAL OPTICAL ESB PORTS: U = UPLINK, D = DOWNLINK) TAG RELATED TO PARENT FCS
- GWY — COMMUNICATIONS GATEWAY ANYBUS ABC3028
- MC — FIBRE TO CAT6 MEDIA CONVERTER
- xxx — EQUIPMENT OR VENDOR PACKAGE PANELS AS NOTED WITHIN BLOCK.
- EOL — MCC MODULE DOL INTELLIGENT ELECTRONIC DEVICE/OVERLOAD
- UPS — UNINTERRUPTIBLE POWER SUPPLY
- VSD - VARIABLE SPEED DRIVE
- MULTI CORE FIBRE OPTIC CABLE OR DUPLEX PATCH LEAD
- CAT6 — CAT6 ETHERNET CABLE CONNECTION
- xxx-CAM-xxx (PTZ) — CCTV CAMERA (Z = FIXED (ZOOM ONLY), PTZ = PAN/TILT/ZOOM)
- SD — COMMS SURGE DIVERTER DEVICE
- POE — POWER OVER ETHERNET PORT

AS BUILT

REV	DATE	REVISION	DRN	CHK	TECH APP	APP
6	13.MAR.26	AS [redacted] FOR [redacted] III TSF	ME	JEA	MC	MSB
5	11.DEC.25	RE-APPROVED FOR CONSTRUCTION	ET	MC	KV	TH
4	11.NOV.25	RE-APPROVED FOR CONSTRUCTION	[redacted]	[redacted]	[redacted]	TH
3	09.OCT.25	RE-APPROVED FOR CONSTRUCTION				
2	08.AUG.25	RE-APPROVED FOR CONSTRUCTION	MT	[redacted]	[redacted]	
1	10.JUL.25	RE-APPROVED FOR CONSTRUCTION	[redacted]			
0	21.MAY.25	APP [redacted] FOR CONSTRUCTION	[redacted]		KVN	[redacted]

GENERAL NOTES AND STANDARD DRAWINGS INDEX — 2000-F00-STD-EL-10001

NORTHERN STAR RESOURCES LIMITED

DRA PACIFIC (PTY) LIMITED

[redacted]	J. [redacted]	06.DEC.2024
CHECKED	C. [redacted]	06.DEC.2024
DESIGNED	J. [redacted]	06.DEC.2024
TECH APP	K. [redacted]	14.APR.2025
[redacted] APP	T. [redacted]	21.MAY.2025
CLIENT APP		

PROJECT: KCGM
FIM TSF PROJECT

TITLE: FIM III BOOSTER STATION
F23-SR-601 SWITCHROOM
COMMUNICATIONS BLOCK DIAGRAM

A1 | SCALE NTS | DRG No. 2000-F23-BLK-IC-40001 | REV 6