


240VAC TERMINALS

1		F72PP656-1156	RD
2		F72PP656-240VN	BK
3			
4	⏚	EARTH	GNYE

NOTES 2, 6

F72PP656-P3
2.5 mm² 2C+E

F72PP656
MOTOR TERMINAL BOX

ANTI-COND HEATER

24VDC LOOPED POWER
NEXT MODULE
PREV MODULE

CABLE ZONE
24VDC TERMINALS

Q120	4A	F72SW172-2530	
1		F72SW172-2540	
2		F72SW172-2540	
3		F72PP656-1077	WH
4		F72PP656-1087	BK
5	⏚	SCREEN	
6		F72PP656-1200	
7		F72PP656-1230	
8		F72PP656-1230	
9		F72PP656-1242	
10		F72PP656-1262	
11		F72PP656-1282	
12			
13			
14			
15			
16			
17	⏚	EARTH	GNYE

NOTE 2

F72PP656-I1
1.5 mm² 1 Pair O/S

THERMISTORS

COMMISSIONING
BYPASS

F72PP656LCS-C1
1.5 mm² 4C+E

F72PP656-LCS
LOCAL CONTROL STATION

LOS
START
GNYE

NOTES

1. TERMINALS ON TERMINAL STRIPS ABOVE 50VAC SHALL HAVE A SEPARATE PERSPEX SHROUD AND SHALL BE LABELLED "DANGER xxxVAC".
2. WIRE NUMBER FERRULES ON TERMINAL STRIP SHALL BE PREFIXED WITH EQUIPMENT NUMBER e.g. F72PP656-1200.
3. EACH WIRE SHALL BE IDENTIFIED AT BOTH ENDS WITH FERRULES.
4. NHP TDGE2
   IN:250A IΔN MIN:0.3A TOROID TO SUIT CABLE DIAMETER. (1)
5. EARTH LEAKAGE RELAY (ELV) USER INTERFACE TO BE MOUNTED ON MCC MODULE DOOR. RELAY ENERGISED (NORMALLY CLOSED CONTACT OPEN) IN NORMAL OPERATION.
6. 240VAC TERMINALS FOR THE HEATER CIRCUITS SHALL BE LOCATED IN THE MCC DRIVE MODULE.
7. EXTERNAL CURRENT TRANSFORMER RATIO
   RED PHASE: 400/5A
   WHITE PHASE: 400/5A
   BLUE PHASE: 400/5A (1)

LEGEND

- 00/01/00 — DCS DIGITAL INPUT
- 00/02/00 — DCS DIGITAL OUTPUT
- ⊗ — MCC TERMINAL
- ◓ — VSD TERMINAL
- ◒ — FIELD TERMINAL
- ◑ — DCS OR I/O TERMINAL
- ◧ — MARSHALLING TERMINAL
- (x) — DEVICE TERMINAL
- ⊗ cc — INDICATION LAMP, cc = COLOUR

(1)

TERMINATION LEGEND

Q120	4A	F72SW172-2xxx	
1		F72SW172-2xxx	
2		F72SW172-2xxx	
3		F72PP656-1200	
4		F72PP656-1230	RD
5		F72PP656-1230	BK
6	⏚	EARTH	GNYE

CORE COLOUR/IDENTIFIER
BARRIER
FERRULE
JUMPER/DISCONNECT/FUSE/EARTH
TERMINAL No.
DESTINATION

2000-F72-SCM-EL-10657_Rev1

F72-SW-172 F72-PP-656 lime ringmain pump 1
schematic and termination diagram

O:\CAD PROJECTS\235 NORTHERN STAR RESOURCES LTD\235TI KCGM GROWTH PROJECT\03 DELIVERABLES\EL\F72 - REAGENTS MIXING & STORAGE\2000-F72-SCM-EL-10657.DWG 02DEC25 12:40PM HOTSEAT04