HOLDS:

1. PENDING VALVE TAGGING.
2. CLIENT TO CONFIRM INSTRUMENT TYPE AND/OR TAG NUMBER.
3. EQUIPMENT SIGHTED BUT NO TAG NUMBER AND/OR DESCRIPTION IS CONFIRMED.
4. CERAMIC LINED (CL). TO BE CONFIRMED BY CLIENT.

NOTES:

1. FOR GENERAL NOTES REFER TO 2000-F00-PID-PR-10001 TO 10007.
2. VENDOR FLUSHING SYSTEM IS NOT OPERATING PROPERLY.
3. REFER TO P&ID 2000-F75-PID-PR-60011 FOR GLAND WATER NETWORK.
4. PROCESS CONTROL SYSTEM CONNECTIONS NOT SHOWN, OR WHERE SHOWN NOT CONFIRMED.
5. THIS LINE WAS OBSERVED HANGING ABOVE THE SAMPLER AND WAS NOT CONNECTED TO ANY EQUIPMENT OF FITTING.
6. REFER TO P&ID 2000-F75-PID-PR-60017 FOR DETAILS ON FLUSHING WATER CONTINUATION.

ORIGINAL DRAWING:
25\PI\1000\1001\1002\1003\1004

ORIGINAL DRAWING: FME-25-PI-431