GLAND WATER DISCHARGE PUMPS
(75-PP-66C/D)
2000-F75-PID-PR-60010
GLAND WATER

19-0022-GW-PE-160

160x110

100VBF F19-65128 HOLD 3

19-0043-GW-PE-63

110x63

PE ST

50x25 25VB F19-65300 — TO 19-PP-52A

19-0040-GW-ST-25

50x25 25VB F19-65268 — 25VB F19-65269 — TO 19-PP-52B

110x63

19-0042-GW-PE-63

50VBF F19-XXXXX HOLD 1

PE ST

63x32 25VB F19-65301 — TO 19-PP-53A

19-0041-GW-ST-25

63x32 25VB F19-65302 — TO 19-PP-53B

NOT CONNECTED

25VB F30-61547

30-0087-GW-ST-25

30-0088-GW-ST-15

15VB F30-61546 — 15VB F30-XXXXX HOLD 1 — NOT CONNECTED

25VC

30-0089-GW-ST-25

15VB — TO F30-PP-04B

110x63 63x32

100VBF F30-XXXXX HOLD 1

PE ST

HOLD 2 FCV XXX

F30-61548

25VB F30-XXXXX HOLD 1 — HOLD 2 FCV XXX — 25VB F30-XXXXX HOLD 1

30-0090-GW-ST-25

PE ST

25VB F30-XXXXX HOLD 1 — HOLD 2 FT/FS XXX — 25VB F30-XXXXX HOLD 1 — TO F30-PP-04A

30-0091-GW-ST-25

19-0044-GW-PE-110

100VBF F19-XXXXX HOLD 1

PE ST

19-0047-GW-ST-80

19-0046-GW-ST-25

25VB F19-65303 — HOLD 2 FCV XXXXX — 25VB F19-65304 — TO 19-PP-54

100x80

100VBF F19-XXXXX HOLD 1

19-0047-GW-ST-25

25VB F19-IP-101 F19-65311 — 25VB F19-65312 — 25VB F19-65313

100VBF F19-XXXXX HOLD 1

50VB F19-XXXXX HOLD 1

90x63

PI XXX HOLD 2

25VB F19-65314 — HOLD 2 FCV XXXXX — 25VB F19-65315 — 25VB F19-65316 — 25VC — 19-0141-GW-ST-25 — TO 19-PP-51B

26-0049-GW-PE-63

63x32 25VB F19-XXXXX HOLD 1

HOLD 2 XX XXXX

63x32 25VB

19-0048-GW-ST-25

19-0140-GW-ST-25

HOLD 2 FCV XXXXX — HOLD 2 — HOLD 2 PI XXX — FT/FS XXXX — TO 19-PP-51A

25VB F19-65308 — 25VB F19-65309 — 25VB F19-65310

19-0050-GW-PE-63

ST PE

50VB F19-XXXXX HOLD 1

25VB F19-65727

PI XXX HOLD 2

25VB F19-65126

TO 19-PP-55

HOLD 2 FCV XXXXX

25VB F19-65305 — 25VB F19-65306 — 25VB F19-65307

V1W

PIT XXX HOLD 2

19-0051-GW-ST-50

25VB F19-65120 — 25VB F19-65121 — HOLD 2 FCV XXXXX — 25VB F19-65122 — 25VC — 25VB F19-65125 — TO 19-PP-61B

19-0053-GW-ST-25

50x25

PI XXX HOLD 2

HOLD 2 XXX XXX

25VB F19-65317

25VB F19-65123 — 25VB F19-65124

19-0052-GW-ST-50

25VB F19-65318 — 25x50

NOTE 2

25VB F19-XXXXX HOLD 1 — 25VB F19-XXXXX HOLD 1 — NOTE 2

25VB F19-65319 — NOTE 2

PI XXX HOLD 2

TO 19-PP-61A

26-0079-GW-PE-110

110x90

110x90

26-0073-GW-PE-90

80VBF F25-XXXXX HOLD 1

25-0072-GW-PE-90

80VBF F25-XXXXX HOLD 1 — TO GRADE

110x90

50VB F25-XXXXX HOLD 1

100VBF F25-XXXXX HOLD 1

50VB F25-XXXXX HOLD 1

25-0070-GW-PE-63

50VB F25-62793

PE ST

63x25 25VB F25-62794 — TO 25-PP-04A

63x25 25VB F25-62795 — TO 25-PP-04B

25-0071-GW-ST-25

FCV XXXXX HOLD 2

26-0074-GW-PE-63

PE ST

50x25 — 25VB F26-62995 — TO F26-PP-41A/B

50x25 — 25VB F26-62996 — TO F26-PP-41A/B

26-0075-GW-ST-25

90x63

PE ST

50VB F26-62994

26-0077-GW-ST-50

50x25 25VB F26-62992 — XX XXX HOLD 2,7 — 50x25 25VB F26-62993

TO 26-PP-42A HOLD 7

26-0078-GW-ST-25

TO 26-PP-42B HOLD 7

90x63

PE ST

50VB F26-62989

HOLD 3 50VB F26-62990 — TO 26-PP-31A (NOTE 3)

50VB F26-62991 — TO 26-PP-31B (NOTE 3)

26-0076-GW-ST-50

XX XXX HOLD 3

100VBF F25-62992

1100D

100VBF F25-62991

25-0065-GW-PE-110

100VBF F25-62888

PE ST

25-0066-GW-ST-50

50x25 25VB F25-62889 — TO F25-PP-02A

50x25 25VB F25-62890 — TO F25-PP-02B

25-0151-GW-ST-25

100VBF F25-62884

PE ST

25-0067-GW-ST-50

50x25 25VB F25-62885 — TO F25-PP-05A

50x25 25VB F25-62886 — TO F25-PP-05B

25-0152-GW-ST-25

100VBF F25-62879

PE ST

25-0068-GW-ST-50

50x25 25VB F25-62877 — TO F25-PP-61A

50x25 25VB F25-62878 — TO F25-PP-61B

25-0153-GW-ST-25

100VBF F25-62880

PE ST

25-0069-GW-ST-50

50x25 25VB F25-62881 — TO F25-PP-62A

50x25 25VB F25-62882 — TO F25-PP-62B

25-0154-GW-ST-25

100VBF F25-62887 — FCV XXX HOLD 2 — 25VB F25-62855 — FCV XXX — 25VB F25-62856 HOLD 2

100VBF F25-62883 — 25VB F25-62857 — FCV XXX — 25VB F25-62858 HOLD 2

25-0063-GW-ST-25

50x25 25VB F25-62854 — DN25 HOLD 4,5 — 25VB F25-62859 — TO 25-PP-63B

50x25 25VB F25-62848 — 25VB F25-62851 — FCV XXX — 25VB F25-62852 HOLD 2 — DN25 HOLD 4,5 — 25VB F25-62853 — DN25 HOLD 4,5 — FT XXXXX HOLD 2 — TO 25-PP-63A

25-0062-GW-ST-25

25VB F25-62849 — 25VB F25-62850

25-0064-GW-ST-25

50VB F25-62847

PI XXX HOLD 2

HOLD 8 XXVB F25-62820

100VBF F25-XXXXX HOLD 1

25-0055-GW-ST-50

50VB F25-XXXXX HOLD 1

PE ST

100x50

100VBF F25-XXXXX HOLD 1

25-0054-GW-PE-110

100VBF F25-XXXXX HOLD 1

160x110

GLAND WATER DISCHARGE PUMPS
(75-PC-66C/D)
2000-F75-PID-PR-60010
GLAND WATER

75-0023-GW-PE-160

25-0056-GW-ST-25

25VB F25-62861 — FIT 25194 HOLD 2 — 25VB F25-62862 — HOLD 2 FCV XXXXX — 25VB F25-62863 — TO 25-PP-19

25VB F25-62864 — HOLD 2 FCV XXXXX — 25VB F25-62865

25-0060-GW-ST-25

25-0057-GW-ST-25

25VB F25-62866 — FIT 25204 HOLD 2 — 25VB F25-62867 — HOLD 2 FCV XXXXX — 25VB F25-62868 — TO 25-PP-20

25VB F25-62869 — HOLD 2 FCV XXXXX — 25VB F25-62870

25-0061-GW-ST-25

25-0058-GW-ST-25

25VB F25-62872 — FIT 25214 HOLD 2 — 25VB F25-62873 — HOLD 2 FCV XXXXX — 25VB F25-62874 — TO 25-PP-21

25VB F25-62875 — HOLD 6 — 25VB F25-62876

50VB F25-62871

AREA 19 CIRCUIT
WATER DISTRIBUTION
2000-F19-PID-PR-60007
CIRCUIT WATER

19-0014-CTW-PE-63

PE ST

50VB F19-XXXXX HOLD 1

NOTES:

1. FOR GENERAL NOTES REFER TO 2000-F00-PID-PR-10001 TO 10007.
2. OPEN PIPING.
3. GLAND WATER LINE EXISTS BUT NOT CONNECTED TO 26-PP-31A/B. THESE PUMPS HAVE A SEPARATE SOURCE OF GLAND WATER SUPPLY.REFER TO WASHDOWN WATER DISTRIBUTION P&ID 2000-F75-PID-PR-60021 FOR ALTERNATIVE SOURCE OF SUPPLY FOR GLAND WATER.
4. PROCESS CONTROL SYSTEM CONNECTIONS NOT SHOWN, OR WHERE SHOWN NOT CONFIRMED.

HOLDS:

1. PENDING VALVE TAGGING.
2. CLIENT TO CONFIRM INSTRUMENT TYPE AND/OR TAG NUMBER.
3. THE LOCATION OF CHANGE IN LINE SIZE AND VALVE SIZE - TBC AT SITE
4. COVERED WITH MUD. DETAILS - TBC BY CLIENT.
5. CHECK VALVES - TBC BY CLIENT.
6. CHECK VALVE OR A STRAINER - TBC BY CLIENT.
7. THE WATER SOURCE DURING VARIOUS SITE VISITS CHANGED (i.e. NOT CONNECTED TO GLAND WATER COUPLING WHEN LAST SEEN). WATER SOURCE AND INSTRUMENT DETAILS - TBC BY CLIENT.
8. SIZE AND/OR PIPE CLASS TBC.