INSTRUMENT AIR NETWORK
2000-F81-PID-PR-60011
INSTRUMENT AIR

78-0128-IA-ST-80
80x50
50VB F65-63785
50VB F81-IP-009 F65-63784
50x25
25VB F65-63786
KV 651048 25VB F78-63783
KV 651009
KV 651007
KV 651005
20VB F78-6380
HOLD 2 VALVE (BOTTOM GATE ACTUATOR) AT SECOND PACKED BED WET SCRUBBER F65-WS-71 BOTTOM
XXX XXXX
25VB F65-XXXXX HOLD 1
65-0153-IA-ST-25
FV 651011
25VB 65-IP-265 F78-63782
65-0152-IA-ST-25
25VB F78-63781
FV 651003
78-0150-IA-ST-50
50VB F78-63480
50VB F78-63469
HOLD 2 PSV XXXX
DN32
50VB F78-63481
PI XXXX
HOLD 2
15VB F78-63467
F78-RA-72
KILN 5 INSTRUMENT AIR RECEIVER
80x50
50VB F78-63469
78-0149-IA-ST-15
T
15VB F78-63482
15VB F78-63483
78-0156-IA-ST-50
DN50 DN25
25x20
20VB F81-IP-104 F78-XXXXX HOLD 1
HOLD 2 PI XXXX XXX XXXX
20VB
TO REGENERATIVE THERMAL OXIDISER INSTRUMENT AIR ACCUMULATOR F78-PV-71
78-0151-IA-ST-25
ST PE
25VB F78-63466
25x20
20VB F78-63464
15VB F78-63460
KV 78183 KV 78184 KV 78187
KV 78188 KV 78256
20VB F78-63465
KV 78189 KV 78287
KV 78190 KV 78289
KV 78191 KV 78290
KV 78255 KV 78297
PE ST
15VB F78-63461
78-0154-IA-PE-20
15VB F78-63462
15VB F78-63463
R
AT GRADE LEVEL (TOWARDS AREA 65)
TO 78-MA-01 AREA 78 MERCURY ANALYSER
78-0155-IA-ST-25
20VB F78-63484
KV 78102 KV 78126
KV 78127 KV 78128
KV 78131 KV 78132
KV 78248
25VB F78-63489
KV 78453
25VB F78-63470
HOLD 2 XXX XXXX
78-0157-IA-ST-25
25VB F78-XXXXX HOLD 1
78-0158-IA-ST-25
20VB F78-63486
KV 78253
KV 78254
KV 78260
25VB F78-63487
DN25
78-0159-IA-ST-25
20VB F78-63488
KV 78444 KV 78447
KV 78448 KV 78236
KV 78237 KV 78238
KV 78239
20VB F78-63485
KV 78216 KV 78217
KV 78218 KV 78219
KV 78446 KV 78162
FLOCC WATER ADDITION VALVE TO MTC THICKENER
HOLD 4 NOTE 4
FV 19587
15VB F19-IP-094 F19-65105
25x15
19-0148-IA-ST-25
20VB F19-65215 20x25
KV 19584A KV 19584B
19-CP-59
MTC THICKENER U/F 52A/B DUMP VALVES
15VB F19-65211
25VB F19-65210
HOLD 1
25VB F19-XXXXX HOLD 1
25VB F19-65206
KV 19589B KV 19589A
19-CP-03
MTC THICKENER U/F CIRCUIT KNIFE GATE VALVES PNEUMATIC CONTROL PANEL
25VB F19-65211
MTC THICKENER U/FLOW PUMP F19PP52A/B SUCTION VALVES
FV 19574A FV 19574B
HOLD 3
F19-IP-055 F19-65212
F19-IP-056 F19-65213
NOTE 3 HOLD 4
FCV 19522
MTC BALL MILL DISCHARGE WATER CONTROL VALVE
25VB F19-65208 F19-65209
FV 19526B FV 19525B FV 19526A FV 19525A
25VB F19-65207
HOLD 1
NOTE 7
25VB F19-65208
FV 19523B
15VB F19-65176
15VB F19-65177
15VB F19-65178
R
COPPER SULPHATE CuSO4
FCV 19770
FV 19523A
25VB F19-65174
15VB F19-65175
KV 19530B KV 19530C KV 19530A KV 19530D
25VB F19-65220 25VB F19-65221 25VB F19-65222 25VB F19-65223
19-0161-IA-ST-40
19-0162-IA-ST-25
25VB F19-65225 25VB F19-65226 25VB F19-65227 25VB F19-65228
F R
ST PE
15VB F19-65229
HOUSING WITH LASER RADIATION WARNING AT CONVEYOR CV53 (NEAR CHUTE F15CH01)
HOUSING WITH LASER RADIATION WARNING AT CONVEYOR 15CV03 IN RECYCLE CRUSHER AREA
40x25
50x40
50x25
25VB F19-65224
NEAR CONVEYOR F19CV20 ISPLATOR 19-HS-64
HOLD 4
MTC SAG MAIN FEED WATER VALVE
KV 19504
FCV 19501
25VB F19-65219
FIM SAG WATER ADDITION SHUT-OFF VALVE
FV 19615
15VB F19-65331
25x15
25VB F19-65333
NOTE 3
FCV 19622
F R
25VB F19-XXXXX HOLD 1
25VB F19-65334
KV 19656
15VB 25x15 F19-65336
FIM SCATS DIVERTER GATE (TO 19-CV-21 SCATS CONVEYOR CHUTE)
19-0165-IA-ST-25
19-0164-IA-ST-25
25VB F19-65332
50VB F19-XXXXX HOLD 1
19-0166-IA-ST-50
50VB F19-XXXXX HOLD 1
25VB F19-XXXXX HOLD 1
19-0163-IA-ST-25
ST PE
25x20
20VB
15VB
FV 19660
BALL CHARGING BIN 61A- BALL RELEASE VALVE
F19-XXXXX F19-XXXXX HOLD 1
19-0170-IA-ST-25
25VB F19-65142
25x15
HOLD 3 F19-65143
F R
SV 19659
TO DIVERTOR GATE 19-DG-62 SOLENOID
NOTE 3
F19-XXXXX HOLD 1
PI XXXX HOLD 2
19-0171-IA-ST-15
FV 19661
BALL CHARGING BIN 61B - BALL RELEASE VALVE
15VB F19-XXXXX HOLD 1
FV 19662
BALL CHARGING BIN 61C - BALL RELEASE VALVE
15VB F19-65339
25VB F19-65378
25x15
15VB F19-65140
19-169-IA-ST-25
25VB F19-65141
40x25
19-168-IA-ST-25
NOTE 3,4
25x15
15VB F19-IP-255 F19-65330
FCV 19601
FILM SAG FEED WATER CONTROL VALVE
50VB F19-XXXXX HOLD 1
19-167-IA-ST-25
TOWARDS SAG MILL
25VB F19-XXXXX HOLD 1
25VB F19-XXXXX HOLD 1
25VB F19-XXXXX HOLD 1
40x25
SAG MILL LUBE AREA
25VB F19-65336
INSTRUMENT AIR NETWORK
2000-F81-PID-PR-60011
INSTRUMENT AIR
19-0129-IA-ST-80
80VB F19-65144
80VB F19-65145
50VB F19-65146
HOLD 7
15VB F19-IP-190 F19-65216
FCV 19583
15VB F19-65217
19-1147-IA-ST-15
ST PE
15VB F19-XXXXX HOLD 1
HOLD 1
19-0130-IA-ST-50
50VB F19-XXXXX HOLD 1
50x25
25VB F19-XXXXX HOLD 1
T
19-0131-IA-ST-50
25VB F19-65148 25VB F19-65147
50VB F19-65151
50VC
MTC DEWATER SCREEN WASH WATER VALVE
FV 19559
19-0146-IA-ST-25
15VB F19-IP-086 F19-65203
15VB F19-XXXXX HOLD 1
19-0144-IA-ST-25
25VB F19-65218
15VB F19-65204
FV 19582
19-0143-IA-ST-50
50x25
50VB F19-XXXXX HOLD 1
25VB F19-XXXXX HOLD 1
19-0142-IA-ST-25
19-0141-IA-ST-25
19-0140-IA-ST-50
50VB F19-65160
19-0133-IA-ST-25
25VB F19-IP-156 F19-65152
50VB F19-IP-161 F19-65153
KV 19375
KV 19374
KV 19383
20VB F19-65186
50x25
50VB F19-65155
50VB F19-IP-160 F19-65154
50VC
50x25
F19MS61-RA61
PV6 INSTRUMENT AIR RECEIVER
20x15
50x25
50VB F19-65156
HOLD 2 PI XXXX
15VB F19-65150
PI XXXX HOLD 2
KV 19353B KV 19353A KV 19352B KV 19352A
19-CP-41
25VB F19-65180
KV 19355B KV 19355A
19-CP-43
15VB F19-65181
19-0132-IA-ST-25
19-0134-IA-ST-50
PE ST
19-0135-IA-ST-25
HOLD 2 FCV 19354
WATER FEED LINE VALVE TO HOPPER F19HP53
15VB F19-65184
15VB F19-65183
R
25VB F19-65182
50x25
50VB F19-65185
25x50
HOLD 2 FCV 19771
MTC FLOAT FEED PAX DOSING STATION ACUATE VALVE
19-0136-IA-ST-25
25VB F19-65164
25VB F19-65163
KV 19893A KV 19893B
25VB F19-65166 25VB F19-65165
15VB F19-65168
15VB F19-65169
15VB F19-65157
SV XXXX
DRAIN
HOLD 2
25x15
25VB F19-XXXXX HOLD 1
19-0160-IA-ST-25
25VB F19-65161
19-0137-IA-ST-25
25VB F19-65170
25VB F19-65173
25VB F19-65171
15VB F19-65172
KV 19251 KV 19258 KV 19280 KV 19281
KV 19288 KV 19289 KV 19290
SOLENOID CONTROL PANEL F19-CP-22
15VB F19-65168
15VB F19-65167
LCV 19252
FV 19520
NOTE 3
MTC GRAVITY CONCENTRATOR TRANSFER WATER TO F19PP55
MTC GRAVITY CONCENTRATOR F19HP55 WATER CONTROL
LV 19287
15VB F19-IP-194 F19-65201
NOTE 3,5
LV 19282
15VB F19-IP-195 F19-65200
NOTE 3,5
NOTE 5
25VB F19-XXXXX HOLD 1
FCV 19262
15VB F19-65200
19-0139-IA-ST-25
SOLENOID CONTROL PANEL F19-CP-20
KV 19257 KV 19259 KV 19260
25x15
15VB F19-XXXXX HOLD 1
SOLENOID CONTROL PANEL F19-CP-74
KV 19893A KV 19893B
25VB F19-65179
15VB 25x15 F19-65162
KV 19283 KV 19284
KV 19286
SOLENOID CONTROL PANEL F19-CP-21
KV 19625A KV 19626A KV 19643A
KV 19625B KV 19626B KV 19643B
25VB F19-XXXXX HOLD 1
DN25 ACTUATED VALVE ON COPPER SULPHATE LINE NEAR SAG MILL 19MS61
FCV 19621
NOTE 3

NOTES:

1. FOR GENERAL NOTES REFER TO 2000-F00-PID-PR-10001 TO 10007.
2. PROCESS CONTROL SYSTEM CONNECTIONS NOT SHOWN, OR WHERE SHOWN NOT CONFIRMED.
3. TAG NUMBER NOT SEEN IN FIELD AND IS AS PER ORIGINAL PLANT P&ID.
4. TAG NUMBER NOT SEEN IN FIELD AND IS AS PER ISOLATION POINT REGISTER.
5. LINE/TUBING - BROKEN.

HOLDS:

1. PENDING VALVE TAGGING AT SITE.
2. CLIENT TO CONFIRM INSTRUMENT TYPE AND/OR TAG NUMBER.
3. VALVE SIZE AND/OR TYPE TBC AT SITE.
4. TUBING RUNS IN CABLE TRAY. UNIDENTIFIED USER. TBA/TBC BY CLIENT.
5. IT SEEMS THIS VALVE EXIST. THIS IS COVERED WITH MUD AND SO EXISTENCE OF THIS VALVE AND VALVE SIZE - TBC BY CLIENT.
6. IP REGISTER DETAIL NOT MATCHING WITH ACTUATED VALVE NUMBERS TAKEN FROM ORIGINAL P&ID. CLIENT TO CONFIRM IF ACTUATED VALVE NUMBERS FCV-19287 AND LV-19282 SWAPPED IN THE IP REGISTER.
7. TO A PANEL. UNIDENTIFIED USER. TBA/TBC BY CLIENT.