INSTRUMENT AIR DESICCANT DRYER
(F81-RA-35A/B)

2000-F81-PID-PR-60010
INSTRUMENT AIR

81-0016-IA-ST-80

65-0001-IA-ST-80

INSTRUMENT AIR DISTRUBUTION
2000-F81-PID-PR-60017
INSTRUMENT AIR

INSTRUMENT AIR RINGMAIN NETWORK
2000-F81-PID-PR-60015
INSTRUMENT AIR

30-0017-IA-ST-80

65-0018-IA-ST-50

65-0019-IA-ST-50

65-0020-IA-ST-25

65-CP-80

30-0021-IA-ST-50

30-0022-IA-ST-25

30-0023-IA-ST-50

30-0024-IA-ST-25

30-0025-IA-ST-25

30-0026-IA-ST-25

30-0027-IA-ST-25

30-0028-IA-ST-15

30-0029-IA-ST-15

30-0030-IA-ST-15

30-0031-IA-ST-15

30-0032-IA-ST-40

30-0033-IA-ST-40

30-0027I-IA-ST-25

30-0047-IA-ST-25

30-0270-IA-ST-25

30-0048-IA-ST-25

30-0046-IA-ST-15

30-0050-IA-ST-15

30-0051-IA-ST-25

30-0045-IA-ST-25

30-0044-IA-ST-50

30-0043-IA-ST-25

30-0042-IA-ST-25

30-0041-IA-ST-25

30-0040-IA-ST-15

30-0037-IA-ST-25

30-0036-IA-ST-25

30-0035-IA-ST-25

30-0039-IA-ST-50

30-0038-IA-ST-50

TAILS SAMPLER TERTIARY DIVERTER VALVE

KV 30778

SV 30780 HOLD 5 NOTE 3

LAUNDER VALVES F30LGV65F & XXX

NOTE 5

FV 30647B FV 30647A

FV 30646A FV 30646B

FV 30645A FV 30645B

SAMPLER VALVE FROM CIL3 TAILS LAUNDER

XXX 30701D XXX 30701C XXX 30648

FV 30701B FV 30701A

SV 65971 SV 65960 SV 65961 SV 65970

FV 30680 KV 65962

TO A PANEL (NEXT TO SCREEN SPRAY WATER CONTROL PANEL AT CARBON SAFETY SCREEN FLOOR

30-CP-78 GLAND WATER SUPPLY SYSTEM CONTROL PANEL

XX XXXX XX XXXX XX XXXX HOLD 2

AT SCREEN F30-SC-64A/B FLOOR

TO A PANEL ON SCREENS F30SC64A/B FLOOR

AT CARBON SAFETY SCREEN FLOOR

SV 30772 NOTE 3 HOLD 5

SV 30775 NOTE 3

SV 30776 HOLD 5 NOTE 3

HOLD 5 UNKNOWN DESTINATION

30-CP-80(TK62A OXYGEN INJECTION SYSTEM KNIFE GATE ISOLATION VALVES PNEUMATIC CONTRL PANEL)

KV 30645 KV 30646 KV 30647

KV 65352 KV 65354 KV 65355 KV 65356 KV 65355 KV 65396

KV 65950 KV 65941 KV 65940 KV 65951

KV 6597 KV 65719 PI 65942

PI XXXX HOLD 2

FV 65350 NOTE 3

FV 30631A FV 30631B

AV 30620 AV 30622

CARBON SAFETY SCREEN SPRAY WATER VALVE PANEL

FV 30702D FV 30702C FV 30702B FV 30702A

NEAR F30TK64 PLANT SPILLAGE TRANSFER TANK

POLY TUBING TO LPS STORAGE VESSEL F81-TK-01 AREA

BURRIED POLY TUBING

150VBF VALVE D/S OF MAG FLOW 9D_SGT04-FLM05.

TO SGD_VBF160_ISO_52 TO SSRT_VBF200_ISO_25

SOLENOID CONTROL PANEL 30-CP-79

KV 30732 KV 30733

30PP62B TAILS PUMP TO "B" TAILS LINE

30PP62D TAILS PUMP TO "B" TAILS LINE

FV 30643B FV 30643A NOTE 3

FV 30644A FV 30644B

FV 30345A FV 30345B

FV 30346A FV 30346B

FV 30347A FV 30347B NOTE 3

FV 30343A FV 30343B

FV 30344A FV 30344B

FCV 30378

FV 3014F FV 3014D

XXX XXXX ACTUATED LAUNDER VALVE FROM CIL1 2B TO 2C HOLD 2

XX 30084 CIL 1 PbNO3 FLOW

XX 3013 CIL 1 LIME ADDITION VALVE F3013

HS 30500 CIL NO.1 FEED SAMPLER HAND STATION PANEL

HOLD 5 TOWARDS CYANIDE DOSING STATION F30-DS-01

CIL NO.1 FEED SAMPLER HAND STATION PANEL

30SM52 CIL1 TAILS SAMPLER CONTROL BOX

XX XXXX HOLD 2

CYNOPROBE ANALYSER UNIT / CONTROL PANEL (NEAR NORTH DAM)

KV 3089 KV 3090 KV 3091 KV 3092 KV 3093 KV 3094

KV 30100A KV 30100B

HS 65910 HOLD 5,7

HS 30720A HS 30721A HS 30722A HS 30723 HS 30722B HS 30721B HS 30720B HS 30724 HS 30725

HS 30720D HS 30721D HS 30722D HS 30720C HS 30721C HS 30722C HS 30726

HOLD 3

HOLD 4

HOLD 6

OPEN AT GRADE

NOTES:

1. FOR GENERAL NOTES REFER TO 2000-F00-PID-PR-10001 TO 10007.
2. PROCESS CONTROL SYSTEM CONNECTIONS NOT SHOWN, OR WHERE SHOWN NOT CONFIRMED.
3. TAG NUMBER NOT SEEN IN FIELD AND IS AS PER ORIGINAL PLANT P&ID.
4. IF THE POLY TUBING IS CONNECTED TO THE 30JB3020 THEN THE INSTRUMENTS SHOWN BELOW ARE THE USERS.
5. ONE OUT OF THESE TWO VALVES NOT CONNECTED AND THE OTHER ONE CONNECTED VIA A REGULATOR.

HOLDS:

1. PENDING VALVE TAGGING AT SITE.
2. CLIENT TO CONFIRM INSTRUMENT TYPE AND/OR TAG NUMBER.
3. VALVE TYPE TBC AT SITE. NOT VISIBLE AT TIME OF INSPECTION.
4. VALVE SIZE TBC AT SITE.
5. TUBING RUNS IN CABLE TRAY / PIPE CONDUIT . UNIDENTIFIED USER. TBA/TBC BY CLIENT.
6. TUBING RUNS IN PIPE RACK . UNIDENTIFIED USER. TBA/TBC BY CLIENT.
7. IT SEEMS THAT THIS SUPPLIES AIR TO KV65910 ONLY. IN CASE THIS FEEDS TO 65-CP-69 THEN ADDIDITIONAL USERS ARE KV65908 & KV65909. TBC BY CLIENT.