NOTE:
1. EXISTING MAGNETIC FLOW METER REPLACED AS PART OF THE CIL 3 TANKS REPLACEMENT PROJECT.
2. TEE PROVIDED FOR TEMPORARY CONSTRUCTION TIE-IN.

LEGEND
EXISTING
NEW
DEMOLISH

2000-F75-PID-PR-10003 BORE WATER
75-611-BW-PE-355
2000-F17-PID-PR-10002 FLOTATION TAILINGS U/F PUMPS
30-3028-FS-PE10-355
2000-F81-PID-PR-10002 FLOTATION TAILINGS THICKENER U/F
81-606-CA-MS-050
81-607-IA-MSG-050
30-3061-IA-MSG3-25
F30-CP-402 CONCENTRATE THICKENER RECYCLE VALVE CONTROL PANEL
25VB03S1 F30-12539
30-619-IA-MSG-025
30-3060-IA-MSG3-25
25VB03S1 F30-12680
30-603-IA-MSG-025
30-604-IA-MSG-015
30-618-IA-MSG-025
30-600-CA-MS-025
30-601-CA-MS-025
30-606-CA-MS-025
F30-CP-401 CONCENTRATE THICKENER U/F PUMPS VALVE CONTROL PANEL
25VB03S1 F30-12541
REAGENTS
FME-70-PI-459
70-607-FL-PE-063
CONCENTRATE THICKENER FLOCCULANT DOSING PUMP
2000-F72-PID-PR-10016 FLOCCULANT
30-4024-FL-PE8-63
W118027
2000-F18-PID-PR-10001 SIGNAL
FLOTATION TAILS
FME-25-PI-433
25-605-FS-RL-400 NOTE 5
FINAL CONCENTRATE PUMPS
2000-F18-PID-PR-10001 FLOTATION SLURRY
30-3021-FS-PE10-280
CONCENTRATE THICKENER UNDERFLOW PUMP
2000-F30-PID-PR-10002 CONCENTRATE
30-3024-CON-RL1-150
2000-F75-PID-PR-10003
30-600-PW-PE-160
30-3026-PW-PE8-160
30-3020-FL-SS1-50
30-3130-PW-PE8-90
30-3118-PW-PE8-160
30-3102-FS-PE10-280
30-3103-FS-RL1-250
30-3101-FS-RL1-250
30-3117-FD-PE10-90
30-602-PW-PE-063
30-606-PW-PE-090
30-605-PW-PE-090
30-3074-PW-PE8-160
30-3131-FL-PE8-90
30-600-FL-XS-025
30-601-FL-XS-025
30-600-FS-RL-350
30-601-FS-RL-350
30-603-FS-RL/MH-350
30-605-FS-PE-355
30-604-FS-PE-355
30-609-GW-MS-015
30-608-GW-MS-025
30-641-PW-MS-600
TO 75-TK-61
2000-F75-PID-PR-10007
30-904-FS-PE10-355
2000-F30-PID-PR-10019
30-TH-61 BED PRESSURE
2000-F30-PID-PR-10002 SIGNAL
FME-30-PI-438
FILTER FEED TANKS FEED BOX
35-3009-FS-RL1-250
2000-F35-PID-PR-10001 FLOTATION SLURRY
BYPASS TO FINAL TAILS
CONCENTRATE THICKENER UNDERFLOW PUMP 1
2000-F30-PID-PR-10002 CONCENTRATE
CONCENTRATE THICKENER UNDERFLOW PUMP 2
2000-F30-PID-PR-10002 CONCENTRATE
CONCENTRATE THICKENER UNDERFLOW SUCTION
2000-F30-PID-PR-10002 PROCESS WATER
CYANIDE CONTROLLER
2000-F71-PID-PR-10001 RATIO
CONCENTRATE THICKENER FLOCCULANT DOSING FLOW
2000-F72-PID-PR-10016 SIGNAL
LOCAL CONTROL PANEL SEE VENDOR DRG
VENDOR PACKAGE
SP BELOW AT THICKENER GANTRY
SP BELOW THICKENER
SP @ THICKENER BRIDGE
TO GRADE
MECH
NOTE 11

NOTES:
1. FLOWMETE D FV30649A/B ARE EXISTING AND INSTALLED. ROJECT.
2. REPURPOS 606.
3. REMOVE EXISTING THICKENER U/F SUCTION ELBOWS FOR NEW TIP-1026/1027. NO ADDITIONAL REMOVAL REQUIRED.
4. REMOVE LINE 25-605-FS-RL-400 ON PIPERACK TO ALLOW FOR SPACE FOR NEW LINES F30-3024-CON-PE16-160
5. REMOVE LINE 25-605-FS-RL-400 ON PIPERACK TO [redacted] FOR SPACE FOR NEW LINES IN STAGE 2.
6. PIPING 30-605-FS-PE-355 AND 30-604-FS-PE-335 [redacted] REMOVED DOWNSTREAM OF VALVE STATION TO ALLOW FOR [redacted] IN PIPERACK.
7. MANUAL OPERATED VALVE WITH PROXIMITY SWIT
8. EXISTING FEED BE REMOVED AND REPLACED BY NEW FEEDBOX
9. CASCADE MODE [redacted] FOR FIC30616 USING MANUALLY INPUT FLOCCULANT DOSAGE IN G/T
10. RUBBER LINED PREFORMED SLURRY HOSE REDUCER 0
11. NEW FLOWMETER CONTROLS EXISTING FLOCCULANT [redacted] DURING STAGE 1 AND THE NEW CONCENTRATE THICKENER FLOCCULANT D UMP IN STAGE 2

30-TV-61 FLOTATION TAILS THICKENER U/FLOW TECH TAYLOR VALVE
30-PS-63 FLOTATION TAILINGS AREA WASHDOWN [redacted]

30-FD-441 CONCENTRATE THICKENER FEED BOX NOTE 8
30-FD-63 FLOTATION TAILINGS THICKENER FEED BOX
30-TH-61 FLOTATION TAILINGS THICKENER No3 CONCENTRATE THICKENER
30-PP-61A/B FLOTATION TAILINGS THICKENER No.3 U/FLOW [redacted] No.1 & 2

TYPICAL FV INSTRUMENT ARRANGEMENT WITH REMOTE SOLENOID

LEGEND
EXISTING
NON-EXISTENT
STAGE 1 - NEW
STAGE 1 - REMOVE
STAGE 1 - DECOMMISSIONED (OTHERS)
STAGE 2 - NEW
STAGE 2 - REMOVE
STAGE 2 - DECOMMISSIONED (OTHERS)