20\PI\1003 CONCENTRATE TRANSFER BALL MILL #1 20-121-MS-PE/PN16-75

20\PI\1004 CONCENTRATE TRANSFER BALL MILL #2 20-221-MS-PE/PN16-75

19\PI\1005 CONCENTRATE TRANSFER MIC BALL MILL 19-015-MS-PE/PN16-75

LAH 66700 / LI 66700

LT 66700

66-306-FD-PE-63

KV 66702

80V801

66-303-MS-PE-90

TO GRADE AT BM1 SUMP RAMP

O/F

66-302-MS-PE-225

TO GRADE

WE 66701 ×4

LOAD CELLS

WT 66701

WI 66701

F66HP01

CONCENTRATE SETTLING CONE

KV 66703

100V801

KV 66704

50V801

WASH WATER

66\PI\1501

66-408-WW-PE-63

SS2 PEDC1

66-3062-CN-SS2-25

66-301-MS-RL-100

MAKEUP WATER VALVE KV 66711

SPRAY VALVE KV 66712

REACTOR LEVEL LI 66720 / LAH 66720 / LAL 66720

FLUSH VALVE KV 66721

WASTE VALVE KV 66722

PREGNANT DRAIN VALVE KV 66723

LEACH OVERFLOW KV 66724

DESLIME OVERFLOW KV 66725

REACTOR DECANT LEVEL 2 KV 66726

SOLUTION TANK PREGNANT RETURN VALVE KV 66727

LEACH DECANT RETURN VALVE KV 66728

REACTOR DECANT LEVEL 1 KV 66729

FT 66710 / FE 66710 / FI 66710 / FQ 66710

TIE-IN #406

66-406-POT-PE-90

POTABLE WATER

15VB03S1 F66-12800

25VBE1S1 F66-12799

NOTE 5 TIP 1045

90x63 / 90x32

T3 V23

T2 V24

POTABLE WATER INLET

T8 CONCENTRATE IN

LT 12 REACTOR LEVEL

V44 V37 V38 V29 V28 V32 V39 V31 V30

CYANIDE DISTRIBUTION MANIFOLD

CYANIDE

50VD

PI

T5 V21 CYANIDE INLET

FIT 10

25VBE1S1 F66-12804

15VB03S1 F66-12803

25VBE1S1 F66-12802

50VD

KV 66716

FQ 66713 / FI 66713

NOTE 5 TIP 1044

CAUSTIC TRANSFER PUMP DISCHARGE RINGMAN

CAUSTIC

50VD 50VD

T4 V22 CAUSTIC INLET

FIT 11

KV 66714

FQ 66715 / FI 66715

20\PI\1500 66-421-GW-PE/PN10-32 GLAND WATER

T17 GLANDWATER INLET

FE 66718 / FT 66718 / FI 66718 / FQ 66718

66\PI\1501 66-407-CW-PE-90 WASH WATER

T1 PROCESS WATER INLET

20\PI\1501 66-405-IA-MSG-25 INSTRUMENT AIR

25x15

T19 INSTRUMENT AIR INLET

TIE-IN #404D

66-404-PA-MS-25 PLANT AIR

25x15

T18 PLANT AIR INLET

T12 REACTOR DRAIN V45

DN50 TO GRADE

V40 V50 V46 V43 V42 V34 V41 V33 V35

KV 66717 BARREN ELUATE MAKEUP VALVE

KV 66731 PREG. DISCHARGE VALVE

KV 66732 SOLUTION TANK DISCHARGE

KV 66733 SOLIDS DISCHARGE

KV 66734 ACACIA FEED VALVE

KV 66735 D/C PUMP GLAND WATER

KV 66736 SOLIDS SUCTION FLUIDISATION VALVE

KV 66737 DESLIME OVERFLOW DISCHARGE

KV 66738 DIAPHRAM PUMP AIR SUPPLY

KV 66739 DESLIME WATER VALVE

ACACIA REACTOR

REFER VENDOR P&ID 4862-6000-01-101

F66FS01	LEACH A10 SCREW FEEDER (0.75kW)
F66TK01	SOLUTION TANK
F66AG01	SOLUTION TANK AGITATOR (0.75kW)
F66PP01	REACTOR FEED PUMP (5.5kW)
F66PP03	REACTOR DISCHARGE PUMP (30kW)
F66PP02	REACTOR DRAIN PUMP (PNEUM.)
F66AR01	REACTOR

F66 HT 01, 02 & 03 SOLUTION TANK HEATERS (3x40kW)

LAH 66760 / LI 66760

LT 66760

M

F66PS01 ACACIA AREA SUMP PUMP

25V301

50V801

63x50

KV 66761

50V801

75x63

66-308-FD-PE/PN16-75

TO CIL FEED BOX

EMERGENCY O/F (MECH)

20\PI\1003 TO BALL MILL GRAVITY CIRCUIT

14-3037-CN-PEDC1-32 GRAVITY CONCENTRATE HOPPER 2000-F00-PID-PR-10101 CYANIDE

14-3036-NS-PE8-32 GRAVITY CONCENTRATE HOPPER 2000-F14-PID-PR-10003 CAUSTIC

66-780-PE-PE-50 TO BYPASS TANK 66\PI\1002

25V301 TO GRADE

TI 19

66-314-PE-PE-50 66\PI\0451

66-314-PE-PE-50 2000-F66-PID-PR-10004

FROM GOLD ROOM

TI 409

66-409-BE-PE-90

EXISTING BARREN ELUTE TRANSFER LINE

T20 BARREN EULATE RETURN

90x63

80V106

T7 PREGNANT SOLUTION OUTLET

80V101

66-305-PE-PE-90

SAMPLE

LAL 66770 / LAH 66770 / LI 66770

LT 66770

RS 80 SPARE

VENT

66-311-PE-MSG-100(MECH)

66-310-PE-MSG-80

80V492

TO GRADE TO GRADE

O/F DRAIN MW

F66TK04 PREGNANT ELUATE STORAGE TANK

SPARE 100

80V301

66-312-PE-SS-80

80 x 65

25V301

F66PP04 PREGNANT ELUATE TRANSFER PUMP

M

NOTE 1

66-314-PE-SS-50

40 x 50

25V301

DRAIN TO FLOOR

PE SS

50V106

KV 66771

SS PE

TI 408

NOTE 2

100V106

TI 408

EXISTING PE TRANSFER LINE

66-309-MS-PE/PN16-75

FCV 36 / FIT 09 / FIC 66741 / FAL 66741 / FAH 66741

REACTOR FEED FLOW

LT 13 / LI 66742 / LAH 66742

SOLUTION TANK LEVEL

SOLUTION TANK HEATERS

SOLUTION TANK TEMPERATURE TT 14 / TIC 66743 / TAH 66743 A B

AIR OP PUMP DISCHARGE TT 12

SOLUTION TANK OVERFLOW T6

T13 DN100 TO GRADE

LEACHED CONCENTRATE 80x65

KV 66772 90x75 80V801 RL PE

KV 66773 RL PE 80V801

66-304-MS-PE/PN16-90

TO BALL MILL No.1 DISCHARGE PUMP HOPPER FME-20-PI-423

80V405

NOTES:

1. INTERLOCK WITH EXISTING PE TRANSFER PUMP TO PREVENT SIMULTANEOUS RUNNING.
2. TEE TO BE SS316.
3. PIPE DRAIN TO SAFE LOCATION
4. ALL POLY LINES ARE PN8 U.O.N.
5. LINES BECOME REDUNDANT AFTER STAGE 2 INSTALL.

LEGEND

- EXISTING
- NON-EXISTENT
- STAGE 1 - NEW
- STAGE 1 - REMOVE
- STAGE 1 - DECOMMISSIONED (OTHERS)
- STAGE 2 - NEW
- STAGE 2 - REMOVE
- STAGE 2 - DECOMMISSIONED (OTHERS)