NOTES:

1. ALL STAGNANT SECTIONS OF SAFETY SHOWER PIPEWORK EXPOSED TO DIRECT SUNLIGHT TO BE INSULATED. SITE TO CONFIRM EXTENTS OF INSULATION. INSULATION NOT REQUIRED FOR RINGMAIN.
2. VALVES TO BE LOCKED CLOSED DURING SP2 COMMISSIONING.

POTABLE WATER RINGMAIN (ELUTION)
2000-F24-PID-PR-10028
POTABLE WATER

22-2410-POT-PE8-90

POTABLE WATER RINGMAIN (CIL4)
2000-F24-PID-PR-10028
POTABLE WATER

21-0933-POT-PE8-90

POTABLE WATER RINGMAIN
2000-F75-PID-PR-25010
POTABLE WATER

TIP 1052

75-0613-POT-PE8-90

PE8 SS4 21-2406-POT-SS4-25-TI

TI 25VB03S5 F21-11234 F21-SE-415
CIL4 AREA NORTH GROUND SAFETY SHOWER

TIP 2061 STAGE 1 STAGE 2 80VBFD1L2 F75-12893

TIP 2062 STAGE 1 STAGE 2 80VBFD1L2 F75-12895

80VBFD1L2 F75-12894 NOTE 2

21-2409-POT-SS4-25-TI

1
TI 25VB03S5 F21-11237 F21-SE-417
CIL4 AREA WEST GROUND SAFETY SHOWER 1

TIP 2147 STAGE 1 STAGE 2 80VBFD1L2 F75-12896

80VBFD1L2 F75-12897 NOTE 2

TIP 2148 STAGE 1 STAGE 2 80VBFD1L2 F75-12898

PE8 SS4 AG UG 00-1294-POT-PE8-32

SS4 AG PE8 UG 72-1293-POT-SS4-25-TI

TI

SS4 PE8

1
FAH 72172 FSH 72172
72-0811-POT-SS4-25-TI
TI 25VB03S5 F72-11848 F72-SE-430
HYDROGEN PEROXIDE AREA SAFETY SHOWER 1

1
FAH 72175 FSH 72175
72-2243-POT-SS4-25-TI
TI 25VB03S5 F72-11891 F72-SE-451
HYDROGEN PEROXIDE AREA SAFETY SHOWER 2

TIP 2152 STAGE 1 STAGE 2 50VB03S5 F75-12903

1

TIP 2150 STAGE 1 STAGE 2 50VB03S5 F75-12901

TIP 2151 STAGE 1 STAGE 2 50VB03S5 F75-12902

TIP 2149 STAGE 1 STAGE 2 50VB03S5 F75-12899

1

GREENFIELDS BL BROWNFIELDS 05-27

BROWNFIELDS BL GREENFIELDS 05-29

75-3063-POT-PE8-90 75-0980-POT-PE8-90

GREENFIELDS BL BROWNFIELDS 03-05

80VBFD1L2 F75-12929

TIP 1083

TI

PE8 SS4

28-0815-POT-SS4-25-TI
TI 25VB03S5 F28-11383 F28-SE-419
UFG MILL 2 AREA SAFETY SHOWER 2

28-0814-POT-SS4-50-TI
TI 50x25 25VB03S5 F28-11384 F28-SE-418
UFG MILL 2 AREA SAFETY SHOWER 1

28-2229-POT-SS4-25-TI
TI 25VB03S5 F28-12059 F28-SE-464
UFG MILL 2 AREA SAFETY SHOWER 3

28-1668-POT-SS4-50-TI
TI 50x25 25VB03S5 F28-11385 F28-SE-421
UFG MILL 3 AREA SAFETY SHOWER 2

28-2506-POT-SS4-25-TI
1
TI 25VB03S5 F28-12031 F28-SE-483
UFG MILL 3 AREA SAFETY SHOWER 4

28-2228-POT-SS4-25-TI
TI 25VB03S5 F28-12058 F28-SE-465
UFG MILL 3 AREA SAFETY SHOWER 3

28-0813-POT-PE8-63-TI

PE8 SS4
28-1669-POT-SS4-25-TI
TI 25VB03S5 F28-11386 F28-SE-420
UFG MILL 3 AREA SAFETY SHOWER 1

POTABLE WATER RETURN RINGMAIN
POTABLE WATER

72-2411-POT-PE8-63-TI
HCL AND LEAD NITRATE AREA SAFETY SHOWERS
2000-F24-PID-PR-10028
POTABLE WATER

72-2413-POT-PE8-63-TI
CAUSTIC AREA SAFETY SHOWER
2000-F24-PID-PR-10028
POTABLE WATER

72-2412-POT-PE8-63-TI
LIME AREA SAFETY SHOWERS
2000-F24-PID-PR-10028
POTABLE WATER

1

72-2414-POT-PE8-63-TI
CYANIDE AREA SAFETY SHOWERS
2000-F24-PID-PR-10028
POTABLE WATER

POTABLE WATER RINGMAIN (ELUTION)
22-2410-POT-PE8-90
2000-F24-PID-PR-10028
POTABLE WATER

POTABLE WATER RINGMAIN (CIL4)
21-0933-POT-PE8-90
2000-F24-PID-PR-10028
POTABLE WATER