

INSTRUMENT LINE TYPES		INSTRUMENT OR FUNCTION SYMBOLS				LOGIC IDENTIFIERS		DENSITY METERS		CONVEYOR INSTRUMENT SYMBOLS	
— // — // — // — // — X — X — X — X — — — — — — — L — L — L — L — — — — — — — S — S — S — S — — 0 — 0 — 0 — 0 — — ~ — ~ — ~ — ~ — — T — T — T — T —						f(x) × > < P1 P2 Σ		DIT 1234 DE 1234 DX 1234		BDS 1234 BDS 1234 BELT DRIFT SWITCHES BDA 1234 BDA 1234 BRS 1234 CONVEYOR BELT RIP SWITCH METAL DETECTOR XS 1234 XA 1234 BELT WEIGHTOMETER WE 1234 WQIT 1234 WI 1234 WQI 1234 SSL 1234 UNDERSPEED SWITCH SAL 1234 PWS 1234 PWS 1234 CONVEYOR PULL WIRE SWITCHES PWA 1234 PWA 1234	
INSTRUMENT TAG NUMBERING		DISCRETE INSTRUMENTS SHARED DISPLAY, PLANT CONTROL SYSTEM PANEL MOUNTED INDICATOR SIS									
FIC 1234 TAG IDENTIFICATION LETTERS LOOP NUMBERS EACH INSTRUMENT IS IDENTIFIED FROM THE TABLE ABOVE BY A COMBINATION OF LETTERS AND NUMBERS. A LETTER SUFFIX IS ADDED TO DIFFERENTIATE BETWEEN INSTRUMENTS BEARING THE SAME LETTER PREFIX WITHIN ANY GIVEN LOOP.		LOCALLY MOUNTED (FIELD) TAG 1234 CONTROL ROOM PANEL (NORMALLY ACCESSIBLE TO OPERATOR) TAG 1234 AUXILIARY OR LOCAL PANEL (NORMALLY ACCESSIBLE TO OPERATOR) TAG 1234 BEHIND CONTROL ROOM PANEL (NOT ACCESSIBLE TO OPERATOR) TAG 1234 BEHIND AUXILIARY OR LOCAL PANEL (NOT ACCESSIBLE TO OPERATOR) TAG 1234									
		INSTRUMENT IDENTIFICATION AND SYMBOLS						PRESSURE INSTRUMENT SYMBOLS		SCADA INDICATION, CONTROL AND ALARMS	
INSTRUMENT / FIELD DEVICES		1st LETTER CATEGORY	DESCRIPTION	2nd LETTER CATEGORY	DESCRIPTION	3rd LETTER CATEGORY	DESCRIPTION	PE 1234 PRESSURE ELEMENT PI 1234 PRESSURE INDICATOR PT 1234 PRESSURE TRANSMITTER PIT 1234 PRESSURE INDICATOR TRANSMITTER PDI 1234 DIFFERENTIAL PRESSURE INSTRUMENT PI 1234 PRESSURE INDICATOR WITH FLANGED DIAPHRAGM SEAL PI 1234 PRESSURE INDICATOR WITH SCREWED DIAPHRAGM SEAL			
A/M AUTO/MANUAL CL CLOSE DU/ST DUTY/STANDBY F/R FORWARD/REVERSE F/R/S FORWARD/REVERSE/STOP FC FAIL CLOSED FI FAIL INTERMEDIATE FO FAIL OPEN FL FAIL LAST H HIGH H/L HIGH/LOW HH HIGH HIGH I/D INCREASE/DECREASE L LOW L/O/R LOCAL/OFF/REMOTE L/R LOCAL/REMOTE LC LOCKED CLOSED LCP LOCAL CONTROL PANEL LCS LOCAL CONTROL STATION LL LOW LOW LO LOCKED OPEN M/O/A MANUAL/OFF AUTO M/O/R MANUAL/OFF/REMOTE NC NORMALLY CLOSED NO NORMALLY OPEN O/C/R OPEN/CLOSE/REMOTE OP OPEN SEL FUNCTION SELECT SP STOP ST START U/D UP/DOWN (INCLUDE RAISE/LOWER)		A ANALYSIS B BURNER FLAME / BELT C CONDUCTIVITY (ELECTRICAL) D DENSITY F FLOW G GAUGING (DIMENSIONAL) H HAND (MANUAL) I CURRENT (ELECTRICAL) J POWER K TIME L LEVEL M MECHANICAL EQUIPMENT TAG N TORQUE O ORIFICE / RESTRICTION P PRESSURE / VACUUM / PULL Q QUANTITY R RADIATION S SOLENOID / SPEED / FREQUENCY / SIGHT T TEMPERATURE U MULTI VARIABLE V VIBRATION W WEIGHT / FORCE X MISCELLANEOUS Y EVENT Z POSITION	A ALARM C CONTROL / CAMERA D DIFFERENTIAL / DRIFT / DETECTOR E ELEMENT F RATIO G GLASS GAUGE H HIGH I INDICATOR L LOW M MASS N NUCLEONIC O ORIFICE / RESTRICTION P POINT Q TOTALISER R RECORDER / RELIEF / RIP S SWITCH T TRANSMITTER V VALVE / DAMPER WELL W WIRE X TRANSMISSION SOURCE Y AUXILIARY DEVICES Z ACTUATOR FINAL CONTROL ELEMENT	C CLOSE / CLOSED / CONTROL E ELEMENT H HIGH I INDICATOR L LOW M MEDIUM N NUCLEONIC O OPEN / OPENED Q QUANTITY R RECORDER S SAFETY / SWITCH T TRANSMITTER V VALVE	FM XX FLOWMETER - VARIABLE FLOWMETER - VORTEX FLOWMETER WITH AIR ELIMINATOR G GEARBOX H HYDRAULIC LAMP INDICATOR PROXIMITY SWITCH SIGHT GLASS - INLINE TEMPERATURE WELL - SURFACE MOUNTED		TIC 1234 CAPILLARY TEMPERATURE INDICATING CONTROLLER WITH PNEUMATIC OUTPUT TE 1234 TEMPERATURE ELEMENT TI 1234 TEMPERATURE INDICATOR TIT 1234 TEMPERATURE INDICATOR TRANSMITTER TCV 1234 TEMPERATURE CONTROL VALVE		LSH 1234 DISCRETE ALARM IN PCS LAH 1234 DIT 1234 P&ID REPRESENTATION: DI 1234 FUNCTIONAL ALARM SETPOINTS PROGRAMMED IN PCS HH L LL DETAILS: DIT 1234 DI 1234 t/m³ 0 f(x) DNI 1234 %w/w solids HH L LL		