O:\CAD PROJECTS\235 NORTHERN STAR RESOURCES LTD\23517 KCOM GROWTH PROJECT\03 DELIVERABLES\ELV\F23 - FINAL TAILINGS HANDLING & STORAGE\2000-F23-SLD-EL-10211.DWG 020CT25 9:04AM HOTSEAT04

630A
4 POLE
G
3~
F23-GE-123
415V
400kVA

F23-SR-002
415V FINAL TAILS SWITCHROOM

SWR EARTH BAR

FEEDER FROM F23-SW-023
2000-F23-SLD-EL-10201
TO F23-SW-023
2000-F23-SLD-EL-10201

F23-SW-123
FINAL TAILS 415V EMERGENCY MOTOR CONTROL CENTRE

MCC EARTH BAR

NEUTRAL BAR
NOTE 1

AFD

100A
100A
SD
NOTE 3
2A
32A
2A
63A
1
6A
32A
6A
32A
ATS
M
AUTO
MCCB CHANGEOVER
SWITCH 3 POLE 630A

CONTINUED ON SHT 2
2000-F23-SLD-EL-10212

415V 3NE~ 50Hz 630A 65kA for 1sec

INC

02F-17 250A 2A 32A 90A 250A 250A
02F-09 32A 2A 32A 70A 32A 32A
02F-05 32A 2A 32A 70A
2F-01 250A 2A 32A 90A
1F-01 160A 2A 32A 100/1A
02F-13 20A 2A 32A 70A EOL
01F-01 20A 2A 32A 90A EOL
01F-05 20A 2A 32A 70A EOL
01F-09 20A 2A 32A 70A EOL

1

69kW
F23-DB-001
FINAL TAILS PUMPS
11kV / 415V SWITCHROOM
L&SP DB
2000-F23-SCM-EL-10205

ISL
10kW
F23UPS002-ISL
240VAC UPS
MAINTENANCE
BYPASS SWITCH
2000-F23-SCM-EL-10206

10kW
F23-DB-201
FINAL TAILS PUMPS
415V SWITCHROOM
240VAC UPS DB
2000-F23-TLD-EL-10101

UPS
10kW
F23-UPS-002
FINAL TAILS PUMPS
415V SWITCHROOM
240VAC UPS
2000-F23-TLD-EL-10101

E-SHUT
F23SR002-LCS
NOTE 12

F23-SR-001
11kV FINAL
TAILS PUMPS
SWITCHROOM
BC
6kW
F23-BC-001
FINAL TAILS PUMPS
11kV SWITCHROOM
48V CHARGER
2000-F23-TLD-EL-10052

10kW
F00-DB-401
EVENT POND
L&SP DB
2000-F00-SCM-EL-10213

69kW
F23-DB-301
FINAL TAILS AREA
L&SP DB
2000-F23-SCM-EL-10207

t°
M
3~
45kW
F23-AG-404
FINAL TAILS
TANK AGITATOR
2000-F23-SCM-EL-10208

M 3~ 0.18kW
F23-FN-466
FINAL TAILS
PUMP 1
GEARBOX OIL AIR COOLING FAN
2000-F23-SCM-EL-10210

M 3~ 0.18kW
F23-FN-467
FINAL TAILS
PUMP 2
GEARBOX OIL AIR COOLING FAN
2000-F23-SCM-EL-10211

M 3~ 0.18kW
F23-FN-468
FINAL TAILS
PUMP 3
GEARBOX OIL AIR COOLING FAN
2000-F23-SCM-EL-10212

M 3~ 0.18kW
F23-FN-469
FINAL TAILS
PUMP 4
GEARBOX OIL AIR COOLING FAN
2000-F23-SCM-EL-10213

NORTHERN STAR RESOURCES LIMITED

Approved	X
Approved as Noted	
Not Approved	
For Information Only	

Signed [redacted] Date 15/10/2025

ACCEPTANCE DOES NOT RELIEVE THE SUPPLIER / CONTRACTOR OF ITS RESPONSIBILITY OR LIABILITIES UNDER THE PURCHASE ORDER / CONTRACT

NOTES

1. EARTH-NEUTRAL LINK INSTALLED IN UPSTREAM F23-SW-023 INCOMER TIER. SIGNAGE SHALL BE PLACED ON F23-SW-123 SWITCHBOARD AND ON GENERATOR READING "M.E.N. LINK LOCATED IN F23-SW-023 INCOMER TIER"
2. SWITCHBOARD SHALL BE EXTENSIBLE AND BE PROVIDED WITH THE FACILITY TO EXTEND THE MAIN BUSBAR AND APPEND ADDITIONAL TIERS AT ONE END WITHOUT MAJOR STRUCTURAL DISASSEMBLY.
3. SURGE DIVERTERS SHALL PROVIDE FEEDBACK TO DCS VIA VOLT-FREE CONTACTS. SURGE DIVERTER FUSES SHALL BE SIZED BY VENDOR TO SUIT DUTY.
4. MINIATURE CIRCUIT BREAKERS SHALL BE SIZED AND RATED TO SUIT ACB AND INCOMER REQUIREMENTS.
5. CIRCUIT BREAKER TO BE SUBSTITUTED FOR FUSED-SWITCH WHERE REQUIRED BY EQUIPMENT MANUFACTURERS GUIDELINES.
6. EMERGENCY SHUTDOWN (E-SHUT) PUSH BUTTON N/O WIRED TO SHUNT TRIP NOMINATED CIRCUIT BREAKERS.

LEGEND

- PFR — PHASE FAILURE RELAY
- / > — EARTH LEAKAGE RELAY
- xxxA / xxxA — ST TRIP SET POINT / CB SIZE
- AFD — ARC FLASH DETECTION
- ECR — EARTH CONTINUITY RELAY
- 1 / E-SHUT — SWITCHROOM EMERGENCY SHUTDOWN

2000-F23-SLD-EL-10211_Rev1

F23-SW-123 415V emergency MCC - single line diagram sheet 1