VENDOR SCOPE
(VENDOR PACKAGE NO. V5072)
REFER TO VENDOR
DRG No. 10230-F78-VPI-15001

FIRE WATER DISTRIBUTION
2000-F75-PID-PR-60036
FIRE WATER
66-0059-FW-ST-80

ELECTROWINNING CELL
(66-EC-61A/B)
2000-F66-PID-PR-60008
OFF GAS
66-0032-OG-ST-400

RETORT BUILDING EXHAUST
2000-F66-PID-PR-60006
AIR
66-0733-AIR-PE-450

RETORT OVEN EXHAUST HOOD
(F66-FH-71)
2000-F66-PID-PR-60006
OFF GAS
66-0708-OG-ST-400-PP

PDI 66857 HH H

HOLD 2 XXX XXXX
80VC
80VB F66-XXXXX HOLD 1
VKG 66856 FC

HOLD 2 VBF 66844 FC
HOLD 2 VBF 66845 FC
DN40
500x400

F66-FI-071
GOLDROOM CARBON FILTER
PDIT 66857
15VB
15VB

66-0036-OG-ST-150
150x80
80VB F66-62379
VKG 66857 FC

66-0034-OG-ST-400

DRAIN TO GRADE

HOLD 2 KV 66873 FC
PE ST
450x400

HOLD 2 KV XXXXX FC
INTERNAL EXTERNAL

500x400 DN40 DN40
66-0037-OG-ST-400
66-0041-OG-ST-400
DN40

VBF 66865 F66-IP-298
M F66-FN-073C ELECTROWINNING FUME EXTRACTION FAN 2
VBF 66855 FC 500x400
66-0044-OG-ST-500

VBF 66846
VBF 66853

NOTE 2
HOLD 2 VBF 66849
66-0038-OG-ST-400
NOTE 2
HOLD 2 VBF 66851 F66-IP-296
M F66-FN-073B ELECTROWINNING FUME EXTRACTION FAN 1
VBF 66851 FC 500x400
66-0042-OG-ST-500

DN40
66-0738-OG-ST-400

HOLD 2 VBF 66847 FC
VBF 66852 FC
DN40 DN40
66-0040-OG-ST-400
25VB F66-62380
M F66-FN-073A GENERAL RETORT BUILDING EXHAUST FAN
VBF 66848 FC 500x400
66-0043-OG-ST-500

VENT TO ATMOSPHERE
DN100 SAMPLING POINT
F66-ST-060 GENERAL RETORT BUILDING AND RETORT OVEN EXHAUST STACK

MERCURY LOADED CARBON AND CONDENSED MERCURY STORAGE AREA

FROM MERCURY RETORT
2000-F66-PID-PR-60006
NOTE 4
MERCURY LOADED CARBON DRUMS

CARBON FILTER 1
(F78-FI-71)
2000-F78-PID-PR-60004

CARBON FILTER 2
(F78-FI-72)
2000-F78-PID-PR-60005
NOTE 4
MERCURY LOADED CARBON DRUMS

NOTES:

1. FOR GENERAL NOTES REFER TO 2000-F00-PID-PR-10001 TO 10007.
2. TAG KV66862 ON VALVE ALSO PRESENT.
3. PROCESS CONTROL SYSTEM CONNECTIONS NOT SHOWN, OR WHERE SHOWN NOT CONFIRMED.
4. MANUAL TRANSFER MERCURY LOADED CARBON DRUMS ONTO PALLETS.

HOLDS:

1. PENDING VALVE TAGGING.
2. CLIENT TO CONFIRM INSTRUMENT TYPE AND/OR TAG NUMBER.

ORIGINAL DRAWING: 66\Pi\1605