INSTRUMENT LINE TYPES

- AIR SUPPLY / PNEUMATIC SIGNAL
- CAPILLARY TUBING (FILLED SYSTEM)
- ELECTRIC SIGNAL
- HYDRAULIC SIGNAL
- INSTRUMENT
- NUCLEAR / RADIATION
- SOFTWARE OR DATA LINK SIGNAL
- SONIC / RADAR
- TELEMETRY

INSTRUMENT TAG NUMBERING

FIC 1234 ← TAG IDENTIFICATION LETTERS
FIC 1234 ← LOOP NUMBERS

EACH INSTRUMENT IS IDENTIFIED FROM THE TABLE ABOVE BY A COMBINATION OF LETTERS AND NUMBERS. A LETTER SUFFIX IS ADDED TO DIFFERENTIATE BETWEEN INSTRUMENTS BEARING THE SAME LETTER PREFIX WITHIN ANY GIVEN LOOP.

F	IC	1234	A
FIRST LETTER	SUCCEEDING LETTERS	NUMBER	SUFFIX IF REQ'D
FUNCTIONAL IDENTIFICATION		LOOP NUMBER	
INSTRUMENT TAG NUMBER			

INSTRUMENT / FIELD DEVICES

A/M	AUTO/MANUAL
CL	CLOSE
DU/ST	DUTY/STANDBY
F/R	FORWARD/REVERSE
F/R/S	FORWARD/REVERSE/STOP
FC	FAIL CLOSED
FI	FAIL INTERMEDIATE
FO	FAIL OPEN
FL	FAIL LAST
H	HIGH
H/L	HIGH/LOW
HH	HIGH HIGH
I/D	INCREASE/DECREASE
L	LOW
L/O/R	LOCAL/OFF/REMOTE
L/R	LOCAL/REMOTE
LC	LOCKED CLOSED
LCP	LOCAL CONTROL PANEL
LCS	LOCAL CONTROL STATION
LL	LOW LOW
LO	LOCKED OPEN
M/O/A	MANUAL/OFF AUTO
M/O/R	MANUAL/OFF/REMOTE
NC	NORMALLY CLOSED
NO	NORMALLY OPEN
O/C/R	OPEN/CLOSE/REMOTE
OP	OPEN
SEL	FUNCTION SELECT
SP	STOP
ST	START
U/D	UP/DOWN (INCLUDE RAISE/LOWER)

INSTRUMENT OR FUNCTION SYMBOLS

	DISCRETE INSTRUMENTS	SHARED DISPLAY, PLANT CONTROL SYSTEM	PANEL MOUNTED INDICATOR	SIS
LOCALLY MOUNTED (FIELD)	TAG 1234	TAG 1234	TAG 1234	TAG 1234
CONTROL ROOM PANEL (NORMALLY ACCESSIBLE TO OPERATOR)	TAG 1234	TAG 1234		
AUXILIARY OR LOCAL PANEL (NORMALLY ACCESSIBLE TO OPERATOR)	TAG 1234	TAG 1234		
BEHIND CONTROL ROOM PANEL (NOT ACCESSIBLE TO OPERATOR)	TAG 1234	TAG 1234		
BEHIND AUXILIARY OR LOCAL PANEL (NOT ACCESSIBLE TO OPERATOR)	TAG 1234			

INSTRUMENT IDENTIFICATION AND SYMBOLS

1st LETTER CATEGORY	DESCRIPTION	2nd LETTER CATEGORY	DESCRIPTION	3rd LETTER CATEGORY	DESCRIPTION
A	ANALYSIS	A	ALARM		
B	BURNER FLAME / BELT				
C	CONDUCTIVITY (ELECTRICAL)	C	CONTROL / CAMERA	C	CLOSE / CLOSED / CONTROL
D	DENSITY	D	DIFFERENTIAL / DRIFT / DETECTOR		
		E	ELEMENT		ELEMENT
F	FLOW	F	RATIO		
G	GAUGING (DIMENSIONAL)	G	GLASS / GAUGE		
H	HAND (MANUAL)			H	HIGH
I	CURRENT (ELECTRICAL)	I	INDICATOR	I	INDICATOR
J	POWER				
K	TIME				
L	LEVEL			L	LOW
M	MECHANICAL EQUIPMENT TAG	M	MASS	M	MEDIUM
N	TORQUE	N	[illegible]ATION	N	NUCLEONIC
O	ORIFICE / RESTRICTION	O	ORIFICE / RESTRICTION	O	OPEN / OPENED
P	PRESSURE / VACUUM / PULL	P	POINT		
Q	QUANTITY	Q	TOTALISER	Q	TOTALISER
R	RADIATION	R	RECORDER / RELIEF / RIP	R	RECORDER
S	SOLENOID / SPEED / FREQUENCY / SIGHT	S	SWITCH	S	SAFETY / SWITCH
T	TEMPERATURE	T	TRANSMITTER	T	TRANSMITTER
U	MULTI VARIABLE				
V	VIBRATION	V	VALVE / DAMPER WELL	V	VALVE
W	WEIGHT / FORCE	W	WIRE		
X	MISCELLANEOUS	X	TRANSMISSION SOURCE		
Y	EVENT	Y	AUXILIARY DEVICES		
Z	POSITION	Z	ACTUATOR FINAL CONTROL ELEMENT		

LOGIC IDENTIFIERS

- INTERLOCK - CONTROL SYSTEM
- INTERLOCK - HARD WIRED
- MISCELLANEOUS FUNCTION
- MULTIPLICATION
- SIGNAL SELECTION - HIGH
- SIGNAL SELECTION - LOW
- SUBTRACTION P1-P2
- SUMMATION OF SIGNALS

INSTRUMENT SYMBOLS

- BRAKE
- DIAPHRAGM SEAL - FLANGED
- DIAPHRAGM SEAL - SCREWED
- FLOWMETER - ANNUBAR
- FLOWMETER - CORIOLIS
- FLOWMETER - GEAR
- FLOWMETER - MAGNETIC
- FLOWMETER - ORIFICE
- FLOWMETER - POSITIVE DISPLACEMENT
- FLOWMETER - ROTOMETER
- FLOWMETER - TURBINE
- FLOWMETER - ULTRASONIC
- FLOWMETER - VARIABLE
- FLOWMETER - VORTEX
- FLOWMETER WITH AIR ELIMINATOR
- GEARBOX
- HYDRAULIC
- LAMP INDICATOR
- PROXIMITY SWITCH
- SIGHT GLASS - INLINE
- TEMPERATURE WELL - SURFACE MOUNTED

DENSITY METERS

- DIT 1234 / DE 1234 / DX 1234 — DENSITY TRANSMITTER - NUCLEONIC

FLOW SYMBOLS

- FE 1234 — FLOW ELEMENT
- FT 1234 — FLOW TRANSMITTER
- FIT 1234 — FLOW INDICATOR TRANSMITTER

PRESSURE INSTRUMENT SYMBOLS

- PE 1234 — PRESSURE ELEMENT
- PI 1234 — PRESSURE INDICATOR
- PT 1234 — PRESSURE TRANSMITTER
- PIT 1234 — PRESSURE INDICATOR TRANSMITTER
- PDI 1234 — DIFFERENTIAL PRESSURE INSTRUMENT
- PI 1234 — PRESSURE INDICATOR WITH FLANGED DIAPHRAGM SEAL
- PI 1234 — PRESSURE INDICATOR WITH SCREWED DIAPHRAGM SEAL

TEMPERATURE SYMBOLS

- TIC 1234 — CAPILLARY TEMPERATURE INDICATING CONTROLLER WITH PNEUMATIC OUTPUT
- TE 1234 — TEMPERATURE ELEMENT
- TI 1234 — TEMPERATURE INDICATOR
- TIT 1234 — TEMPERATURE INDICATOR TRANSMITTER
- TCV 1234 — TEMPERATURE CONTROL VALVE

CONVEYOR INSTRUMENT SYMBOLS

- BDS 1234 / BDA 1234 — BELT DRIFT SWITCHES
- PWS 1234 / PWA 1234 — CONVEYOR PULL WIRE SWITCHES
- BRS 1234 / BRA 1234 — CONVEYOR BELT RIP SWITCH
- METAL DETECTOR — XS 1234 / XA 1234
- BELT WEIGHTOMETER — WE 1234 / WQIT 1234 / WI 1234 / WQI 1234
- UNDERSPEED SWITCH — SSL 1234 / SAL 1234

SCADA INDICATION, CONTROL AND ALARMS

DISCRETE ALARM IN PCS

LSH 1234 — LAH 1234

DENSITY INDICATION IN PCS

P&ID REPRESENTATION:

DIT 1234 — DI 1234 (HH, H, L, LL) — FUNCTIONAL ALARM SETPOINTS PROGRAMMED IN PCS

DETAILS:

DIT 1234 — DI 1234 (t/m³) — 0 — f(x) — DNI 1234 (%w/w solids) (HH, H, L, LL)

SUPERSEDED BY 2000-F00-P&ID-PR-10003_MS