LEGEND:

- EXISTING
- NEW
- FUTURE
- DECOMMISSIONED

NOTES:

1. VALVES WILL BE HYDRAULICALLY ACTUATED VIA HYDRAULIC POWER PACK F23-HY-420.
2. A DRYING PAD WILL BE INSTALLED ADJACENT TO THE DRIVE IN SUMP. RECLAIMED MATERIAL WILL BE DISCHARGED TO FIM III TSF BY FRONT END LOADER.
3. MANUAL OPERATED VALVE WITH PROXIMITY SWITCHES.
4. BURSTING DISC RUPTURE PRESSURE TO BE SUITABLE FOR INITIAL OPERATION. WILL BE REQUIRED TO BE REPLACED AT FINAL TSF HEIGHT.
5. DIFFERENTIAL FLOW CALCULATION FOR LEAK DETECTION.

FINAL TAILS PUMP 2 VSD
2000-F23-PID-PR-10002
SIGNAL

DECANT DAM 4 PUMPS
2000-F75-PID-PR-40004
FLUSHING WATER

75-8127-PW-PE16-400

400VBFE1L2 (40208)

400VCE1S1 (40209)

50VB03S1 (40211)

DETAIL 5
HS 23534
XV 23534

400VKG15C1 FL

PE16 RL2

FINAL TAILS PUMP 2
2000-F75-PID-PR-40021
FINAL TAILS

23-8133-FT-PE16-630
LINE B

PE16 RL2

600x500

DETAIL 5
HS 23532
XV 23532

500VKG15C1 FL

PI 23531 H L

PIT 23531

23-8133-FT-RL2-500

SP HS-410

50VB03S1 (40470)

500x300

VENDOR PACKAGE

VSD

M

F23-PP-652
FIM III BOOSTER PUMP 2

F23-FN-654
FIM III BOOSTER PUMP 2 MOTOR FAN

F23-FN-652
FIM III BOOSTER PUMP 2 GEARBOX FAN

SP HS-402

ZIO 23545

ZSO 23545

NOTE 3
ZIC 23545

ZSC 23545

HV 23545

100VKG15C1 RL2 NC

PE8

HS 23541

SP HS-411

50VB03S1 (40111)

500x250

23-8131-FT-RL4-500

FIC 23541 FDI 23541 H L LL

NOTE 5

FIT 23541

FE 23541

M

UA 23539

US 23539

SP MS-403

NOTE 4

PI 23540 HH H L

PIT 23540

DETAIL 5
HS 23538
XV 23538

200VKG15C1 RL4 FL

PE8

DETAIL 5
HS 23537
XV 23537

500VKG15C1 FL

RL4 PE25

600x500

23-8131-FT-PE25-630
LINE B

FIM III VALVE STATION
2000-F23-PID-PR-40005
FINAL TAILS

FIM III BOOSTER PUMP 2
SEAL WATER PUMPS VSD
2000-F75-PID-PR-40014
SIGNAL

FI 23543 H L LL

FIT 23543

FE 23543

PIC 75306 H L LL

PY 75306

PIT 75306

15VB03S1 (40472)

25VB03S1 (40434)

25VC01S3 (40462)

23-8136-FT-PE8-225

23-8144-FT-RL4-250

23-8546-FT-PE8-110

FIM III BOOSTER PUMP 2
SEAL WATER PUMPS
2000-F75-PID-PR-40014
SEAL WATER

75-8128-GW-PE25-32

PE25 SS10

25VB03S1 (40468)

25VB03S1 (40466)

M

25VB03S1 (40467)

75-8208-GW-SS10-25

75-8128-GW-SS10-25

FIM III BOOSTER
PUMP 1 DISCHARGE
2000-F23-PID-PR-40002
FINAL TAILS

23-8116-FT-PE8-225

FIM III BOOSTER
PUMP 1 DISCHARGE
2000-F23-PID-PR-40002
FINAL TAILS

23-8121-FT-RL4-250

FIM III BOOSTER PUMP 1 SUCTION
2000-F23-PID-PR-40002
FINAL TAILS

23-8545-FT-PE8-110

F23-SU-410
FIM III BOOSTER
STATION DRIVE IN SUMP
NOTE 2

FEL

APPROVED FOR CONSTRUCTION