NOTES:

1. REFER TO P&ID 2000-F75-PID-PR-25004 H-10 FOR TIE-IN.
2. HIGH POINT PURGE. VALVE TO BE PLUGGED AND LOCKED CLOSED DURING OPERATION
3. BYPASS SPOOL IN PLACE FOR TEMPORARY COMMISSIONING OF CV-403 SPRINKLER SYSTEM. ALARM CHECK VALVE YV24711 AND LHD YD24713 TO BE INSTALLED AND AS-CONSTRUCTED AT LATER DATE WHEN AVAILABLE

13-1552-FW-MSG2-80
SAG MILL LUBE UNITS SPRINKLER SYSTEM
SP SP-010 8 OFF
13-0147-FW-MSG2-80
SP SP-010 8 OFF
YD 24703A IR
YD 24703B IR
YA 24703 FLAME DETECTED
13-0550-FW-MSG2-80
SET @ 1200 kPag
SP FS-010
PRV 24702
1/2" S/S TUBING
PAL 24701
SP FS-006
SP VC-006
SP VC-006
PSL 24701
YV 24701
PI 24701A
PI 24701B
80VGE1F1 F13-11869
MSG3 13-0556-FW-MSG3-50
FHR 50x25 F13-FHR-412 MILL AREA NORTH SIDE HOSE REEL
13-0551-FW-MSG2-80
BALL MILL LUBE UNITS SPRINKLER SYSTEM
SP SP-010 8 OFF
13-0148-FW-MSG2-80
SP SP-010 8 OFF
YD 24708A IR
YD 24708B IR
YA 24708 FLAME DETECTED
SET @ 1200 kPag
SP FS-010
PRV 24707
1/2" S/S TUBING
PAL 24706
SP FS-006
SP VC-006
SP VC-006
PSL 24706
YV 24706
PI 24706A
PI 24706B
80VGE1F1 F13-11867
13-0570-FW-MSG2-200
13-2472-FW-MSG2-80
MSG2 MSG3 13-0555-FW-MSG3-50
FHR 50x25 F13-FHR-411 MILL AREA SOUTH SIDE HOSE REEL
13-0521-FW-MSG2-50
MSG2 MSG3 13-0552-FW-MSG3-25
FHR 50x25 F13-FHR-408 MILL FEED BOX AREA HOSE REEL
MSG2 MSG3 13-0553-FW-MSG3-25
FHR 50x25 F13-FHR-409 CYCLONE AREA LOWER LEVEL HOSE REEL
MSG2 MSG3 13-0554-FW-MSG3-25
FHR 50x25 F13-FHR-410 CYCLONE AREA UPPER LEVEL HOSE REEL
16-0640-FW-MSG2-200
MSG2 MSG3 13-0490-FW-MSG3-50
FHR 50x25 F13-FHR-423 TRASH SCREENS HOSE REEL 1
MSG2 MSG3 16-1408-FW-MSG3-50
FHR 50x25 F16-FHR-418 FLOTATION CELLS FIRE HOSE REEL 1
MSG2 MSG3 16-1409-FW-MSG3-50
FHR 50x25 F16-FHR-419 FLOTATION CELLS FIRE HOSE REEL 2
00-1406-FW-PE16-110
PE16 U/G MSG2 A/G 24-1407-FW-MSG2-100
FH F24-HYD-407 PROCESS WATER AREA FIRE HYDRANT
13-0567-FW-MSG2-100
FH F13-HYD-411 MILLING AREA FIRE HYDRANT
MSG2 A/G PE16 U/G
00-0565-FW-PE16-225
PE16 U/G MSG2 A/G
200VGE1F1 F75-11863
200x150
PI 24720
25VB03S1 F75-11864
PCV 24721
SET AT 700 kPa
SP FS-008
SP VC-007
SP VC-007
SET AT 700 kPa
PRV 24722
SP FS-009
SP VC-006
SP VC-006
PI 24723
25VB03S1 F75-11866
25VB03S1 F75-11865
TO GRADE
200x150
NOTE 1
TIP 1056 BL
GREENFIELDS ENABLING WORKS 08-01
75-0549-FW-MSG2-200
FIRE WATER NETWORK
FIRE WATER
PE16 U/G MSG2 A/G
MSG2 A/G PE16 U/G
13-0562-FW-MSG2-150
150VGE1F1 F13-11868
SP VC-007
SP VC-007
SET @ 1200 kPag 1400
PRV 24716
SP FS-010
SP VC-008 5 OFF
NOTE 2
25VB03S1 F13-12999 LC
PAL 24715
PSL 24715
YV 24715
PI 24715A
PI 24715B
SP FS-011
13-1757-FW-MSG3-25 TO 13-1774-FW-MSG3-25
SP SP-010 18 OFF
RECYCLE CONVEYOR 2 HEAD SPRINKLER SYSTEM (F13-CV-405)
YD 24717 LHD
YA 24717 FLAME DETECTED
NOTE 3
SET @ 1200 kPag 1400
PRV 24712
SP FS-010
SP VC-007
SP VC-007
13-0571-FW-MSG2-150
150VGE1F1 F13-11871
SP VC-008 5 OFF
NOTE 2
50VB03S1 F13-12998 LC
PAL 24711
PSL 24711
YV 24711
PI 24711A
PI 24711B
SP FS-011
13-1955-FW-MSG3-25 TO 13-1967-FW-MSG3-25
SP SP-010 13 OFF
SAG MILL FEED CONVEYOR HEAD SPRINKLER SYSTEM (F13-CV-403)
YD 24713 LHD
YA 24713 FLAME DETECTED
NOTE 3
13-2473-FW-MSG2-80
YA 24678 ALARM
XA 24678A ISOLATED
XA 24678B FAULT
YD 24678 LHD
F13-FIP-401 SAG MILL DISCHARGE SCREEN FIRE INDICATOR PANEL
13-2594-FW-MSG32-80
SAG MILL DISCHARGE SCREEN SPRINKLER SYSTEM
SP SP-013 3 OFF
SP FS-001
SAG MILL DISCHARGE SCREEN SPRINKLER SYSTEM
SP SP-013 3 OFF
80VGE1F1 F13-10124
SP VC-006
SP VC-006
YA 24679 ALARM
XA 24679A ISOLATED
XA 24679B FAULT
YD 24679 LHD
F13-FIP-402 TRASH DEWATERING SCREEN FIRE INDICATOR PANEL
SP SP-013
TRASH DEWATERING SCREEN SPRINKLER SYSTEM
13-2596-FW-MSG3-15
13-2595-FW-MSG3-25
13-2597-FW-MSG3-15
TRASH DEWATERING SCREEN SPRINKLER SYSTEM
SP SP-013
SP FS-001
80VGE1F1 F13-10125
SP VC-006
SP VC-006
NOTE 2
25VB03S1 F13-12997 LC
FIRE WATER NETWORK
2000-F24-PID-PR-10009
FIRE WATER
13-0200-FW-MSG2-200