NOTES:

1. ALL STAGNANT SECTIONS OF SAFETY SHOWER PIPEWORK EXPOSED TO DIRECT SUNLIGHT TO BE INSULATED. SITE TO CONFIRM EXTENTS OF INSULATION. INSULATION NOT REQUIRED FOR RINGMAIN.

POTABLE WATER RINGMAIN 2000-F24-PID-PR-10021 POTABLE WATER
21-0933-POT-PE8-90
22-2410-POT-PE8-90
72-2411-POT-PE8-63-TI
72-2412-POT-PE8-63-TI
72-2413-POT-PE8-63-TI
72-2414-POT-PE8-63-TI

72-2252-POT-SS4-25-TI
72-2238-POT-SS4-25-TI
72-2239-POT-SS4-25-TI
72-2240-POT-SS4-25-TI
72-2241-POT-SS4-25-TI
72-2242-POT-SS4-25-TI
72-2578-POT-SS4-25-TI
72-2579-POT-SS4-25-TI
72-2582-POT-SS4-25-TI
72-2580-POT-SS4-25-TI
72-2583-POT-SS4-25-TI
72-2237-POT-SS4-25-TI
72-2236-POT-SS4-50-TI
72-2235-POT-SS4-25-TI
72-2234-POT-SS4-25-TI
72-2233-POT-SS4-25-TI
72-2232-POT-SS4-25-TI
72-2231-POT-SS4-25-TI
72-2496-POT-SS4-25-TI

FAH 72187 / FSH 72187 — 25VB03S5 F72-12445 — F72-SE-466 — HCL AREA SAFETY SHOWER 2
FAH 72170 / FSH 72170 — 25VB03S5 F72-11890 — F72-SE-426 — LIME SAFETY SHOWER 3
FAH 72178 / FSH 72178 — 25VB03S5 F72-11844 — F72-SE-455 — HCL AREA SAFETY SHOWER 1
FAH 72179 / FSH 72179 — 25VB03S5 F72-11845 — F72-SE-456 — LEAD NITRATE SAFETY SHOWER
FAH 72168 / FSH 72168 — 25VB03S5 F72-11847 — F72-SE-424 — LIME SAFETY SHOWER 1
FAH 72169 / FSH 72169 — 25VB03S5 F72-11889 — F72-SE-425 — LIME SAFETY SHOWER 2
25VB03S5 F72-11859 — F72-SE-469 — LIME AREA SAFETY SHOWER 4
25VB03S5 F72-11872 — F72-SE-485 — LIME AREA EYE WASH STATION 2
25VB03S5 F72-11899 — F72-SE-486 — LIME AREA EYE WASH STATION 3
25VB03S5 F72-11968 — F72-SE-487 — LIME AREA EYE WASH STATION 4
25VB03S5 F72-11870 — F72-SE-484 — LIME AREA EYE WASH STATION 1
FAH 72177 / FSH 72177 — 25VB03S5 F72-11846 — F72-SE-454 — CAUSTIC SAFETY SHOWER
FAH 72185 / FSH 72185 — 25VB03S5 F72-11884 — F72-SE-462 — SODIUM CYANIDE SAFETY SHOWER 6
FAH 72184 / FSH 72184 — 25VB03S5 F72-11887 — F72-SE-461 — SODIUM CYANIDE SAFETY SHOWER 5
FAH 72180 / FSH 72180 — 25VB03S5 F72-11843 — F72-SE-457 — SODIUM CYANIDE SAFETY SHOWER 1
FAH 72183 / FSH 72183 — 25VB03S5 F72-11886 — F72-SE-460 — SODIUM CYANIDE SAFETY SHOWER 4
FAH 72181 / FSH 72181 — 25VB03S5 F72-11888 — F72-SE-458 — SODIUM CYANIDE SAFETY SHOWER 2
FAH 72182 / FSH 72182 — 25VB03S5 F72-11885 — F72-SE-459 — SODIUM CYANIDE SAFETY SHOWER 3
FAH 72186 / FSH 72186 — 25VB03S5 F72-11955 — F72-SE-504 — SODIUM CYANIDE SAFETY SHOWER 7

21-2585-POT-SS4-25-TI — 25VB03S5 F22-12382 — F22-SE-489 — MERCURY ABATEMENT CHILLER SAFETY SHOWER
21-2407-POT-SS4-25-TI — 25VB03S5 F21-11235 — F21-SE-416 — CIL4 AREA SOUTH GROUND SAFETY SHOWER
22-2415-POT-SS4-25-TI — FAH 22264 / FSH 22264 — 25VB03S5 F22-12146 — F22-SE-471 — CIL4 LOADED CARBON TRANSFER VESSEL UPPER SAFETY SHOWER
22-2416-POT-SS4-25-TI — FAH 22263 / FSH 22263 — 25VB03S5 F22-12147 — F22-SE-470 — CIL4 LOADED CARBON SAFETY SCREEN AREA SAFETY SHOWER
22-2417-POT-SS4-25-TI — FAH 22268 / FSH 22268 — 25VB03S5 F22-12148 — F22-SE-475 — CIL4 ELUTION & ACID WASH COLUMN AREA MIDDLE SAFETY SHOWER
22-2418-POT-SS4-25-TI — FAH 22274 / FSH 22274 — 25VB03S5 F22-12149 — F22-SE-481 — CIL4 CARBON REGENERATION KILN SAFETY SHOWER 2
22-2480-POT-SS4-25-TI — FAH 22272 / FSH 22272 — 25VB03S5 F22-14084 — F22-SE-479 — CIL4 CARBON QUENCH HOPPER AREA SAFETY SHOWER
22-2419-POT-PE8-63-TI — 63x32 — 22-2481-POT-SS4-25-TI — FAH 22275 / FSH 22275 — 25VB03S5 F22-14085 — F22-SE-482 — MERCURY ABATEMENT AREA SAFETY SHOWER 1
22-2420-POT-SS4-25-TI — FAH 22277 / FSH 22277 — 25VB03S5 F22-12151 — F22-SE-506 — MERCURY ABATEMENT AREA SAFETY SHOWER 3
22-2482-POT-SS4-25-TI — FAH 22276 / FSH 22276 — 25VB03S5 F22-14086 — F22-SE-505 — MERCURY ABATEMENT AREA SAFETY SHOWER 2
22-2421-POT-SS4-50-TI — 50x25 — FAH 22273 / FSH 22273 — 25VB03S5 F22-12153 — F22-SE-480 — CIL4 CARBON REGENERATION KILN SAFETY SHOWER 1
22-2423-POT-SS4-25-TI — FAH 22266 / FSH 22266 — 25VB03S5 F22-12154 — F22-SE-473 — CIL4 REGEN KILN DEWATERING SCREEN AREA SAFETY SHOWER
22-2422-POT-SS4-25-TI — FAH 22271 / FSH 22271 — 25VB03S5 F22-12152 — F22-SE-478 — CIL4 ELUTION PUMP AREA SAFETY SHOWER
22-2577-POT-PE8-90

21-2408-POT-SS4-25-TI — 25VB03S5 F21-11236 — F21-SE-418 — CIL4 AREA WEST GROUND SAFETY SHOWER 2
21-2428-POT-SS4-25-TI — FAH 21035 / FSH 21035 — 25VB03S5 F21-11218 — F21-SE-412 — CIL4 AREA UPPER SAFETY SHOWER 1
21-2350-POT-SS4-25-T1 — 25VB03S1 F21-14101 — F21-XM-612 TITRATION LAB — 25VB03S1 F21-11219 — 21-2351-FD-MS1-25 — CIL4 FEED DISTRIBUTION BOX 2000-F21-PID-PR-10001 TITRATION DRAIN
21-0649-POT-SS4-25 — CIL4 CYANIDE ANALYSER 1 2000-F21-PID-PR-10003 POTABLE WATER
21-2429-POT-SS4-25-TI — FAH 21036 / FSH 21036 — 25VB03S5 F21-11238 — F21-SE-413 — CIL4 AREA UPPER SAFETY SHOWER 2
21-2255-POT-SS4-25 — CIL4 CYANIDE ANALYSER 2 2000-F21-PID-PR-10003 POTABLE WATER
21-2430-POT-SS4-25-TI — FAH 21037 / FSH 21037 — 25VB03S5 F21-11239 — F21-SE-414 — CIL4 AREA UPPER SAFETY SHOWER 3
21-2432-POT-SS4-25-TI — FAH 21038 / FSH 21038 — 25VB03S5 F21-11427 — F21-SE-502 — CIL4 TAILS SAMPLER UPPER SAFETY SHOWER
21-2433-POT-SS4-25-TI — FAH 21039 / FSH 21039 — 25VB03S5 F21-11428 — F21-SE-503 — CIL4 TAILS SAMPLER LOWER SAFETY SHOWER
21-0933-POT-PE8-90 — POTABLE WATER RINGMAIN 2000-F24-PID-PR-10021 POTABLE WATER

22-2425-POT-SS4-50-TI — 50x25 — FAH 22270 / FSH 22270 — 25VB03S5 F22-12156 — F22-SE-477 — CIL4 ELUTION & ACID WASH COLUMN BUND AREA SAFETY SHOWER
22-2426-POT-SS4-25-TI — FAH 22269 / FSH 22269 — 25VB03S5 F22-12155 — F22-SE-476 — CIL4 ELUTION & ACID WASH COLUMN AREA LOWER SAFETY SHOWER
FAH 22265 / FSH 22265 — 50x25 — 25VB03S5 F22-12157 — F22-SE-472 — CIL4 LOADED CARBON TRANSFER VESSEL LOWER SAFETY SHOWER
22-2424-POT-SS4-50-TI
22-2427-POT-SS4-25-TI — FAH 22267 / FSH 22267 — 25VB03S5 F22-12168 — F22-SE-474 — CIL4 ELUTION & ACID WASH COLUMN AREA UPPER SAFETY SHOWER
22-2410-POT-PE8-90 — POTABLE WATER RINGMAIN 2000-F24-PID-PR-10021 POTABLE WATER