NOTES:

1. ALL STAGNANT SECTIONS OF SAFETY SHOWER PIPEWORK EXPOSED TO DIRECT SUNLIGHT TO BE INSULATED. SITE TO CONFIRM EXTENTS OF INSULATION. INSULATION NOT REQUIRED FOR RINGMAIN.
2. VALVES TO BE LOCKED CLOSED DURING SP2 COMMISSIONING.

POTABLE WATER RINGMAIN (ELUTION) 2000-F24-PID-PR-10028 POTABLE WATER

POTABLE WATER RINGMAIN (CIL4) 2000-F24-PID-PR-10028 POTABLE WATER

POTABLE WATER RINGMAIN 2000-F75-PID-PR-25010 POTABLE WATER

22-2410-POT-PE8-90

21-0933-POT-PE8-90

75-0613-POT-PE8-90

TIP 1052

TIP 2062 STAGE 1 STAGE 2 80VBFD1L2 F75-12895

TIP 2061 STAGE 1 STAGE 2 80VBFD1L2 F75-12893

80VBFD1L2 F75-12894 NOTE 2

TIP 2148 STAGE 1 STAGE 2 80VBFD1L2 F75-12898

TIP 2147 STAGE 1 STAGE 2 80VBFD1L2 F75-12896

80VBFD1L2 F75-12897 NOTE 2

TIP 2152 STAGE 1 STAGE 2 50VBD3S5 F75-12903

TIP 2150 STAGE 1 STAGE 2 50VBD3S5 F75-12901

TIP 2151 STAGE 1 STAGE 2 50VBD3S5 F75-12902

TIP 2149 STAGE 1 STAGE 2 50VBD3S5 F75-12899

PE8 SS4 21-2406-POT-SS4-25-TI

TI 25VB03S5 F21-11234 F21-SE-415 CIL4 AREA NORTH GROUND SAFETY SHOWER

21-2409-POT-SS4-25-TI

1 TI 25VB03S5 F21-11237 F21-SE-417 CIL4 AREA WEST GROUND SAFETY SHOWER 1

SS4 AG PE8 UG 72-1293-POT-SS4-25-TI TI SS4 PE8

PE8 UG 00-1294-POT-PE8-32

SS4 AG PE8 UG 72-1294-POT-SS4-25-TI

1 FAH 72172 FSH 72172 72-0811-POT-SS4-25-TI TI 25VB03S5 F72-11848 F72-SE-430 HYDROGEN PEROXIDE AREA SAFETY SHOWER 1

1 FAH 72175 FSH 72175 72-2243-POT-SS4-25-TI TI 25VB03S5 F72-11891 F72-SE-451 HYDROGEN PEROXIDE AREA SAFETY SHOWER 2

PE8 SS4 28-0815-POT-SS4-25-TI TI 25VB03S5 F28-11383 F28-SE-419 UFG MILL 2 AREA SAFETY SHOWER 2

PE8 SS4 28-0814-POT-SS4-50-TI TI 50x25 25VB03S5 F28-11384 F28-SE-418 UFG MILL 2 AREA SAFETY SHOWER 1

28-2229-POT-SS4-25-TI TI 25VB03S5 F28-12059 F28-SE-464 UFG MILL 2 AREA SAFETY SHOWER 3

PE8 SS4 28-1668-POT-SS4-50-TI TI 50x25 25VB03S5 F28-11385 F28-SE-421 UFG MILL 3 AREA SAFETY SHOWER 2

28-2506-POT-SS4-25-TI 1 25VB03S5 F28-12031 F28-SE-483 UFG MILL 3 AREA SAFETY SHOWER 4

28-2228-POT-SS4-25-TI TI 25VB03S5 F28-12058 F28-SE-465 UFG MILL 3 AREA SAFETY SHOWER 3

28-0813-POT-PE8-63-TI TI

PE8 SS4 28-1669-POT-SS4-25-TI TI 25VB03S5 F28-11386 F28-SE-420 UFG MILL 3 AREA SAFETY SHOWER 1

BL GREENFIELDS BROWNFIELDS 10-10

BL GREENFIELDS BROWNFIELDS 05-27

BL BROWNFIELDS GREENFIELDS 05-29

BL GREENFIELDS BROWNFIELDS 03-05

75-3063-POT-PE8-90

75-0980-POT-PE8-90

80VBFD1L2 F75-12929

TIP 1083

1

POTABLE WATER RETURN RINGMAIN POTABLE WATER

72-2411-POT-PE8-63-TI HCL AND LEAD NITRATE AREA SAFETY SHOWERS 2000-F24-PID-PR-10028 POTABLE WATER

72-2413-POT-PE8-63-TI CAUSTIC AREA SAFETY SHOWER 2000-F24-PID-PR-10028 POTABLE WATER

72-2412-POT-PE8-63-TI LIME AREA SAFETY SHOWERS 2000-F24-PID-PR-10028 POTABLE WATER

72-2414-POT-PE8-63-TI CYANIDE AREA SAFETY SHOWERS 2000-F24-PID-PR-10028 POTABLE WATER

22-2410-POT-PE8-90 POTABLE WATER RINGMAIN (ELUTION) 2000-F24-PID-PR-10028 POTABLE WATER

21-0933-POT-PE8-90 POTABLE WATER RINGMAIN (CIL4) 2000-F24-PID-PR-10028 POTABLE WATER