NOTES:

1. REFER TO 2000-F24-PID-PR-10035 FOR GLAND WATER DETAIL.
2. THE CIL3 TAILS PRIMARY SAMPLER & CIL3 TAILS SECONDARY SAMPLER ARE LOCATED IN THE CIL4 CIRCUIT (F21).
3. CARBON DETECTION ANALYSER WILL RECEIVE DENSITY SIGNAL INPUT FROM THE CONCENTRATE PRE-LEACH THICKENER UNDERFLOW DENSITY TRANSMITTER (DI30411).
4. EXISTING CYNOPROBE CYANIDE ANALYSER UNIT REPURPOSED FROM ANOTHER AREA IN THE GRANT PROCESSING PLANT FOR USE WITHIN THE CIL3 CIRCUIT.

AE30427
2000-F30-PID-PR-10019
SIGNAL

F30-AN-410
CIL3 CARBON DETECTION ANALYSER 1

XA 30427 FAULT
AI 30427 CARBON CONCENTRATION

NOTE 3

F30-AN-408
CIL3 CARBON DETECTION ANALYSER 2
VENDOR PACKAGE NOTE 3

XA 30430 FAULT
AI 30430 HH H CARBON CONCENTRATION

HIGH PRESSURE PROCESS WATER PUMPS
2000-F24-PID-PR-10030
21-2357-PW-SS3-25
HIGH PRESSURE PROCESS WATER

21-2465-PW-SS3-25

CIL4/ELUTION AIR RECEIVER
2000-F24-PID-PR-10029
21-2110-IA-MSG3-25
PLANT AIR

AE 30430

CIL3 TAILS FEED BOX
2000-F30-PID-PR-10010
30-4052-CON-RL1-250
CONCENTRATE CIL TAILS

F30-CA-424
CIL3 CYANIDE ANALYSER 1
NOTE 4

AI 30394C FREE CYANIDE CONCENTRATION
AI 30394D WAD CYANIDE CONCENTRATION

F30-BX-421
CIL3 TAILS C2 METER BOIL BOX

DETAIL 7
HS 30483
XV 30483

30-4051-CON-PE10-280

TIP-2144
2000-F30-PID-PR-10010
30-4036-CW-PE8-90
CYANIDE WATER

80VBFD1L1 FC

LIC 30462 HH H L LL
LT 30462
LI 30462

DETAIL 3
HS 30463
XV 30463
200VKGD1L1 FL

SP MC-002
50VB03S1 F30-12605

SP SC-018

HS 30462
VSD
M

SP MC-002
50VB03S1 F30-12910

MECH PIPING

DETAIL 3
HS 30465
XV 30465
150VKGD1L1 FL

30-4110-CON-RL1-150

TIP-2144
2000-F30-PID-PR-10010
30-4286-CW-SS3-50
CYANIDE WATER

50VB03S1 F30-12698

SP MC-002
SP@ CIL3 TAILS HOPPER

30-4042-CON-PE10-225
TO GRADE

F30-HP-408
CIL 3 TAILS HOPPER

200-MECH-RL1

DETAIL 4
HS 30464
XV 30464
80VKGD1L1 FO
TO GRADE

200x150
150x100
GLAND NOTE 1

F30-PP-428
CIL3 TAILS PUMP 1

TIP-2206
2000-F75-PID-PR-10007
30-4126-GW-SS3-25
GLAND WATER

21-21111-IA-MSG3-25

WI 30588
f(x)
FI 30588
FIT 30588
DI 30588
DIT 30588
DE 30588
DX 30588
SP MC-002
50VB03S1 F30-12744

RL1 PE10
30-4112-CON-PE10-160

BROWNFIELDS 05-10
BL
GREENFIELDS
30-0805-CON-PE10-160

DN150
F30-SA-443
CIL3 TAILS PRIMARY SAMPLER
DN200

21-2112-CON-PE10-225
CIL4 FEED DISTRIBUTION BOX
2000-F21-PID-PR-10001
CONCENTRATE CIL TAILS

RL1
80VKGD1L1 F30-12143

PE10
30-4136-CON-PE10-90
TO GRADE

SP MS-001
R F
25VB03S1 F30-12607

25x15
15NB BSP

VENDOR PACKAGE 2000-ME027B-E02-10003

PARK POSITION
ZI 30461A
ZI 30461B

SPRAY WATER
HS 30460
SV 30460

DN100 NOTE 2

21-2113-CON-XS-100
100x50
DN50

SPRAY WATER
HS 30479

SP MS-001
R F
25VB03S1 F30-12608

VENDOR PACKAGE 2000-ME027B-E02-10003

SV 30479

F30-SA-444
CIL3 TAILS SECONDARY SAMPLER

DN50
21-2114-CON-PE10-63
CIL4 FEED DISTRIBUTION BOX
2000-F21-PID-PR-10001
CONCENTRATE CIL TAILS

ZI 30480
PARK POSITION

DN50 NOTE 2

25VB03S1 F30-14212
25x15
15NB BSP

21-2115-CON-PE10-63
SAMPLE BUCKET

DETAIL 3
HS 30469
XV 30469
200VKGD1L1 FL

SP MC-002
50VB03S1 F30-12606

DETAIL 4
HS 30470
XV 30470
80VKGD1L1 FO

SP SC-018

VSD
M

SP MC-002
50VB03S1 F30-12916

MECH PIPING

DETAIL 3
HS 30471
XV 30471
150VKGD1L1 FL

200-MECH-RL1
200x150
150x100
GLAND NOTE 1

F30-PP-429
CIL3 TAILS PUMP 2

30-4111-CON-RL1-150

TIP-2206
2000-F75-PID-PR-10007
30-4127-GW-SS3-25
GLAND WATER

ACID EFFLUENT AND FINE CARBON AREA SUMP PUMP
2000-F30-PID-PR-10020
INSTRUMENT AIR
30-4251-IA-MSG3-25

30-4138-IA-MSG3-25
25VB03S1 F30-12050
F30-CP-410
CIL3 TAILS PUMPS CONTROL VALVE PANEL

TIP-2410
2000-F30-PID-PR-10010
INSTRUMENT AIR
30-4137-IA-MSG3-50

30-4137-IA-MSG3-25
ACID EFFLUENT AND FINE CARBON PUMPS CONTROL VALVE PANEL
2000-F30-PID-PR-10020
INSTRUMENT AIR