NOTES:

1. ALL SAMPLE POINTS TO HAVE MINIMAL STUB LENGTH TO SAMPLE VALVE.
2. INVERTED SUCTION TO WITHIN 50mm OF TANK BASE.
3. CONNECTION FOR PUMPS ARE AS2129 TABLE E.

ELECTROWINNING TANK AREA SUMP PUMP
2000-F66-PID-PR-10003
FLOOR DRAINAGE
66-4165-FD-SS1-80

CIL4 ELECTROWINNING CELLS
2000-F66-PID-PR-10002
PREGNANT SOLUTION
66-4166-PE-SS1-150-TI
MANUAL SAMPLING POINT
1.5°
25VB03S1 F66-12809
25VB03S1 F66-12810
66-4176-PE-SS3-25
SAMPLE BUCKET
150VBD1S1 F66-12811
25VB03S1 F66-12812
66-4212-PE-SS3-25
TO GRADE
DETAIL 9 HS 66409
XV 66409
150VBD1S1 FL

CAUSTIC RINGMAIN
2000-F72-PID-PR-10006
CAUSTIC
66-4087-NS-MS1-25-TI
25VBD1S1 F66-12813
25VB03S1 F66-12814
66-4213-NS-MS1-25
TO GRADE
DETAIL 8 HS 66401
XV 66401
25VBD1S1 FC

CIL4 ELUTION PUMPS
2000-F00-PID-PR-10101
PREGNANT ELUATE
00-4151-PE-ECTFEDC1-110
ECTFEDC1
90
SS2
100x80
66-4155-PE-SS2-100-TI
100VBE1S1 F66-12815
25VB03S1 F66-12816
66-4214-PE-SS3-25
TO GRADE
DETAIL 9 HS 66402
XV 66402
100VBE1S1 FL
50x25
DN100
DN80
200-MECH-MS1
66-4157-PE-MS1-200
NOTE 2
200VBD1C1 F66-12877
F66-TK-461
CIL4 ELUATE CIRCULATION TANK 1
50VBD1S1 F66-12818
150VBD1S1 F66-12817
66-4228-PE-SS1-50
15VB03S1 F66-12819
TO GRADE
LIT 66404
LI 66404
HH H L LL
66-4156-PE-SS1-150-TI
50VBD1S1 F66-12820
150VBD1S1 F66-12821
NOTE 3
150x125
F66-PW-461
CIL4 ELECTROWINNING PUMP 1
NOTE 3
100x80
100VCD1S1 F66-12822
50VB03S1 F66-12823
DETAIL 9 HS 66415
XV 66415
100VBD1S1 FL
25VB03S1 F66-12826
100VBD1S1 F66-12827
SAMPLING POINT
FI 66406
FIT 66406
FE 66406
66-4171-PE-SS1-100-TI
CIL4 ELECTROWINNING CELLS
2000-F66-PID-PR-10002
PREGNANT ELUATE

DETAIL 9 HS 66410
XV 66410
150VBD1S1 FL
66-4168-PE-SS1-150-TI
1.5°
25VB03S1 F66-12832
25VB03S1 F66-12833
66-4227-NS-MS1-25
TO GRADE
100VBE1S1 F66-12834
25VB03S1 F66-12835
66-4226-PE-SS3-25
TO GRADE
150VBD1S1 F66-12836
25VB03S1 F66-12837
66-4225-PE-SS3-25
TO GRADE
DETAIL 9 HS 66403
XV 66403
100VBE1S1 FL
66-4169-PE-SS2-100-TI
DETAIL 8 HS 66408
XV 66408
25VBD1S1 FC
50x25
66-4167-NS-MS1-25-TI
DETAIL 9 HS 66416
XV 66416
100VBD1S1 FL
25VB03S1 F66-12824
100VBD1S5 F66-12825
FI 66419
FIT 66419
FE 66419
66-4161-PE-SS1-100-TI
DETAIL 11 HS 66451
HS 66451
SV 66451
25VB03S1 F66-12828
25VB03S1 F66-12830
FC
66-4153-PE-SS3-25
ELECTROWINNING SAMPLER CABINET
2000-F66-PID-PR-10003
PREGNANT ELUATE

SAMPLING POINT
66-4160-BE-SS1-100
BARREN ELUATE TANK
2000-F66-PID-PR-10004
BARREN ELUATE
DETAIL 11 HS 66452
HS 66452
SV 66452
25VB03S1 F66-12829
25VB03S1 F66-12831
FC
66-4154-BE-SS3-25
ELECTROWINNING SAMPLER CABINET
2000-F66-PID-PR-10003
BARREN ELUATE

ELECTROWINNING TANK AREA SUMP PUMP
2000-F66-PID-PR-10003
FLOOR DRAINAGE
66-4170-FD-SS1-80
LIT 66405
LI 66405
HH H L LL
66-4229-PE-SS1-50
15VB03S1 F66-12840
TO GRADE
DN80
DN100
200-MECH-MS1
66-4159-PE-MS1-200
TO GRADE
NOTE 2
200VBD1C1 F66-12878
F66-TK-471
CIL4 ELUATE CIRCULATION TANK 2
50VBD1S1 F66-12839
150VBD1S1 F66-12838
66-4158-PE-SS1-150-TI
50VB03S1 F66-12841
150VBD1S1 F66-12842
NOTE 3
150x125
F66-PW-462
CIL4 ELECTROWINNING PUMP 2
NOTE 3
100x80
100VCD1S1 F66-12843
50VB03S1 F66-12844
DETAIL 9 HS 66418
XV 66418
100VBD1S1 FL
66-4162-BE-SS1-100-TI
25VB03S1 F66-12845
100VBD1S1 F66-12846
DETAIL 9 HS 66417
XV 66417
100VBD1S1 FL
25VB03S1 F66-12847
100VBD1S1 F66-12848