NOTES:

1. FLANGED ASME B16.5 CLASS 150.
2. FIC17003 CASCADE SETPOINT IS SELECTED VIA HS17003A TO AN OPERATOR ENTERED RATIO SETPOINT OR THICKENER CONTROL CUBE.
3. FLOCCULANT DELIVERY TRUCK COMES WITH POWDER BLOWER AND DN100 MALE CAMLOCK ADAPTOR.
4. SIGNALS FROM FLOCCULANT UNLOADING LCS TO DCS.
5. SIREN & BEACON COMBINATION WILL ACTIVATE UPON A HIGH LEVEL TO INDICATE FULL FLOCCULANT SILO.
6. TEMPERATURE SWITCH INSTALLED IN PUMP STATOR BY VENDOR.
7. FUTURE SWAP OVER FROM SCHEME WATER TO BORE WATER FOR FLOCCULANT PLANT.

RAW WATER DISTRIBUTION
2000-F24-PID-PR-10002
RAW WATER
72-2513-BW-PE8-110

W113121B
2000-F16-PID-PR-10001
SIGNAL

W118027
2000-F18-PID-PR-10001
SIGNAL

FI17003
2000-F17-PID-PR-10001
SIGNAL

SCHEME WATER DISTRIBUTION
2000-F24-PID-PR-10006
SCHEME WATER
72-1060-PSW-SS2-100

PROCESS WATER/REAGENTS/
TRASH SCREENS AIR RECEIVER
2000-F24-PID-PR-10013
PLANT AIR
72-1061-IA-MSG3-25
72-0992-IA-MSG3-25

NOTE 2
HS 17003A
FIC 17003
f(x)
H
L

100VBFD1L2
F72-13112
NOTE 8
100VBFE1S2
F72-13125

SP MS-001
F R
SET @ 600kPa
25VB03S1 F72-12158
25VB03S1 F72-12159
XV 72008
DETAIL 8
HS 72003
XV 72003
F72-XM-441
FLOCCULANT SILO DEHUMIDIFIER
PDI 72064
HH H
OD12 PUSH FITTING
DN100 MALE CAMLOCK C/W CAP
DN100

FLOCCULANT DELIVERY
NOTE 4
SP HS-076
WI 72001
LI 72001
LI 72001 HH H LL
LT 72001
CCTV
F72-CAM-001
PRV 72002
FC
XV 72008
SV 72004C
SV 72004B
SV 72004A
F72-DC-403
FLOCCULANT SILO DUST COLLECTOR
F72-SI-401
FLOCCULANT SILO
100x80
FE 72006
FIT 72006
FIC 72006 L
FCV 72007
PT 72014
PI 72014 L
FE 72005
FIT 72005
FIC 72005 L
FCV 72013
PI 72015
XA 72061
F72-DC-403 SYSTEM FAULT
XC 72063
F72-DC-403 SYSTEM ENABLE
DETAIL 8
HS 72008
NOTE 6 SIREN
YA 72001
YA 72001
F72-AT-401
FLOCCULANT SILO ACTIVATOR
UNLOAD START HS 72021
UNLOAD STOP HS 72022
UNLOAD READY XI 72023
NOTE 5
PAH 72016
PSH 72016
TAH 72017
TSH 72017
F72-BW-411
FLOCCULANT SILO BLOWER
F72-FE-411
FLOCCULANT FEEDER
F72-HT-441
FLOCCULANT HEATED CONE
F72-VT-100
FLOCCULANT EDUCTOR & VENTURI MODULE
FSL 72018
F72-XM-410
FLOCCULANT WETTING HEAD
LT 72031
LI 72031 HH
FAL 72018
FAL 72019
FSL 72019
SET AT 600 kPag
PRV 72020
100x80
TO GRADE
O/F
F72-TK-465
FLOCCULANT MIXING TANK
F72-AG-465
FLOCCULANT MIXING TANK AGITATOR
F72-PK-401
FLOCCULANT MIXING PACKAGE
VENDOR PACKAGE
2000-ME029-E02-10001
2000-ME029-E02-10002
DN100
F72-PP-690
FLOCCULANT TRANSFER PUMP
DN200
LI 72032 HH H L LL
LT 72032
72-0971-FL-MS1-200
O/F
100VBD1C1 F72-12160
200VBD1S3 F72-12161
F72-TK-466
FLOCCULANT STORAGE TANK
100VBD1C1 F72-12162
200-MECH-MS1
72-2202-FL-MS1-200
TO GRADE
50VB03S1 F72-12163
72-0972-FL-MS1-100
LI 72071 H
LIT 72071
LE 72071
80VBFD1L2 F72-12443
80x65
NOTE 1
F72-PS-418
FLOCCULANT AREA SUMP PUMP
MS1
PE8
72-1073-FL-MS1-80
25VB03S1 F72-12444
SP MC-001

SET AT 600 kPag
PRV 72051
72-2189-FL-MS1-80
TO GRADE
MS1
PE8
FLOTATION TAILINGS THICKENER
17-0371-FL-PE8-90
2000-F17-PID-PR-10001
FLOCCULANT
80VCD1C1 F72-12169
80VBD1C1 F72-12170
25VB03S1 F72-12171
80VBD1C1 F72-12172
72-1230-FL-MS1-80
TAH 72053
TSH 72053
TE 72053
NOTE 7
DN50
NOTE 3
VSD
15VB03S1 F72-12120
72-1228-FL-MS1-100
100VBD1C1 F72-12164
100VBD1C1 F72-12166
25VB03S1 F72-12165
25VB03S1 F72-12167
100x80
F72-PP-691
FLOTATION TAILINGS THICKENER FLOCCULANT DOSING PUMP 1
SP MC-001
100VBD1C1 F72-12166
25VB03S1 F72-12165
TO GRADE
25VB03S1 F72-12165
100VBD1C1 F72-12164

SET AT 600 kPag
PRV 72052
72-2184-FL-MS1-80
TO GRADE
80VCD1C1 F72-12178
80VBD1C1 F72-12179
25VB03S1 F72-12180
80VBD1C1 F72-12181
72-1231-FL-MS1-80
TAH 72054
TSH 72054
TE 72054
NOTE 7
DN50
NOTE 3
VSD
15VB03S1 F72-12121
72-1229-FL-MS1-100
100VBD1C1 F72-12173
100VBD1C1 F72-12175
25VB03S1 F72-12174
25VB03S1 F72-12176
100x80
F72-PP-692
FLOTATION TAILINGS THICKENER FLOCCULANT DOSING PUMP 2
SP MC-001
TO GRADE
72-0972-FL-MS1-100
72-4061-FL-MS1-50
CONCENTRATE PRE-LEACH THICKENERS FLOCCULANT DOSING PUMP
2000-F72-PID-PR-10016
FLOCCULANT
72-0972-FL-MS1-100
CONCENTRATE THICKENERS FLOCCULANT DOSING PUMPS SKID
2000-F72-PID-PR-10016
FLOCCULANT
72-1076-FL-PE8-90
FLOTATION TAILINGS THICKENER RECIRCULATION FEED BOX
2000-F17-PID-PR-10001
SPILLAGE