NOTES:

1. FLEXIBLE CONNECTION TO INTAKE MANIFOLD PROVIDED WITH DELIVERY TRUCK.
2. SPARE OXYGEN LANCE TAKE-OFF. BLIND FLANGE TO BE INSTALLED POST VALVE.
3. COOLING WATER CONNECTION IS FLANGED AS2129 TABLE E.
4. PURGING CONNECTION POINT. PURGING SYSTEM AND CONNECTION TO PURGING SYSTEM BY OTHERS.

VPSA FLOW FI 72619 | VPSA PRESS PI 72620 | VPSA TEMP TI 72621 | VPSA PURITY AI 72622 | DELIVERY PRESS PI 72623 | DROIX TEMP TI 72624 | VPSA POWER JI 72625

TANK TC-1640 LEVEL LI 72626 | TANK TC-2640 LEVEL LI 72627 | LOX FLOW FI 72628 | VPSA RUNNING XI 72629 | VPSA FAULT XA 72630 | FIRE ALARM XA 72631

VENDOR PACKAGE

F72-PK-405
OXYGEN PLANT

POTABLE WATER DISTRIBUTION
2000-F24-PID-PR-10005
POTABLE WATER

72-3015-POT-SS4-50-TI

GREENFIELDS NSR 07-05

50VB03S5 F72-13103

TIP 2143

TI 72633 H L | PI 72634 H L

TIT 72633 | TE 72633 | PIT 72634

50VB01S1 F72-14058

DETAIL 1
FIC 72632 L
FIT 72632 | FE 72632 | FCV 72632

COOLING WATER PUMPS
2000-F13-PID-PR-10009
COOLING WATER

80VBFD1L2 F72-14061 | 80VBFD1L2 F72-14062 | 25VB03S1 F72-14059 | 80x50 | 50VBD1C1 F0 | 80x50 | 80VBFD1L2 F72-14063 | 80VBFD1L2 F72-14064 | 25VB03S1 F72-14060

DN50

13-0204-COW-MSG1-80-TI

GREENFIELDS Owner 07-02 NOTE 3

TIP 2127

PLANT AIR RECEIVER
2000-F24-PID-PR-10007
PLANT AIR

72-1204-IA-MSG3-50

50VB03S1 F72-13105

25VB03S1 F72-14075

MT

SP MS-002

LIQUID OXYGEN DELIVERY

GREENFIELDS Owner 07-04

TIP 2125

GREENFIELDS NSR 07-06

TIP 2142

GREENFIELDS NSR 07-03 NOTE 3

TIP 2128

50VB03S1 F72-14016

GREENFIELDS Owner 07-01

50VBE1S3 F72-14065 NOTE 4

100VBE1S3 F72-14066

TIP 2141

15VB03S7 F30-14222 | 15VB03S7 F30-14223

100x50 | SET @ 800 kPag PCV 21399 | 100x50

72-1201-OXY-SS6-100

GREENFIELDS BROWNFIELDS 05-23

100x80

21-2120-OXY-SS6-100

25VBE1S3 F72-13134

100VBE1S3 F72-14067

PI 21340 | PI 21340 | FI 21341 | PT 21340 | FIT 21341 | FE 21341

30-4037-OXY-SS6-80 → CIL2 OXYGEN HEADER 2000-F30-PID-PR-10013 OXYGEN

21-2121-OXY-SS6-50

21-0461-OXY-SS6-50

PI 21342 25VBE1S3 F72-13113 | PI 21343 25VBE1S3 F72-13117

PI 21345 25VBE1S3 F72-13110 | PI 21346 25VBE1S3 F72-13111

21-2124-OXY-SS6-50

100x80

PI 21351 25VBE1S3 F72-13129

21-2127-OXY-SS6-50

PI 21353 25VBE1S3 F72-13127 | PI 21354 25VBE1S3 F72-13126 | PI 21352 25VBE1S3 F72-13133

TI 72635 H L | PI 72636 H L | TIT 72635 | TE 72635 | PT 72636 | PI 72636 | 50VB01S1 F72-14057 | DN50

25VBE1S3 F72-13040 | 25VBE1S3 F72-13041

SET @ 700kPa PCV 21346

25VBE1S3 F72-13118 | 25VGLE1S1 FC

DETAIL 1
FIC 21347 H L
FIT 21347 | FE 21347 | FCV 21347

PIT 21348 | PI 21348 H L

25VBE1S3 F72-13120

21-0415-OXY-SS6-25 → CIL4 TANK 1 OXYGEN INJECTION 1 2000-F21-PID-PR-10001 OXYGEN

25VBE1S3 F72-13119 | 25VGLE1S1 FC

DETAIL 1
FIC 21349 H L
FIT 21349 | FE 21349 | FCV 21349

PIT 21350 | PI 21350 H L

25VBE1S3 F72-13121

21-0417-OXY-SS6-25 → CIL4 TANK 1 OXYGEN INJECTION 2 2000-F21-PID-PR-10001 OXYGEN

21-0460-OXY-SS6-25 → CIL4 TANK 1 OXYGEN SPARGE 2 2000-F21-PID-PR-10001 OXYGEN

21-2122-OXY-SS6-25 → CIL4 TANK 1 OXYGEN SPARGE 1 2000-F21-PID-PR-10001 OXYGEN

21-0462-OXY-SS6-25 → CIL4 TANK 3 OXYGEN SPARGE 1 2000-F21-PID-PR-10002 OXYGEN

21-0463-OXY-SS6-25 → CIL4 TANK 3 OXYGEN SPARGE 2 2000-F21-PID-PR-10002 OXYGEN

21-2125-OXY-SS6-25 → CIL4 TANK 2 OXYGEN SPARGE 1 2000-F21-PID-PR-10001 OXYGEN

SET @ 700kPa PCV 21355

25VBE1S3 F72-13042 | 25VBE1S3 F72-13043

25VBE1S3 F72-13430 | 25VGLE1S1 FC

DETAIL 1
FIC 21356 H L
FIT 21356 | FE 21356 | FCV 21356

PIT 21357 | PI 21357 HH H L

25VBE1S3 F72-13432

21-0418-OXY-SS6-25 → CIL4 TANK 2 OXYGEN INJECTION 1 2000-F21-PID-PR-10001 OXYGEN

25VBE1S3 F72-13431 | 25VGLE1S1 FC

DETAIL 1
FIC 21358 H L
FIT 21358 | FE 21358 | FCV 21358

PIT 21359 | PI 21359 HH H L

25VBE1S3 F72-13433

21-0419-OXY-SS6-25 → CIL4 TANK 2 OXYGEN INJECTION 2 2000-F21-PID-PR-10001 OXYGEN

21-2126-OXY-SS6-25 → CIL4 TANK 2 OXYGEN SPARGE 2 2000-F21-PID-PR-10001 OXYGEN

21-2129-OXY-SS6-25 → CIL4 TANK 4 OXYGEN SPARGE 2 2000-F21-PID-PR-10002 OXYGEN

21-2128-OXY-SS6-25 → CIL4 TANK 4 OXYGEN SPARGE 1 2000-F21-PID-PR-10002 OXYGEN

72-0375-COW-MSG1-80 → CHILLER TANK 2000-F13-PID-PR-10009 COOLING WATER RETURN

72-4149-WW-PE8-63 → FINAL TAILS TANK 2000-F23-PID-PR-10001 WASTE WATER