NOTES:

1. DELETED.
2. THE ROOF LOCATED MANHOLES SHALL BE AN EMERGENCY VENT MANHOLE FOR PROTECTION AGAINST RAPID DECOMPOSITION OF HYDROGEN PEROXIDE. 4 OFF.
3. ALL HYDROGEN PEROXIDE ISOLATION VALVE VENT HOLES TO BE INSTALLED ON UPSTREAM SIDE OF VALVE.
4. SPARE NOZZLE.
5. FLANGED ASME B16.5 CL150.
6. THE SIREN WILL ACTIVATE UPON A HIGH-HIGH LEVEL AND/OR HIGH TEMPERATURE ALARM.
7. MINSUP FOR CONNECTION TO A MOBILE COMPRESSOR (ALTERNATIVE SUPPLY) AT GROUND LEVEL.

FI75611 — 2000-F75-PID-PR-25008 — SIGNAL
FI75612 — 2000-F75-PID-PR-25008 — SIGNAL
FI75610 — 2000-F75-PID-PR-25008 — SIGNAL

FIM I DECANT RETURN FREE CN AI 72219 HH H
KALTAILS DAM DECANT RETURN FREE CN AI 72217 HH H
WARNING ALARM XA 72216
CRITICAL ALARM XA 72215
KALTAILS DAM DECANT RETURN WAD CN AI 72218 HH H
FIM I DECANT RETURN WAD CN AI 72220 HH H

KALTAILS TRANSFER PUMP 1 & 2 — 2000-F75-PID-PR-25008 — DECANT WATER — TIP 1076 — 72-1010-PW-PE16-63 — 63x32 — 25VB03S1 F72-12379 — 25VB03S1 F72-12380 — TO GRADE — 5/16" TUBING
FIM I DECANT PUMP — 2000-F75-PID-PR-25008 — DECANT WATER — TIP 1077 — 72-1011-PW-PE16-63 — 63x32 — 25VB03S1 F72-12377 — 25VB03S1 F72-12378 — TO GRADE — 5/16" TUBING
DECANT DAM 3 & 4 PUMPS — 2000-F75-PID-PR-25008 — DECANT WATER — TIP 1078 — 72-2510-PW-PE16-63 — 63x32 — 25VB03S1 F72-12459 — 25VB03S1 F72-12458 — TO GRADE — 5/16" TUBING

F72-CA-401
HYDROGEN PEROXIDE AREA CYANIDE ANALYSER

DD3 & DD4 RETURN WAD CN AI 72238 HH H
DD3 & DD4 RETURN FREE CN AI 72222 HH H
VENDOR PACKAGE 2000-ME020-E02-10001

HYDROGEN PEROXIDE DELIVERY
F72-XM-485
HYDROGEN PEROXIDE UNLOADING HOSE TUNDISH
SP HS-081
SP MC-007
72-0673-HP-SS5-50
25VB03S7 F72-12397
25VB03S7 F72-12399
50VBE1S4 F72-12398 LC
50VBE1S4 FC
TO GRADE
25VB03S1 -
SP HS-058
SP MC-001
72-2526-HP-PE16-63
63x32
TO GRADE

PRV 72205 SET @ 690 kPag 50x15
DETAIL 7 HS 72203
XV 72203
WL 72201 ind
LI 72201B
LI 72201 HH H L LL
LI 72201
LT 72201
TI 72202 HH H
TIT 72202
TE 72202
YA 72204
SIREN NOTE 6
YA 72204

NOTE 2
O/F
DN100
F72-TK-511
HYDROGEN PEROXIDE STORAGE TANK
80VBE1S4 F72-12400
50VBE1S4 F72-12401
50VCE1S4 F72-12402
50VCE1S4 F72-12403
150-MECH-SS1
72-0697-HP-SS5-80
TO GRADE

PRV 72212 SET @ 220 kPag
PI 72213
25VB03S1 F72-12395
VENT
PCV 72211 SET @ 180 kPag
25x15
25VB03S1 F72-12396
SP HS-008
SP MC-001 NOTE 7
72-1261-IA-MGS3-25
25VC01S1 F72-12394
25VB03S1 F72-12393
25VC01S1 F72-12392
25VB03S1 F72-12391

F72-XM-425
HYDROGEN PEROXIDE AREA UNLOADING ARM AND PLATFORM
VENDOR PACKAGE 2000-ME079-J02-10001

CIL4 REAGENTS AIR RECEIVER — 2000-F24-PID-PR-10016 — PLANT AIR — 72-1260-IA-MGS3-25
25VB03S1 F72-14097
3/8" NPT
25x10

DETAIL 11 HS 72214
SV 72214 S
SP MS-001 F R
HS 72221A START PUMP
HS 72221B STOP PUMP

CIL4 REAGENTS AIR RECEIVER — 2000-F24-PID-PR-10016 — PLANT AIR — 72-2075-IA-MSG3-25
25VC01S1 F72-12441
25VB03S1 F72-12442
FC

LI 72210 H
LIT 72210
LE 72210
72-1012-PW-PE8-63
72-2074-HP-PE8-63
50VBE1S4 -
SP HS-006
SP HS-098
NOTE 5
F72-PS-434
HYDROGEN PEROXIDE AREA SUMP PUMP
100x50
25VB03S7 F72-12457
TO GRADE

RAW WATER PUMPS — 2000-F24-PID-PR-10032 — RAW WATER — 00-1386-BW-PE8-63 — PE8 UG — SS3 AG — 72-1737-BW-SS3-50 — 50x25 — 25VB03S1 F72-12384 — SP MC-001 — SP@ HYDROGEN PEROXIDE AREA

72-0674-HP-SS5-50
25VB03S7
TO GRADE

SP MC-006
25VB03S7 F72-12407
FIC 72227 H L LL
VSD
M
NOTE 4 DN25
NOTE 5
F72-PP-521
HYDROGEN PEROXIDE DOSING PUMP 1
50VB03S1 F72-12381
72-0773-HP-SS5-25
25VBE1S4 F72-12404
25VB03S7 F72-12405
25VBE1S4 F72-12406
PRV 72223 SET AT 600 kPag 25x15 TO GRADE
PRV 72230 SET AT 600 kPag 25x15 TO GRADE
15VB03S7 F72-12408
25VCE1S4 F72-12409
25VBE1S4 F72-12410
15VB03S7 F72-12411
72-0786-HP-SS5-25
25VBE1S4 F72-12412
PRV 72226 SET AT 600 kPag 25x15 TO GRADE
FIT 72227
FE 72227
SP HS-091
TIP 1036
HYDROGEN PEROXIDE INLINE MIXER 1
2000-F75-PID-PR-25008 HYDROGEN PEROXIDE
25VCE1S4 F72-12435
25VCE1S4 F72-12436
15VBE03S7 F72-14091
15VBE03S7 F72-14092
72-3123-HP-SS5-15
TO GRADE

SET @ 600 kPag PRV 72208 50x15 TO GRADE
72-0776-HP-SS5-25
25VBE1S4 F72-12413
25VB03S7 F72-12414
25VBE1S4 F72-12415
SP MC-006
25VB03S7 F72-12416
NOTE 4 DN25
VSD
M
NOTE 5
F72-PP-523
HYDROGEN PEROXIDE DOSING PUMP 3
PRV 72225 SET AT 600 kPag 25x15 TO GRADE
15VB03S7 F72-12417
72-0788-HP-SS5-25
SET AT 600 kPag PRV 72232 25x15 TO GRADE
DETAIL 9 HS 72240
XV 72240
25VBE1S4 FL
15VBE03S7 F72-12429
25VCE1S4 F72-12427
PRV 72233 SET AT 600 kPag 25x15 TO GRADE
25VCE1S4 F72-12431
25VCE1S4 F72-12578
PRV 72239 SET AT 600 kPag 25x15 TO GRADE
DETAIL 9 HS 72241
XV 72241
DETAIL 9 HS 72242
XV 72242
15VBE03S7 F72-12433
25VBE1S4 F72-12434
25VBE1S4 F72-12461
15VB03S7 F72-12460

SP MC-006
25VB03S7 F72-12421
NOTE 4 DN25
VSD
M
NOTE 5
F72-PP-522
HYDROGEN PEROXIDE DOSING PUMP 2
PRV 72224 SET AT 600 kPag 25x15 TO GRADE
PRV 72231 SET AT 600 kPag 25x15 TO GRADE
15VB03S7 F72-12422
25VCE1S4 F72-12423
25VBE1S4 F72-12424
15VB03S7 F72-12425
72-0787-HP-SS5-25
25VBE1S4 F72-12426
PRV 72229 SET AT 600 kPag 25x15 TO GRADE
72-0913-HP-SS5-25
72-0798-HP-SS5-25
FIT 72228
FE 72228
SP HS-091
TIP 1037
HYDROGEN PEROXIDE INLINE MIXER 2
2000-F75-PID-PR-25008 HYDROGEN PEROXIDE
72-0774-HP-SS5-25
25VBE1S4 F72-12418
25VB03S7 F72-12419
25VBE1S4 F72-12420
25VCE1S4 F72-12437
25VCE1S4 F72-12438
15VBE03S7 F72-14087
15VBE03S7 F72-14088
72-3124-HP-SS5-15
TO GRADE

SP MC-006
25VB03S7 F72-12449
NOTE 4 DN25
VSD
M
NOTE 5
F72-PP-524
HYDROGEN PEROXIDE DOSING PUMP 4
PRV 72234 SET AT 600 kPag 25x15 TO GRADE
PRV 72235 SET AT 600 kPag 25x15 TO GRADE
15VB03S7 F72-12540
25VCE1S4 F72-12451
25VBE1S4 F72-12452
15VB03S7 F72-12453
72-2273-HP-SS5-25
25VBE1S4 F72-12454
PRV 72236 SET AT 600 kPag 25x15 TO GRADE
FIT 72237
FE 72237
SP HS-099
TIP 1038
HYDROGEN PEROXIDE INLINE MIXER 3
2000-F75-PID-PR-25008 HYDROGEN PEROXIDE
72-2272-HP-SS5-25
25VBE1S4 F72-12446
25VB03S7 F72-12447
25VBE1S4 F72-12448
25VCE1S4 F72-12455
25VCE1S4 F72-12456
15VBE03S7 F72-14089
15VBE03S7 F72-14090
72-3125-HP-SS5-15
TO GRADE

72-0544-HP-SS5-100
SS5 PE16
72-0929-HP-PE16-110
TO GRADE
FINAL TAILS TANK
2000-F23-PID-PR-10001
SPILLAGE