FALL 30921
75\PI\5303

STOP

PAHH 30904
PAL 30904
PAH 30904

LOW SELECT BLOCK

TO FIM II SEAL WATER PUMP
75\PI\5303

FDI 30908
NOTE 1
FI 30908
FAL 30908
FAH 30908
FIT 30908
FE 30908

FINAL TAILS PUMP 4
2000-F75-PID-PR-40021
FINAL TAILS

75-5007-FT-PE20-560
LINE C

FIM II
BYPASS VALVE STATION
2000-F75-PID-PR-40021
FINAL TAILS

75-5007-FT-PE12W-560
TAILS LINE C

30-6000-FT-PE12W-560

PE20
RL2
560x630
600 x400
NOTE 2

TIP
32

ZSO 30900
NO
ZSC 30900
KV 30900
400F30VKG65A

PAL 30902
PIC 30902
PIT 30902
50F30VB02

VSD

400x250
250F30VKG67A
RL
PE

30-6004-FT-RL-400
400x250
250F30VKG70A
RL
PE
ZSC 30930
ZSO 30930
NC

30-6004-FT-MH-400
400x300

F30PP77A
VENDOR PACKAGE
75\PI\5308

400x250
PIC 30904
PIT 30904
50F30VB04
400x150
150F30VKG86A

PSH 30T001
150
400x150
30-6008-FT-MH-400
400x150

KV 30906
ZSC 30906
ZSO 30906
NO
400F30VKG66A
30-6008-FT-RL-400
400x250
250F30VKG69A
RL
PE
ZSO 30910
ZSC 30910
NC
KV 30910

500x400
M
RL PE
600x500
30-6012-FT-RL-500

30-6016-FT-PE25W-630
FIM II
VALVE STATION No.1
2000-F75-PID-PR-40016
FINAL TAILS

FIM II
BYPASS VALVE STATION
2000-F75-PID-PR-40021
FLUSHING WATER

75-8553-PW-PE16-355

TIP
21

175-6096-PW-PE16-355
FIM II VALVE STATION No.1
2000-F75-PID-PR-40016
FLUSHING WATER

150F30VKG68A
RL
PE

175-6028-FT-PE16W-250
175-6022-PW-PE16W-250
175-6028-FT-PE16W-160
175-6028-FT-PE16W-250
175-6026-FT-PE25W-160

175-6022-PW-PE16W-250
250F30VBF40
250F30VC45
250x50
50F30VB01

175-6028-FT-PE16W-250

FLUSHING WATER
75\PI\1015
175-6020-PW-PE16W-250
250F30VC46
250F30VBF41
355x250

175-6096-PW-PE16W-355

175-6022-PW-PE16W-250

175-6094-FT-PE25W-160

SEAL WATER
75\PI\5303
175-6048-GW-SS-25

175-6024-FT-PE16W-250

SEAL WATER
75\PI\5303
175-6050-GW-SS-25

175-6030-FT-PE16W-90

NEW SCOUR PIT

175-6024-FT-PE16W-250

PE
RL
250F30VKG70B
NC
ZSC 30931
ZSO 30931

FALL 30922
75\PI\5303

PE
RL
250F30VKG67B
ZSO 30901
NO
ZSC 30901
KV 30901
400F30VKG65B

PAL 30903
PIC 30903
PIT 30903
50F30VB03

STOP
LOW SELECT BLOCK
VSD

400x250
400x250
400x300
30-6006-FT-RL-400
30-6006-FT-MH-400

F30PP77B
VENDOR PACKAGE
75\PI\5308

STOP

PAHH 30905
PAH 30905
PAL 30905
PIC 30905
PIT 30905
50F30VB05
PSH 30T001
150
400x150
30-6010-FT-RL-400
30-6010-FT-MH-400
400x150
400x150
150F30VKG86B

ZSO 30907
NO
ZSC 30907
KV 30907
400F30VKG66B

FDI 30909
NOTE 1
FI 30909
FAL 30909
FAH 30909
FIT 30909
FE 30909

PE
RL
250F30VKG69B
400x250

500x400
M
RL PE
600x500
30-6014-FT-RL-500

30-6018-FT-PE25W-630
FIM II
VALVE STATION No.1
2000-F75-PID-PR-40016
FINAL TAILS

FINAL TAILS PUMP 3
2000-F75-PID-PR-40021
FINAL TAILS

75-5005-FT-PE20-560
LINE A

FIM II
BYPASS VALVE STATION
2000-F75-PID-PR-40021
FINAL TAILS

75-5005-FT-PE12W-560
TAILS LINE A

30-6002-FT-PE12W-560

PE20
RL2
560x630
600 x400
NOTE 2

TIP
31

150F30VKG68B
RL
PE

KV 30911
ZSC 30911
ZSO 30911
NC

175-6024-FT-PE16W-160

90x50
50F30VB31
90x40
LSH 30912
LAHH 30912
LSL 30912
LIT 30912

175-6030-FT-MH-40

F30PS71

SUMP

POTABLE WATER
25F30VB33
25F30VC43
25F30VB34

BUND AREA

OVERFLOW TO TRAFFICABLE GRATED DRAIN.
DRAIN TO TOE DRAIN

LEGEND:
- EXISTING
- NEW
- FUTURE
- DECOMMISSIONED

NOTES:
1. DIFFERENTIAL FLOW CALCULATION FOR LEAK DETECTION.
2. EXISTING REDUCER TO BE RELOCATED.