NOTES:
1. REUSE EXISTING FLOWMETER.
2. ALL VALVES ARE PREFIXED WITH "F75DCW3". FOR PURPOSES OF CLARITY THIS WILL BE OMITTED FROM P&ID.
3. LOW CYANIDE WATER FLUSHING DUTIES
4. VENT VALVE TO BE POSITIONED AT HIGH POINT SOUTH OF DAMS.
5. POSITIONERS TO BE ADDED TO MANUAL VALVES 450 F2KV01H & F2KV01G
6. EXISTING BUTTERFLY VALVES TO BE RESITED UPSTREAM OF NEW TIE PIECE & KNIFE GATE VALVE
7. REUSE EXISTING SECTION OF DN450 PN16 PE100 HDPE PIPE (BURIED).
8. DIFFERENTIAL FLOW CALCULATION FOR LEAK DETECTION.
9. FURTHER DETAILS FOR SALINE WATER POND SOUTH / BORE WATER DAM 2 CAN BE FOUND ON 2000-F75-PID-PR-10001

LEGEND:
- EXISTING
- NEW
- FUTURE
- DECOMMISSIONED

2000-F75-PID-PR-40031 DF3

FI 75662 FIT 75662 FE 75662

75-706-DCW-PE16-400-SI

DF3-VBF400-ISO_22

NOTE 5 ZS 75660 DF3-VBF400-ISO_21 ZS 75661

NOTE 5 TI 03 450X400 400x300 M 400x300 NOTE 3

DF3-VBF400-ISO_23 DF3-VCV400-NRV_24

DF3-VBF250-ISO_25 TI 04 DF3-VB50-ISO_26 C/TAILS LINE TO A/B DAMS 75\Pi\xx

DF3-VBF250-ISO_27 TI 05 DF3-VB50-ISO_28 A TAILS LINE TO D/A DAMS 75\Pi\xx

75\Pi\xx C TAILS LINE

75\Pi\xx A TAILS LINE

PI 75663

DF3-VBF250-ISO_29 TI 08 DF3-VB50-ISO_30 C/TAILS LINE TO A/B DAMS 75\Pi\xx

DF3-VBF250-ISO_31 TI 09 DF3-VB50-ISO_32 TBC 75\Pi\xx

DF3-VBF250-ISO_33 TI 10 NOTE 6 DF3-VB50-ISO_34 A TAILS LINE TO C PADDOCK 75\Pi\xx

TI 06 DF3-VBF400-ISO_35 NEW DN400 SCOUR TO TOE DRAIN 75\Pi\xx

F30 TAILS - STATION 02
FIM II. TAIL VALVES STATION
(SPAGHETTI JUNCTION).

DECANT DAM 4 2000-F75-PID-PR-40004 DECANT RETURN
75-8532-PW-PE12.5-500 500VBFE1L1 (45001) 500VCE1S1 (45002) 630x500

DECANT DAM 3 2000-F75-PID-PR-40031 DECANT RETURN
75-8112-PW-PE12.5-450 450VBFE1L1 (45003) 450VCE1S1 (45004) 630x450 75-8112-PW-PE12.5-630 710x630

SALINE DAM #3 WATER PUMPS 2000-F75-PID-PR-25009 SALINE WATER
75-0890-BW-PE12.5-630 CHANGE TO EXISTING LINE STYLE 3A

HYDROGEN PEROXIDE INLINE MIXER 3 2000-F75-PID-PR-25008 DECANT WATER
75-8112-PW-PE12.5-710 700VBFE1L1 LO (45007) 700VBFE1L1 (45006)

SALINE DAM #3 WATER PUMPS 2000-F75-PID-PR-25009 SALINE WATER
75-0890-BW-PE12.5-630 CHANGE TO EXISTING LINE STYLE 3A

OE SALINE WATER POND SOUTH NOTE 9 SALINE WATER POND NORTH

OE NEW DN355 OD PE100 PN16 LOW CYANIDE WATER POND FIM

HYDROGEN PEROXIDE INLINE MIXER 3 2000-F75-PID-PR-25008 DECANT RETURN
75-8112-PW-PE12.5-710

KEARNS CORNER 2000-F75-PID-PR-40021 FLUSHING WATER
75-5001-PW-PE12.5-355

EXISTING 75-TK-01 CYANIDE WATER TANK

FI 7531A FIT 7531A FE 7531A NOTE 1

KV 75668 HS 75668 DF3-VBF300-CTV_04 HS 75669 KV 75669

NOTE 4 DN50 DF3-VB50-ARV_07 NOTE 7 NOTE 4 DN50 DF3-VB50-ARV_06

DF3-VB450-ISO_10 ϕ450 ZS 75667 TI 11 TI 14 TI 15 450x280 M TI 12 TI 13 355x280 DF3_355PE DF3-VBF300-CTV_03 DF3-VBF350-ISO_02 DF3-VBF350-ISO_01

CYANIDE WATER TANK 2000-F75-PID-PR-25008 DECANT WATER

KEARNS CORNER 2000-F75-PID-PR-40021 DECANT WATER