NOTES:

1. REFER TO P&ID 2000-F75-PID-PR-25003 J-10 FOR TIE-IN.
2. HIGH POINT VALVE TO BE PLUGGED AND LOCKED CLOSED DURING OPERATION.

FIRE WATER NETWORK
2000-F75-PID-PR-25003
FIRE WATER

75-0558-FW-MSG2-200 — A/G — U/G — MSG2 — PE16

00-0566-FW-PE16-225

F16-HYD-408
FLOTATION BLOWER AREA FIRE HYDRANT

F17-HYD-414
FLOTATION TAILINGS THICKENER & CHILLED WATER AREA FIRE HYDRANT

FH

16-1400-FW-MSG2-100 — MSG2 A/G — PE16 U/G

00-1399-FW-PE16-110 — PE16 — MSG2 — 225x110

17-1402-FW-MSG2-100 — MSG2 A/G — PE16 U/G

00-1401-FW-PE16-110

PAL 24651

SP VC-006 — SP FS-006 — PSL 24651 — YV 24651 — PI 24651A — PI 24651B — SP VC-006

17-0271-FW-MSG2-80 — MSG2 A/G — PE16 U/G

00-0272-FW-PE16-90

80VGE1F1 F17-11509

PAL 24653

SP VC-006 — SP FS-006 — PSL 24653 — YV 24653 — PI 24653A — PI 24653B — SP VC-006

72-0994-FW-MSG2-80 — MSG2 A/G — PE16 U/G — 100x80

00-0944-FW-PE16-110

80VGE1F1 F72-11511

SP SP-010 4 OFF — THICKENER F17-TH-401 HYDRAULIC DRIVE SPRINKLER SYSTEM

PRV 24652 — SET @ 1400kPag — SP FS-010 — TO GRADE

PRV 24654 — SET @ 1400kPag — SP FS-010 — TO GRADE

SP SP-010 8 OFF — FROTHER TANK PERIMETER SPRINKLERS (F72-TK-432)

FLAME DETECTED — YA 24655 — YD 24655 LHD

F72-HYD-406
FLOTATION TAILINGS THICKENER REAGENTS AREA FIRE HYDRANT

72-0606-FW-MSG2-100 — MSG2 A/G — PE16 U/G

00-0605-FW-PE16-110

F13-HYD-418
COS STOCKPILE FIRE HYDRANT

13-1246-FW-MSG2-100 — MSG2 A/G — PE16 U/G

00-1245-FW-PE16-110

F13-HYD-405
RECYCLE CRUSHERS C & D FIRE HYDRANT

13-0569-FW-MSG2-100 — MSG2 A/G — PE16 U/G — 225x110

00-0568-FW-PE16-225

PE16 U/G — MSG2 A/G — MSG2

13-0637-FW-MSG3-50

13-1819-FW-MSG3-50 — 50X25 — **F13-FHR-405** RECYCLE CRUSHING FIRE HOSE REEL 2

13-0559-FW-MSG3-50 — 50X25 — **F13-FHR-414** RECYCLE CRUSHING FIRE HOSE REEL 1

25VB03S1 F13-11524

50VB03S1 F13-11523

80VGE1F1 F13-11513

PAL 24656 — PSL 24656 — YV 24656 — PI 24656A — PI 24656B

SP FS-006 — SP VC-006 — SP VC-006

SP FS-010 — PRV 24657 — SET @ 1400kPag — TO GRADE

13-1403-FW-MSG2-200

200VGE1F1 F13-11515 — 50VBE1S1 F13-11517

50VBE1S1 F13-11518 — 200VGE1F1 F13-11528 — 50VBE1S1 F13-11529

SP VC-003 4 OFF

MSG2 A/G — PE16 U/G — 00-1405-FW-PE16-225 — PE16 — MSG2 — U/G — A/G — 12-0638-FW-MSG2-200 — FIRE WATER NETWORK 2000-F24-PID-PR-10022 FIRE WATER

PE16 — MSG2 — U/G — A/G — 00-0578-FW-PE16-110 — PE16 U/G — MSG2 A/G — 12-0633-FW-MSG2-100 — FH

F12-HYD-404
STOCKPILE FEED CONVEYOR TAKEUP TOWER FIRE HYDRANT

13-0564-FW-MSG3-50 — 50x25 — **F13-FHR-403** COS FIRE HOSE REEL 1

NOTE 2 — 25VB03S1 F13-14146 LC — 13-0636-FW-MSG3-50 — 50x25 — **F13-FHR-404** COS FIRE HOSE REEL 2

MSG2 — MSG3 — 13-1432-FW-MSG3-50 — 50VB03S1 F13-11520 — 25VB03S1 F13-11522

PAL 24662 — PSL 24662 — YV 24662 — PI 24662A — PI 24662B

100x80 — SP FS-006 — NOTE 2 — 25VB03S1 F13-14154 LC

80VGE1F1 F13-11530 — SP VC-006 — SP VC-006 — 13-0563-FW-MSG2-80

13-1880-FW-MSG3-25 TO 13-1904-FW-MSG3-25

SP SP-010 28 OFF — SP SP-011 42 OFF

FLAME DETECTED — YA 24664 — YD 24664 LHD

13-0200-FW-MSG2-200 — FIRE WATER NETWORK 2000-F24-PID-PR-10023 FIRE WATER

RECYCLE CRUSHER D LUBE SPRINKLER SYSTEM — SP SP-010 6 OFF — 13-1935-FW-MSG3-25 TO 13-1940-FW-MSG3-25

RECYCLE CRUSHER C LUBE SPRINKLER SYSTEM — SP SP-010 6 OFF — 13-1945-FW-MSG3-25 TO 13-1950-FW-MSG3-25

FLAME DETECTED — YA 24658 — YD 24658A IR — YD 24658B IR

RECYCLE CRUSHER ISOLATION GATES HYDRAULIC UNIT — SP SP-010 1 OFF — 13-0947-FW-MSG3-50 — MSG3 — MSG2

RECYCLE CRUSHER D HYDRAULIC UNIT — SP SP-010 1 OFF — 13-0946-FW-MSG3-25 — MSG3 — MSG2

RECYCLE CRUSHER C HYDRAULIC UNIT — SP SP-010 1 OFF — 13-0945-FW-MSG3-25 — MSG3 — MSG2

13-0561-FW-MSG2-80 — 13-1404-FW-MSG2-80 — 13-0560-FW-MSG2-80

FIRE WATER NETWORK
2000-F75-PID-PR-60035
FIRE WATER

75-0598-FW-MSG2-100 — MSG2 A/G — PE16 U/G

100VGE1F1 F75-11660

00-0635-FW-PE16-110 — PE16 U/G — MSG2 A/G — 75-0642-FW-MSG2-100 — MSG2 A/G — PE16 U/G — 00-0685-FW-PE16-110 — PE16 U/G — MSG2 A/G — 75-1816-FW-MSG2-100 — FH

F75-HYD-416
SALINE WATER PUMPS AREA FIRE HYDRANT