NOTES:

1. ALL STAGNANT SECTIONS OF SAFETY SHOWER PIPEWORK EXPOSED TO DIRECT SUNLIGHT TO BE INSULATED. SITE TO CONFIRM EXTENTS OF INSULATION. INSULATION NOT REQUIRED FOR RINGMAIN.
2. VALVES TO BE LOCKED CLOSED DURING SP2 COMMISSIONING.

LEGEND:

SP2 NEW
SP2 DECOMMISSIONED

POTABLE WATER
RINGMAIN (ELUTION)
2000-F24-PID-PR-10028
POTABLE WATER

22-2410-POT-PE8-90

POTABLE WATER
RINGMAIN (CIL4)
2000-F24-PID-PR-10028
POTABLE WATER

21-0933-POT-PE8-90

POTABLE WATER RINGMAIN
2000-F75-PID-PR-25010
POTABLE WATER

75-0613-POT-PE8-90

TIP 2062 STAGE 1 STAGE 2
80VBFD1L2 F75-12895

TIP 2148 STAGE 1 STAGE 2
80VBFD1L2 F75-12898

PE8 SS4
72-1293-POT-SS4-25-TI
TI

PE8 SS4
21-2406-POT-SS4-25-TI
TI
25VB03S5 F21-11234
F21-SE-415
CIL4 AREA NORTH GROUND SAFETY SHOWER

TIP 2061 STAGE 1 STAGE 2
80VBFD1L2 F75-12893

80VBFD1L2 F75-12894 NOTE 2

21-2409-POT-SS4-25-TI
TI
25VB03S5 F21-11237
F21-SE-417
CIL4 AREA WEST GROUND SAFETY SHOWER 1

TIP 2147 STAGE 1 STAGE 2
80VBFD1L2 F75-12896

80VBFD1L2 F75-12897 NOTE 2

PE8 SS4 AG
PE8 UG 00-1294-POT-PE8-32
SS4 AG PE8 UG

72-0811-POT-SS4-25-TI
TI
25VB03S5 F72-11848
F72-SE-430
HYDROGEN PEROXIDE AREA SAFETY SHOWER 1

FAH 72172
FSH 72172

72-2243-POT-SS4-25-TI
TI
25VB03S5 F72-11891
F72-SE-451
HYDROGEN PEROXIDE AREA SAFETY SHOWER 2

FAH 72175
FSH 72175

TIP 2152 STAGE 1 STAGE 2
50VB03S5 F75-12903

TIP 2150 STAGE 1 STAGE 2
50VB03S5 F75-12901

TIP 2151 STAGE 1 STAGE 2
50VB03S5 F75-12902

TIP 2149 STAGE 1 STAGE 2
50VB03S5 F75-12899

PE8 SS4
28-0815-POT-SS4-25-TI
TI
25VB03S5 F28-11383
F28-SE-419
UFG MILL 2 AREA SAFETY SHOWER 2

PE8 SS4
28-0814-POT-SS4-50-TI
TI
50x25
25VB03S5 F28-11384
F28-SE-418
UFG MILL 2 AREA SAFETY SHOWER 1

28-2229-POT-SS4-25-TI
TI
25VB03S5 F28-12059
F28-SE-464
UFG MILL 2 AREA SAFETY SHOWER 3

PE8 SS4
28-1668-POT-SS4-50-TI
TI
50x25
25VB03S5 F28-11385
F28-SE-421
UFG MILL 3 AREA SAFETY SHOWER 2

28-2506-POT-SS4-25-TI
25VB03S5 F28-12031
F28-SE-483
UFG MILL 3 AREA SAFETY SHOWER 4

28-2228-POT-SS4-25-TI
TI
25VB03S5 F28-12058
F28-SE-465
UFG MILL 3 AREA SAFETY SHOWER 3

28-0813-POT-PE8-63-TI
TI

PE8 SS4
28-1669-POT-SS4-25-TI
TI
25VB03S5 F28-11386
F28-SE-420
UFG MILL 3 AREA SAFETY SHOWER 1

75-3063-POT-PE8-90
75-0980-POT-PE8-90
75-3111-POT-PE8-90
POTABLE WATER TANK
2000-F75-PID-PR-25002
POTABLE WATER

72-2411-POT-PE8-63-TI
HCL AND LEAD NITRATE AREA SAFETY SHOWERS
2000-F24-PID-PR-10028
POTABLE WATER

72-2413-POT-PE8-63-TI
CAUSTIC AREA SAFETY SHOWER
2000-F24-PID-PR-10028
POTABLE WATER

72-2412-POT-PE8-63-TI
LIME AREA SAFETY SHOWERS
2000-F24-PID-PR-10028
POTABLE WATER

72-2414-POT-PE8-63-TI
CYANIDE AREA SAFETY SHOWERS
2000-F24-PID-PR-10028
POTABLE WATER

22-2410-POT-PE8-90
POTABLE WATER RINGMAIN (ELUTION)
2000-F24-PID-PR-10028
POTABLE WATER

21-0933-POT-PE8-90
POTABLE WATER RINGMAIN (CIL4)
2000-F24-PID-PR-10028
POTABLE WATER