PARTIALLY AS CONSTRUCTED

R03 5

F02 1 | F02 2 | F02 3 | F02 4 | F02 5 | F03 1 | F03 2 | F03 3 | F03 4 | F03 5 | F04 1 | F04 2

415V 3 PHASE + NEUTRAL 50Hz 2500A FORM 4 FAULT LEVEL 50kA FOR 1 sec.

CONTINUED DWG 34\E\0021-001

50A | 20A | 100A 160A | 100A 160A | 315A 400A | 63A | 80A 100A | 125A 200A | 315A 400A | 20A 32A

CA-60 | CA-72 | CA6-210-EI @ 350A | 415V/110V 2KVA | 16A

F35PP448-VS | F35PP435-VS | F35-PP-61BVS | F35-PP-61AVS | F35-PP-63AVS | F34-PP-01VS | F35-PP-63BVS

15 kW | 5.5 kW | 30 kW | 30 kW | 110 kW | 37 kW | 110 kW

1RL3 | 1RL2 | 2 | NOTE 2.

BYPASS SWITCH & TRANSFORMER | 240V | 110V

F35-PP-448 F1 CIRCUIT 2 FEED PUMP REF DWG 2000-F34-SCM-EL-10003 — TO SUBSTATION COMMS RACK

F35_PP_435 UFG CIRCUIT 1 FEED PUMP REF DWG 2000-F34-SCM-EL-10002 — TO SUBSTATION COMMS RACK

F35-PP-61B ULTRA FINE GRINDING CONCENTRATE THICKENER U/F PUMP B REF. DWG. 34\E\0041-018 — TO PROCESS CONTROL CUBICLE

F35-PP-61A ULTRA FINE GRINDING CONCENTRATE THICKENER U/F PUMP A REF. DWG. 34\E\0041-010 — TO PROCESS CONTROL CUBICLE

SPARE

F35-PP-63A ULTRA FINE GRINDING DESLIME CYCLONE FEED PUMP A REF. DWG. 34\E\0041-010 2000-F34-SCM-EL-10005 — TO PROCESS CONTROL CUBICLE

SPARE

F34-XE-02 SUBSTATION No.10 240V UN INTERRUPTABLE POWER SUPPLY REF. DWG. 34\E\0041-004

11

F34-XE-02F SUBSTATION No.10 240V/110V PROTECTION EQUIPMENT SUPPLY REF. DWG 20\E\0421-002 & 20\E\0001

SPARE

F34-PP-01 ULTRA FINE GRINDING MILL FEED PUMP REF. DWG. 34\E\0041-010 — TO PROCESS CONTROL CUBICLE

F35-PP-63B ULTRA FINE GRINDING DESLIME CYCLONE FEED PUMP B FEED PUMP B REF. DWG. 34\E\0041-010 2000-F34-SCM-EL-10005 — TO PROCESS CONTROL CUBICLE

SPARE

34-TR-03 110V SUPPLY MCC 34-SW-01 REF DWG 34\E\0041-001 ONWARDS

110kW DRIVE PANEL 35-AG-61B — 35-AG-61B FILTER FEED TANK No.2 AGITATOR REF. DWG. 2000-F34-SCM-EL-10102

Approved [X]
Approved as Noted [ ]
Not Approved [ ]
For Information Only [ ]
Signed C Laird Date 07/08/2026
ACCEPTANCE DOES NOT RELIEVE THE SUPPLIER / CONTRACTOR OF ITS RESPONSIBILITY OR LIABILITIES UNDER THE PURCHASE ORDER / CONTRACT

R02 4 | R02 5 | R03 1 | R03 2 | R03 3 | R03 4 | F02 2 | R03 5 | R03 6 | R03 7 | R03 8 | R04 1 | R04 2 | R04 3 | R04 4 | R04 5

415V 3 PHASE + NEUTRAL 50Hz 2500A FORM 4 FAULT LEVEL 50kA FOR 1 sec.

CONTINUED DWG 34\E\0021-001

32A 100A | 16A 100A | 32A 63A | 50A 63A | 32A 63A | 16A 63A | 63A | 50A | 10A 63A | 6A 63A | 10A 63A | 100A 100A | 125A 60A | 250A 400A

CA7-9 | CA7-60 | CA-76 | CA6-210-EI @ 350A | NOTE 3

80/5 W | 125/5 W | 250/5 W

F34CR02-IS | F34CR01-IS | F34PP443-VS | F35PP449-VS | SOFT STARTER

20A | 20A | CRANE | CRANE | 4 kW | 2.2 kW | 11 kW | 15 kW | 1.5 kW | 22 kW | 15 kW | xx kW | 0.75 kW | 1.5 kW | 30 kW | 37 kW | 110 kW

1RL3 | 2 | NOTE 2. | 1RL1

F34-CR-02 ULTRA FINE GRINDING DAVIT CRANE REF. DWG 34\VE\xxx

F34-CR-01 ULTRA FINE GRINDING MONORAIL CRANE REF. DWG 34\VE\xxx

F34-RC-01 ULTRA FINE GRINDING LIQUID RESISTANCE STARTER CONTROL PANEL REF. DWG 34\E\0041-011 REF. DWG 34\E\0021-001

F34-PS-02 ULTRA FINE GRINDING CYCLONE AREA SUMP PUMP REF. DWG 34\E\0041-005

F34-PS-01 ULTRA FINE GRINDING MILL AREA SUMP PUMP REF. DWG 34\E\0041-005

34-SC-01 UFG VIBRATING SCREEN REF. DWG 34\E\0041-xxx

F34-PP-443 UFG MILL 1 PRODUCT PUMP REF DWG: 2000-F34-SCM-EL-10001 — TO SUBSTATION COMMS RACK

F35-PP-449 UFG CIRCUIT 3 FEED PUMP REF. DWG: 2000-F34-SCM-EL-10004 — TO SUBSTATION COMMS RACK

F34-FV-01 UFG VIBRATING FEEDER REF. DWG 34\E\0041-xxx

F34-HE-01 ULTRA FINE GRINDING MILL DRIVE HEATER REF. DWG 34\E\0041-004

SPACE

F34-FN-01 ULTRA FINE GRINDING GEARBOX OIL COOLING FAN REF. DWG 34\E\0041-004

F35-AG-62 ULTRA FINE GRINDING PLANT FEED TANK AGITATOR REF. DWG 34\E\0041-006 — TO PROCESS CONTROL CUBICLE

F35-PW-62 ULTRA FINE GRINDING PLANT FEED PUMP REF. DWG 34\E\0041-006 — TO PROCESS CONTROL CUBICLE

F35-AG-61B ULTRA FINE GRINDING FILTER FEED TANK B AGITATOR REF. DWG 34\E\0041-007 — TO PROCESS CONTROL CUBICLE

LEGEND

- COMBINED FUSE SWITCH
- CONTACTOR
- OVERLOAD
- VSD — VARIABLE SPEED DRIVE
- RTD — RTD
- THERMISTOR
- LOCAL CONTROL STATION
- M — MOTOR
- BUCHHOLZ PROTECTION
- PQM — POWER QUALITY METER
- LINK
- FUSE
- UPS
- OVERCURRENT RELAY WITH TIME LAG
- I INST — INSTANTANEOUS EARTH CURRENT RELAY
- A mA — AMP SIGNAL CONVERTOR
- 5 20A — GPO
- HEATER
- CONTROL TRANSFORMER
- TRANSFORMER
- WITHDRAWABLE BREAKER HEATER
- DISTRIBUTION BOARD
- SOFT STARTER

LEGEND

- STAGE 1 - NEW
- STAGE 1 - REMOVE
- STAGE 1 - DECOMMISSIONED (OTHERS)
- STAGE 2 - NEW
- STAGE 2 - REMOVE
- STAGE 2 - DECOMMISSIONED (OTHERS)

NOTES

1. ALL AFS (ARC FLASH SENSORS) ARE CONNECTED TO THE ARC FLASH RELAY VIA I/O UNITS.
2. VSD OUTGOING FIELD CABLES DISCONNECTED AND MADE SAFE AT BOTH ENDS.
3. BUCKET R04/5 EQUIPMENT IS NOT TO BE MODIFIED. BYPASS THE CONTACTOR ONLY AND LEAVE INSITUE. NEW CABLE TERMINATES TO LOAD SIDE OF EXISTING FUSED SWITCH

KCGM GROWTH PROJECT

DRAWING NO. 2000-F34-SLD-EL-10102

REV	DATE	DESCRIPTION	CHECK
1RL3	20/07/26	AS CONSTRUCTED FOR SP1	
1RL2	04/06/26	AS CONSTRUCTED FOR F34.20.01	
2	03/08/26	DESIGN CHANGE INFLUENCED BY SHUTDOWN PLANNING	

MK	DATE	REVISION	BY	CKD	APP
7	09/01/18	AS BUILT	RH	JM	JM
6	15/02/07	34SC01 DETAILS ADDED.			
5	13/05/04	PUMP 35-PP-64 MOVED FROM 34-SW-62, PANEL 1F			
4	15/05/02	"AS BUILT"		IGC	
3	05/02/02	DRIVES 34-PW-01A, 01B, 01C ADDED		IGC	
2	05/02/02	"AS BUILT" AS PER KOUNIS DRAWINGS		AB	

MK	DATE	REVISION	BY	CKD	APP
1	15/11/01	HOLD #53 ADDED, OTHER MINOR REVISIONS	MGM	EM	
0	11/10/01	ISSUED FOR CONSTRUCTION		EM	
11	11/05/20	ISSUED FOR CONSTRUCTION - F34XE02		AA	
10	14/09/20	2019 S.L.D. UPDATE PROJECT "AS BUILT"		RA	
9A	26/08/19	2019 S.L.D. UPDATE PROJECT "AS BUILT"- FIELD REVIEW		RH	
8	08/06/18	ARC FLASH SENSOR INSTALLED		JMR	

REFERENCE DRAWINGS | DWG NO.

SCALE NTS | DRAWN [redacted] 23/08/01 | DESIGNED [redacted] 21/08/01 | CHECKED | APPROVED | PROJ.APP | PROJ FILE #.

FIMISTON PLANT
ULTRA FINE GRINDING
SUBSTATION NO 10 415V MCC 34-SW-02
SINGLE LINE DIAGRAM

A1 | 34\E\0021-002 | 11

KALGOORLIE CONSOLIDATED GOLD MINES PTY. LTD. ABN 009 377 619 003