F13-SR-005
415V MILL CHILLERS & REAGENTS SWITCHROOM

F13-SW-020
MILL CHILLERS & REAGENTS 415V MOTOR CONTROL CENTRE

CONTINUED ON SHT 1
2000-F13-SLD-EL-10701

CONTINUED ON SHT 3
2000-F13-SLD-EL-10703

415V 3NE~ 50Hz 4000A 65kA for 1sec

03R-10	02R-05	02R-01	02R-09	03F-16	03R-19	02R-17	02R-21	2R-04	2R-07
20A	32A	20A	20A	20A	100A	20A	20A	20A	20A
2A 32A	2A 32A	2A 32A	2A 32A	2A 32A	2A 32A	2A 32A	2A 32A	2A 32A	2A 32A
I >	I >	I >			I >	I >	I >	I >	I >
70A	70A	70A	70A	70A	70A	100/1A	100/1A	100/1A	100/1A
EOL	EOL	EOL	EOL	EOL	EOL				
M 3~	M 3~	M 3~		M 3~	t° M 3~	M 3~	M 1~	M 3~	M 3~
0.6kW	7.5kW	0.37kW	0.15kW	1.1kW	37kW	5.5kW	0.046kW	1.5kW	1.5kW
F72-AT-401 FLOCCULANT SILO ACTIVATOR	F72-BW-411 FLOCCULANT SILO BLOWER	F72-FE-411 FLOCCULANT FEEDER	SPARE DOL	F72-FN-491 PAX FAN	F72-PP-690 FLOCCULANT TRANSFER PUMP	F72-PP-691 FLOTATION TAILINGS THICKENER FLOCCULANT DOSING PUMP 1	F72-FN-691 FLOTATION TAILINGS THICKENER FLOCCULANT DOSING PUMP 1 MOTOR COOLING FAN	F72-PP-692 FLOTATION TAILINGS THICKENER FLOCCULANT DOSING PUMP 2	F72-FN-692 FLOTATION TAILINGS THICKENER FLOCCULANT DOSING PUMP 2 MOTOR COOLING FAN	F72-PP-693 CONCENTRATE PRE-LEACH THICKENER FLOCCULANT DOSING PUMP	F72-PP-694 CONCENTRATE THICKENER FLOCCULANT DOSING PUMP
2000-F72-SCM-EL-10702	2000-F72-SCM-EL-10703	2000-F72-SCM-EL-10704	2000-F72-SCM-EL-10718	2000-F72-SCM-EL-10201	2000-F72-SCM-EL-10706	2000-F72-SCM-EL-10707	2000-F72-SCM-EL-10707	2000-F72-SCM-EL-10708	2000-F72-SCM-EL-10708	2000-F72-SCM-EL-10709	2000-F72-SCM-EL-10710

NOTES

1. REFER TO SHEET 1.

LEGEND

1. REFER TO SHEET 1.

Approved	X
Approved as Noted	
Not Approved	
For Information Only	

ACCEPTANCE DOES NOT RELIEVE THE SUPPLIER / CONTRACTOR OF ITS RESPONSIBILITY OR LIABILITIES UNDER THE PURCHASE ORDER / CONTRACT

2000-F13-SLD-EL-10702_Rev1

Milling & classification F13-SW-020 415V MCC single line diagram sheet 2

O:\CAD PROJECTS\235 NORTHERN STAR RESOURCES LTD\235117 KCGM GROWTH PROJECT\03 DELIVERABLES\ELV\F13 - MILLING & CLASSIFICATION\2000-F13-SLD-EL-10702.DWG 30MAY25 8:08AM SANDRA CULL