F13-SR-005
415V MILL CHILLERS & REAGENTS SWITCHROOM

F13-SW-020
MILL CHILLERS & REAGENTS 415V MOTOR CONTROL CENTRE

CONTINUED ON SHT 2
2000-F13-SLD-EL-10702

CONTINUED ON SHT 4
2000-F13-SLD-EL-10704

415V 3NE~ 50Hz 4000A 65kA for 1sec

2R-10	03R-14	03F-01	03F-04	03F-07	03F-10	03F-13	3F-05	3F-08	3F-11	3F-14	3F-17
20A	100A	20A	20A	20A	20A	20A	20A	20A	20A	20A	20A
2A 32A	2A 32A	2A 32A	2A 32A	2A 32A	2A 32A	2A 32A	2A 32A	2A 32A	2A 32A	2A 32A	2A 32A
	I > 70A										
	EOL										
I > 100/1A	I > 100/1A	I > 100/1A	I > 100/1A	I > 100/1A	I > 100/1A	I > 100/1A	I > 100/1A	I > 100/1A	I > 100/1A	I > 100/1A	I > 100/1A
						1					
M 3~ 1.5kW	M 3~ 30kW	M 3~ 2.2kW	M 3~ 2.2kW	M 3~ 2.2kW	M 3~ 1.1kW	M 3~ 1.1kW	M 3~ 0.37kW	M 3~ 0.37kW	M 3~ 0.37kW	M 3~ 0.37kW	M 3~ 0.37kW
1											
F72-PP-696 THICKENERS STANDBY FLOCCULANT DOSING PUMP 2000-F72-SCM-EL-10712	F72-PS-418 FLOCCULANT AREA SUMP PUMP 2000-F72-SCM-EL-10713	F72-PP-661 PAX DOSING PUMP 1 2000-F72-SCM-EL-10202	F72-PP-662 PAX DOSING PUMP 2 2000-F72-SCM-EL-10203	F72-PP-663 PAX DOSING PUMP 3 2000-F72-SCM-EL-10204	F72-PP-664 PAX DOSING PUMP 4 2000-F72-SCM-EL-10205	F72-PP-665 PAX DOSING PUMP 5 2000-F72-SCM-EL-10206	F72-PP-666 FROTHER DOSING PUMP 1 2000-F72-SCM-EL-10251	F72-PP-667 FROTHER DOSING PUMP 2 2000-F72-SCM-EL-10252	F72-PP-668 FROTHER DOSING PUMP 3 2000-F72-SCM-EL-10253	F72-PP-669 FROTHER DOSING PUMP 4 2000-F72-SCM-EL-10254	F72-PP-670 FROTHER DOSING PUMP 5 2000-F72-SCM-EL-10255

NOTES

1. REFER TO SHEET 1.

LEGEND

1. REFER TO SHEET 1.

NORTHERN STAR RESOURCES LTD

Approved	X
Approved as Noted	
Not Approved	
For Information Only	

ACCEPTANCE DOES NOT RELIEVE THE SUPPLIER / CONTRACTOR OF ITS RESPONSIBILITY OR LIABILITIES UNDER THE PURCHASE ORDER / CONTRACT

2000-F13-SLD-EL-10703_Rev1

Milling & classification F13-SW-020 415V MCC single line diagram sheet 3

O:\CAD PROJECTS\235 NORTHERN STAR RESOURCES LTD\23517 KCGM GROWTH PROJECT\03 DELIVERABLES\ELV\F13 - MILLING & CLASSIFICATION\2000-F13-SLD-EL-10703.DWG 30MAY25 8:08AM SANDRA CULL