415V FROM
F22-SW-031
2000-F22-SCM-EL-10271

415V FROM
F22-GE-131
2000-F22-SLD-EL-10261

EARTH BAR

F22-SW-131
MOTOR CONTROL CENTRE

F22-SD-131
415VAC SURGE DIVERTER
106kA
SD OK
SD OK
SD OK
24VDC
SD

LINE 227
2000-F22-SCM-EL-10273

F105 F110 F111 F116 F121

N1 2A 32A
N2 100A 100A
N3 2A 32A
N4 2A 32A
N5 2A 32A

LLI RD
LLI RD

A116
ATYSC65CIP
ATS CONTROL INTERFACE
PART OF

A115
ATyS C65 CONTROLLER
PART OF
NOTE 3, 6.

F1 F2 F3 F4 F5 F6
6A 32A
6A 32A

SOURCE 1
MAIN
SUPPLY

SOURCE 2
GENERATOR
SUPPLY

Q131 400A
Q132 400A

U131
MOTOR OPERATION
UNIT

U132
MOTOR OPERATION
UNIT

TERASAKI
TEMBREAK
PRO B MODEL
MCCB

TERASAKI
TEMBREAK
PRO B MODEL
MCCB

MOTOR OPERATOR
(PART OF)

MOTOR OPERATOR
(PART OF)

MAIN PWR
(ORANGE)

PART
OF

CPSR

CONT LINE 243

LINE 234

24VDC
0VDC

CURRENT
TRANSFORMER

RS485

USB

NOT USED

END OF BUS
RESISTOR
4829 0180

DIGIS IO-10
4829 0140
MODULE 2

DIGIS IO-10
4829 0140
MODULE 1

DIGIWARE
BUS

CAT6 – CAT6 – CAT6 – CAT6

415V 3NE~ 50Hz 600A 65kA for 1 sec

R
W
B
N

NOTES

1. SURGE DIVERTERS SHALL PROVIDE FEEDBACK TO DCS VIA VOLT-FREE CONTACTS. SURGE DIVERTER FUSES SHALL BE SIZED BY VENDOR TO SUIT DUTY.
2. MINIATURE CIRCUIT BREAKERS SHALL BE SIZED AND RATED TO SUIT ACB AND INCOMER REQUIREMENTS.
3. ALL TERMINATIONS ABOVE 50VAC SHALL BE TO IP2x OR ABOVE, IF NOT, TO HAVE A SEPARATE PERSPEX SHROUD FITTED AND SHALL BE LABELLED "DANGER xxxVAC".
4. WIRE NUMBER FERRULES ON TERMINAL STRIP SHALL BE PREFIXED WITH EQUIPMENT NUMBER e.g. F22SW131-0600, UNLESS OTHERWISE NOTED.
5. EACH WIRE SHALL BE IDENTIFIED AT BOTH ENDS WITH FERRULES.
6. ATS TO BE CONFIGURED SUCH THAT LOSS OF MAINS POWER SHALL START GENERATOR AND TRANSFER SUPPLY SOURCE. UPON DETECTION OF MAINS POWER ATS SHALL AUTO TRANSFER TO MAINS AND SHUTDOWN GENERATOR WITH A NOMINAL DELAY OF 5 MINUTES.

LEGEND

00/01/00	DCS DIGITAL INPUT
00/02/00	DCS DIGITAL OUTPUT
⊗	MCC TERMINAL
⊗	VSD TERMINAL
◒	FIELD TERMINAL
◑	DCS OR I/O TERMINAL
◧	MARSHALLING TERMINAL
(x)	DEVICE TERMINAL
⊗ cc	INDICATION LAMP cc = COLOUR

"SOURCES LTD\23517 KCGM GROWTH PROJECT\03 DELIVERABLES\ELF22 - CIL4 CARBON TREAMENT & ELUTION\2000-F22-SCM-EL-10272.DWG 18DEC25 12:14PM HOTSEAT04

2000-F22-SCM-EL-10272_Rev2

F22-SW-131 - F22-SW-131 415V emergency switchboard incomer - schematic diagram sheet 1