240VAC SUPPLY CIRCUIT R10
LINE 65

240VAC SUPPLY CIRCUIT W10
LINE 66

F75SW556-UPS1
HELIOS - CBI2420A
240VAC/24VDC, 20A UPS

F75SW556-UPS2
HELIOS - CBI2420A
240VAC/24VDC, 20A UPS

INPUT AC 240V

OUTPUT DC 24V 20A

UPS 1 BATTERY
VISION 6FM17-X
12V 17Ah
2 OFF

UPS 2 BATTERY
VISION 6FM17-X
12V 17Ah
2 OFF

MAIN
1073 / 1083
TO RTU DIGITAL INPUT
UPS 1 MAIN INPUT SUPPLY HEALTHY
2000-F75-TER-IC-40120

MAIN
1079 / 1089
TO RTU DIGITAL INPUT
UPS 2 MAIN INPUT SUPPLY HEALTHY
2000-F75-TER-IC-40122

BATTERY HEALTHY
1093 / 1103
TO RTU DIGITAL INPUT
UPS 1 BATTERY HEALTHY
2000-F75-TER-IC-40120

BATTERY HEALTHY
1099 / 1109
TO RTU DIGITAL INPUT
UPS 2 BATTERY HEALTHY
2000-F75-TER-IC-40122

1111 1116 1120 1127

F75SW556-RM
HELIOS
DRM40 20-40A
REDUNDANCY MODULE
IN1 IN2
DC 12-28V 20A
OUTPUT 40A

CB117 20A 1174 1176 1184

F75SW556-SD
TRANSTECH
TLP-SF20SL-24VDC
SURGE FILTER
24VDC TRANSIENT SURGE DIVERTER

CB120 20A 1204 (+24VDC) (0VDC) 1206

1200

CB123 6A 1231 1236
S123 DOOR
S124 DOOR
S125 DOOR
WH
1 PANEL LIGHTS

CB127 2A 1271
TO POWER METER LINE 21
2 POWER METER 24VDC POWER SUPPLY

CB129 2A 1291
TO MOXA NETWORK SWITCH LINE 178
3 MOXA NETWORK SWITCH 24VDC POWER SUPPLY

CB131 4A 1311
TO DATA RADIO LINE 168
4 DATA RADIO 24VDC POWER SUPPLY

CB133 2A 1331
TO RADIO MODEM LINE 175
5 RADIO MODEM 24VDC POWER SUPPLY

CB135 4A 1351 TS135 1353 REF
SWITCHBOARD VENTILATION FAN
6 SWITCHBOARD VENTILATION FAN 24VDC POWER SUPPLY

CB137 6A F75CP556-24VDC
F75-CP-556
2000-F75-SCM-EL-40111
F75CP556-0VDC
7 F75-CP-556
FIM III UNDERDRAINAGE PUMP 1 CONTROL PANEL
24VDC POWER SUPPLY

CB139 6A
8 SPARE

CB141 10A 1411
RTU SLOT 1 MARSHALLING STRIP
9 RTU SLOT 1 MARSHALLING STRIP 24VDC POWER SUPPLY

CB143 10A 1431
RTU SLOT 2 MARSHALLING STRIP
10 RTU SLOT 2 MARSHALLING STRIP 24VDC POWER SUPPLY

CB145 10A
11 SPARE

CB147 1A FIT75789-P1
FIT-75789
2000-F75-TER-IC-40121
FIT75789-P1
12 FIT-75789
MAGNETIC FLOW METER
24VDC POWER SUPPLY

24VDC SUPPLY CONT'D ON LINE 150

24VDC SUPPLY CONT'D FROM LINE 148

CB152 1A — 13 SPARE
CB154 1A — 14 SPARE
CB156 4A — 15 SPARE
CB158 4A — 16 SPARE

F75-RTU-556
ACE3600 RTU
MOTOROLA
F7509A C/W V103AG

RTU BUS MOTHERBOARD AND 3 I/O SLOTS FRAME

CB163 10A 1631
MOTOROLA V251 BQ
18-72V POWER SUPPLY
AUX IN — 18-72VDC POWER SUPPLY — AUX IN
17

MOTOROLA ACE3640 F7502A
REMOTE TERMINAL UNIT
CPU
SERIAL 1
SERIAL 2
ETH1 — CAT6 — CAT6 — CAT6 — CAT6 — CAT6 — CAT6 — CAT6

MOTOROLA V245 AF
MIXED I/O MODULE
16 DI, 4 DO, 4 AI
RTU I/O SLOT 1
2000-F75-TER-IC-40120 AND 40121

MOTOROLA V245 AF
MIXED I/O MODULE
16 DI, 4 DO, 4 AI
RTU I/O SLOT 2
2000-F75-TER-IC-40122 AND 40123

MOTOROLA V20 AC
SPARE BLANK I/O MODULE

MOXA ETHERNET SWITCH SDS-3008
P8 P7 P6 P5 P4 P3 P2 — CAT6 — CAT6
P1 — CAT6 — CAT6 — CAT6 — POWER METER LINE 23
CAT6 — CAT6 — CAT6 — CAT6 — CAT6 — CAT6 — CAT6

1291 1206 — 24VDC SUPPLY LINE 129

DATA RADIO
GE SD04-MDFESNASNN
COM2 SERIAL
YAGI ANTENNA
YB9-61
SITE NETWORK
COAX_1
SURGE SUPPRESSOR
IS-B-50-LN-C2
1311 1206 — 24VDC SUPPLY LINE 131

RADIO MODEM 4G
GT-LE990C1-AP
RS232 PORT
4G LTE CELLULAR MOBILE ANTENNA
CD7195-B-SMA
SITE NETWORK
COAX_1
SURGE SUPPRESSOR
IS-B-50-LN-C2
1331 1206 — 24VDC SUPPLY LINE 133

1813 Q023 1823
TO RTU DIGITAL INPUT
MCCB TRIPPED
2000-F75-TER-IC-40120

0VDC TERMINALS

1	•	F75SW556-1206
2	•	F75SW556-1206
3	•	F75SW556-1206
4	•	F75SW556-1206
5	•	F75SW556-1206
6	•	F75SW556-1206
7	•	F75CP556-0VDC
8	•	
9	•	F75SW556-1206
10	•	F75SW556-1206
11	•	
12	•	FIT75789-P1
13	•	
14	•	
15	•	
16	•	
17	•	F75SW556-1206

APPROVED FOR CONSTRUCTION

2000-F75-SCM-EL-40119_Rev0

FIM III tailings dam F75-SW-556 FIM III TSF switchboard 1 schematic diagram sheet 2