240VAC SUPPLY CIRCUIT R10
LINE 65

240VAC SUPPLY CIRCUIT W10
LINE 66

F75SW804-PS1
PHOENIX
QUINT4-PS/1AC/24DC/20
240VAC/24VDC, 20A POWER SUPPLY

F75SW804-PS2
PHOENIX
QUINT4-PS/1AC/24DC/20
240VAC/24VDC, 20A POWER SUPPLY

DC OK 13 1053 / 14 1063 — POWER SUPPLY 1 24VDC HEALTHY TO 2000-F75-TER-IC-40138

DC OK 13 1059 / 14 1069 — POWER SUPPLY 2 24VDC HEALTHY TO 2000-F75-TER-IC-40138

(+24VDC) 1071 1070 (0VDC) 1077 1078

F75SW804-RM
PHOENIX
QUINT-ORING/24DC/2x20/1x40
REDUNDANCY MODULE

(+24VDC) (0VDC)

CB117 20A 1174 1184 1176

F75SW804-SD
TRANSTECH
TLP-SF20SL-24VDC
SURGE FILTER

24VDC TRANSIENT SURGE DIVERTER

CB120 20A 1204 (+24VDC) (0VDC) 1206

1200

CB123 6A 1231 — S123 DOOR, S124 DOOR, S125 DOOR — 1236 WH — 1 PANEL LIGHTS

CB127 2A 1271 — TO POWER METER LINE 21 — 2 POWER METER 24VDC POWER SUPPLY

CB129 2A 1291 — TO MOXA NETWORK SWITCH LINE 178 — 3 MOXA NETWORK SWITCH 24VDC POWER SUPPLY

CB131 4A 1311 — TO DATA RADIO LINE 168 — 4 DATA RADIO 24VDC POWER SUPPLY

CB133 2A 1331 — TO RADIO MODEM LINE 175 — 5 RADIO MODEM 24VDC POWER SUPPLY

CB135 4A 1351 — TS135 REF — 1353 — SWITCHBOARD VENTILATION FAN — 6 SWITCHBOARD VENTILATION FAN 24VDC POWER SUPPLY

CB137 6A F75CP804-24VDC — F75-CP-804 2000-F75-SCM-EL-40117 — F75CP804-0VDC — 7 F75-CP-804 FIM III SEEPAGE PUMP 4 CONTROL PANEL 24VDC POWER SUPPLY

CB139 6A — 8 SPARE

CB141 10A 1411 — RTU SLOT 1 MARSHALLING STRIP — 9 RTU SLOT 1 MARSHALLING STRIP 24VDC POWER SUPPLY

CB143 10A — 10 SPARE

CB145 10A — 11 SPARE

CB147 1A FIT75733-P1 — FIT-75733 2000-F75-TER-IC-40139 — FIT75733-P1 — 12 FIT-75733 MAGNETIC FLOW METER 24VDC POWER SUPPLY

24VDC SUPPLY CONT'D ON LINE 150

24VDC SUPPLY CONT'D FROM LINE 148

CB152 1A — 13 SPARE

CB154 1A — 14 SPARE

CB156 4A — 15 SPARE

CB158 4A — 16 SPARE

CB163 10A 1631 — AUX IN (+) / AUX IN (-) — 17

F75-RTU-804
ACE3600 RTU
MOTOROLA
F7509A C/W V103AG

RTU BUS MOTHERBOARD AND 3 I/O SLOTS FRAME

MOTOROLA V251BQ
18-72V POWER SUPPLY
18-72VDC POWER SUPPLY

MOTOROLA ACE3640 F7502A
REMOTE TERMINAL UNIT
CPU
SERIAL 1
SERIAL 2
ETH1 — CAT6 — CAT6 — CAT6 — CAT6 — CAT6 — CAT6 — CAT6

MOTOROLA V245AF
MIXED I/O MODULE
16 DI, 4 DO, 4 AI
RTU I/O SLOT 1
2000-F75-TER-IC-40138 AND 40139

MOTOROLA V20AC
SPARE BLANK I/O MODULE

MOTOROLA V20AC
SPARE BLANK I/O MODULE

MOXA ETHERNET SWITCH SDS-3008
P8 P7 P6 P5 P4 P3 P2 — CAT6 — CAT6 — CAT6 — CAT6 — CAT6 — CAT6 — CAT6
P1 — CAT6 — CAT6 — CAT6 — POWER METER LINE 23

1291 / 1206 — 24VDC SUPPLY LINE 129

DATA RADIO
GE-SD04-MDFESNASNN
COM2 SERIAL
COAX_1
YAGI ANTENNA
YB9-61
SITE NETWORK
SURGE SUPPRESSOR
IS-B-50-LN-C2
1311 / 1206 — 24VDC SUPPLY LINE 131

RADIO MODEM 4G
GT-LE990C1-AP
RS232 PORT
COAX_1
4G LTE CELLULAR MOBILE ANTENNA
CD7195-B-SMA
SITE NETWORK
SURGE SUPPRESSOR
IS-B-50-LN-C2
1331 / 1206 — 24VDC SUPPLY LINE 133

1813 / Q023 1823 — TO RTU DIGITAL INPUT MCCB TRIPPED 2000-F75-TER-IC-40138

0VDC TERMINALS

1	•	F75SW804-1206
2	•	F75SW804-1206
3	•	F75SW804-1206
4	•	F75SW804-1206
5	•	F75SW804-1206
6	•	F75SW804-1206
7	•	F75CP804-0VDC
8	•	
9	•	F75SW804-1206
10	•	
11	•	
12	•	FIT75733-P1
13	•	
14	•	
15	•	
16	•	
17	•	F75SW804-1206

APPROVED FOR CONSTRUCTION

2000-F75-SCM-EL-40129_Rev0

FIM III tailings dam F75-SW-804 FIM III TSF switchboard 6 schematic diagram sheet 2