EXISTING

TO POLE TSF2N-18
REFER DWG.
180\E\3021-002

33kV POWERLINE

EQUIPMENT MOUNTED ON POLE TSF2N-21

TSF2N-21-PTS

EQUIPMENT MOUNTED ON POLE TSF3-1

EQUIPMENT MOUNTED ON POLE TSF3-2

TSF3-2-PTS

TSF3-2-REC
800A

F23-TR-601
33/11kV
5000kVA

NER

FIM III
BOOSTER STATION
SWITCHROOM
F23-SR-601

EQUIPMENT MOUNTED ON POLE TSF3-4

TSF3-4-PTS

TSF3-4-FU
100A

EQUIPMENT MOUNTED ON POLE TSF3E-1

TSF3E-1-PTS

TSF3E-1-FU
100A

EQUIPMENT MOUNTED ON POLE TSF3E-12

TSF3E-12-FU
3A

F75-TR-804
33/0.44kV
100kVA

125A

FIM III TSF
SWITCHBOARD 6
F75-SW-804

EQUIPMENT MOUNTED ON POLE TSF3E-14

TSF3E-14-PTS

TSF3E-14-FU
15A

KIOSK
TRANSFORMER

F75-TR-600
33/1kV
500kVA

N

FIM III DECANT
CELL 1
MAIN SWITCHBOARD
F75-SW-600

FUTURE

EQUIPMENT MOUNTED ON POLE TSF3E-15

TSF3E-15-FU
3A

F75-TR-803
33/0.44kV
100kVA

125A

FIM III TSF
SWITCHBOARD 5
F75-SW-803

EQUIPMENT MOUNTED ON POLE TSF3E-18

TSF3E-18-FU
3A

F75-TR-802
33/0.44kV
100kVA

125A

FIM III TSF
SWITCHBOARD 4
F75-SW-802

EQUIPMENT MOUNTED ON POLE TSF3E-22

TSF3E-22-FU
3A

F75-TR-801
33/0.44kV
100kVA

125A

FIM III TSF
SWITCHBOARD 3
F75-SW-801

EQUIPMENT MOUNTED ON POLE TSF3E-45

TSF3E-45-PTS

TSF3E-45-FU
15A

KIOSK
TRANSFORMER

F75-TR-602
33/1kV
500kVA

N

FIM III DECANT
CELL 3
MAIN SWITCHBOARD
F75-SW-602

FUTURE

POLE TSF3E-46

EQUIPMENT MOUNTED ON POLE TSF3W-1

EQUIPMENT MOUNTED ON POLE TSF3W-5

TSF3W-5-FU
8A

1

F75-TR-556
33/0.44kV
200kVA

250A

FIM III TSF
SWITCHBOARD 1
F75-SW-556

EQUIPMENT MOUNTED ON POLE TSF3W-12

TSF3W-12-PTS

TSF3W-12-FU
15A

KIOSK
TRANSFORMER

F75-TR-601
33/1kV
500kVA

N

FIM III DECANT
CELL 2
MAIN SWITCHBOARD
F75-SW-601

FUTURE

POLE TSF3W-13

NORTHERN STAR RESOURCES LTD

Approved ☐

Approved a [redacted] X

[redacted] pproved ☐

For Information Only

# 2000-T03-SLD-EL-41001_Rev1

High voltage distribution - FIM III TSF - single line diagram