Docusign Envelope ID: 2E3DD104-80EB-4954-A6BB-3A98DFF9A8E1

240VAC
240VAC UPS SUPPLY
FROM F23-DB-603
REFER 2000-F23-TLD-EL-40013
240VN
IS103 32A
IS103 32A
1030
CB015
16A
30 mA
1051
POWER RAIL - PDU No.1
1039N
240VAC POWER RAIL PDU No.1
NOTE 5
108L
109N
CB109 16A
CB110 16A
1090
1100
F23COM601-PS1
PHOENIX
QUINT4-PS/1AC/24DC/20
240VAC/24VDC, 20A POWER SUPPLY
INPUT AC 240V
L/+ N/- PE
OUTPUT DC 24V 20A
24V 0V
13 DC OK 14
F23COM601PS1+24VDC
F23COM601PS1-SIG
POWER SUPPLY 1 HEALTHY TO F23-DCS-601 2000-F23-TER-IC-40001
F23COM601-PS2
PHOENIX
QUINT4-PS/1AC/24DC/20
240VAC/24VDC, 20A POWER SUPPLY
INPUT AC 240V
L/+ N/- PE
OUTPUT DC 24V 20A
24V 0V
13 DC OK 14
F23COM601PS2+24VDC
F23COM601PS2-SIG
POWER SUPPLY 2 HEALTHY TO F23-DCS-601 2000-F23-TER-IC-40001
1181
1187
1190
1198
F23COM601-RM
PHOENIX
QUINT4-DIODE/12-24DC/2x20/1x40
REDUNDANCY MODULE
INPUT DC
OUTPUT DC
1241
CB124
20A
1244
24VDC
0VDC
1245
CB127
10A
1271
F23COM601-PS3
WEIDMULLER
DC/DC CONVERTER 24/48V 10A
PRO TOPDC 24/48V 10A
24VDC
48VDC
F23COM601PS3+24VDC
F23COM601PS3-SIG
POWER SUPPLY 3 HEALTHY TO F23-DCS-601 2000-F23-TER-IC-40001
48VDC
0VDC - 48VDC
F23-ETH-605
(CCTV SWITCH)
CB137
10A
1372
DC+
CISCO
IE-3300-8P2S
DC-
F23-ETH-605
CCTV SWITCH
POWER SUPPLY
SURGE DIVERTER
nVENT ERICO LANRJ45C6P
SURGE DIVERTER
FOR CCTV CAMERA
1241
CB144
6A
1444
S144
DOOR
1445
WH
PANEL LIGHT
1241
24VDC SUPPLY
CONT'D ON LINE 152
1245

1241
24VDC SUPPLY
CONT'D FROM LINE 148
1245
CB153
4A
SPARE
CB155
4A
SPARE

NOTES

1. EACH WIRE SHALL BE IDENTIFIED AT BOTH ENDS WITH FERRULES.
2. REFFER TO THE ELECTRICAL EQUIPMENT LIST 2000-F23-LST-EL-40002 FOR DETAILS OF FOBOTS AND NETWORK SWITCHES.
3. REFER TO COMMUNICATIONS RACK GENERAL ARRANGEMENT DRAWING 2000-F23-DRG-IC-40001.
4. REFER TO COMMUNICATIONS BLOCK DIAGRAM 2000-F23-BLK-IC-40001.
5. EACH CISCO ETHERNET SWITCH AND SERVEREDGE KVM SHALL HAVE ONE POWER CABLES CONNECTED FROM THE DEVICE TO THE 240VAC PDU.

POWER RAIL – PDU
F23–KVM–601
19" HDMI LCD KVM CONSOLE
F23–ETH–XXX
CISCO SWITCH

AS BUILT

REFERENCES	DWG No	REV	DATE	REVISION	DRN	CHK	TECH APP	PROJ APP
		3	16.MAR.26	AS–BUILT FOR FIM III TSF	[redacted]	[redacted]	[redacted]	MBB
		2	10.DEC.25	RE–ISSUED FOR CONSTRUCTION	ET	[redacted]	KV	TH
FIM III BOOSTER STATION – F23–SR–601 – SWITCHROOM COMMUNICATIONS BLOCK DIAGRAM	2000–F23–BLK–IC–40001	1	10.JUL.25	RE–APPROVED FOR CONSTRUCTION	[redacted]	[redacted]	[redacted]	TH
FIM III BOOSTER STATION – F23–COM–601 – COMMUNICATIONS CABINET GENERAL ARRANGEMENT	2000–F23–DRG–IC–40001	0	14.APR.25	APPROVED FOR CONSTRUCTION				TH

NORTHERN STAR RESOURCES LIMITED

DRA PACIFIC (PTY) LIMITED

[redacted]	[redacted]	05.FEB.2025
CHECKED	[redacted]	05.FEB.2025
DESIGNED	[redacted]	05.FEB.2025
TECH APP	K. [redacted]	10.MAR.2025
[redacted] APP	[redacted]	14.APR.2025
CLIENT APP		

PROJECT: KCGM
FIM – TSF PROJECT

TITLE: FIM III BOOSTER STATION
F23–COM–601 – COMMUNICATIONS CABINET
SCHEMATIC DIAGRAM

A1 | SCALE NTS | DRG No. 2000–F23–SCM–IC–40001 | REV 3