240VAC UPS SUPPLY
FROM F72-DB-201
2000-F72-TLD-EL-10105

240VAC
F72DCS413P1-L
240VAC
F72DCS413P1-N
240VAC

Q006
10A
0060

Q007
10A
0076

F72DCS413-PS1
PHOENIX
QUINT4-PS/1AC/24DC/20
240VAC/24VDC, 20A POWER SUPPLY
DC OK
F72DCS413PS1+24VDC
F72DCS413PS1
POWER SUPPLY 1
24VDC HEALTHY
TO 2000-F72-TER-IC-10012

F72DCS413-PS2
PHOENIX
QUINT4-PS/1AC/24DC/20
240VAC/24VDC, 20A POWER SUPPLY
DC OK
F72DCS413PS2+24VDC
F72DCS413PS2
POWER SUPPLY 2
24VDC HEALTHY
TO 2000-F72-TER-IC-10012

(+24VDC)
(0VDC)
0131
0137
0130
0138

F72DCS413-RM
PHOENIX
QUINT-ORING/24DC/2x20/1x40
REDUNDANCY MODULE

Q022
20A

0220
0205

Q025
6A
0250
S025
DOOR
0255
0VDC
WH
1
PANEL LIGHT

FIELD CONTROL UNIT
POWER SUPPLY 1
POWER SUPPLY 2

Q028
6A
0280
Q029
2A
1
0VDC
2
0VDC
3
F72-FCS-413
FIELD CONTROL UNIT
24VDC POWER SUPPLIES

Q032
2A
0320
F72SR001-LCS
2000-F72-TER-EL-10202
0VDC
4
F72SR001-LCS
SWITCHROOM
EMERGENCY SHUTDOWN
24VDC POWER SUPPLY

Q036
6A
0360
AIT72547
2000-F72-TER-IC-10014
0VDC
5
AIT72547
CYANIDE RINGMAIN AREA HCN
GAS MONITOR ANALYSER
TRANSMITTER
24VDC POWER SUPPLY

Q038
6A
0380
1
AIT72548
2000-F72-TER-IC-10014
0VDC
6
AIT72548
CYANIDE UNLOADING 1 HCN
GAS MONITOR ANALYSER
TRANSMITTER
24VDC POWER SUPPLY

Q040
2A
0VDC
7
SPARE
24VDC POWER SUPPLY

Q042
6A
0420
1
AIT72549
2000-F72-TER-IC-10014
0VDC
8
AIT72549
CYANIDE UNLOADING 2 HCN
GAS MONITOR ANALYSER
TRANSMITTER
24VDC POWER SUPPLY

0220
24VDC SUPPLY
CONT'D ON LINE 51
0205

(+24VDC)
(0VDC)
0220
24VDC SUPPLY
CONT'D FROM LINE 048
0205

Q053
10A
0530
Q054
10A
0540
POWER SUPPLY 1
POWER SUPPLY 2
NODE INTERFACE UNIT
F72FCS413-NU01
0VDC
9
0VDC
10
YOKOGAWA - NIU
NETWORK I/O NODE
A2NN30D-440001102

Q060
10A
0600
24VDC FIELD POWER
2000-F72-TER-IC-10012
FIELD POWER - I/O BASE PLATE
16 CHANNEL I/O MODULE
F72FCS413NU01-01
DIGITAL INPUT
0VDC
11
16 CHANNEL NIO
BASEPLATE
A2BN3D-01020/L

Q065
10A
0650
24VDC FIELD POWER
2000-F72-TER-IC-10013
FIELD POWER - I/O BASE PLATE
16 CHANNEL I/O MODULE
F72FCS413NU01-02
DIGITAL INPUT
0VDC
12
16 CHANNEL NIO
BASEPLATE
A2BN3D-01020/L

Q070
10A
0700
24VDC FIELD POWER
2000-F72-TER-IC-10014
FIELD POWER - I/O BASE PLATE
16 CHANNEL I/O MODULE
F72FCS413NU01-03
ANALOGUE INPUT
0VDC
13
16 CHANNEL NIO
BASEPLATE
A2BN3D-01020/L

NOTES

1. TERMINALS ON TERMINAL STRIPS ABOVE 50VAC SHALL HAVE A SEPARATE PERSPEX SHROUD AND SHALL BE LABELLED "DANGER xxxVAC".
2. WIRE NUMBER FERRULES ON TERMINAL STRIP SHALL BE PREFIXED WITH EQUIPMENT NUMBER e.g. F72DCS413-XXXX.
3. EACH WIRE SHALL BE IDENTIFIED AT BOTH ENDS WITH FERRULES.
4. FOR NETWORK CONNECTION & BUS CABLING DETAILS REFER TO DCS PANEL COMMUNICATIONS TERMINATION DIAGRAMS.
5. INSTRUMENT EARTH BAR TO BE BONDED TO MAIN EARTH BAR WITH SOLID COPPER LINK.

LEGEND

- FIELD TERMINAL
- DCS OR I/O TERMINAL
- MARSHALLING TERMINAL
- DEVICE TERMINAL (x)
- INDICATION LAMP, cc = COLOUR
- EARTH BAR
- INSTRUMENT EARTH BAR

NIO BASEPLATE

F72FCS413NU01-01
- NETWORKED INPUT/OUTPUT (N-IO) BASEPLATE
- NODE INTERFACE UNIT (N-IU)
- FIELD CONTROL UNIT

DRG No.	REFERENCES
2000-F72-TLD-EL-10105	F72-DB-201 LV SWITCHROOM 240V UPS DB THREE LINE DIAGRAM
2000-F72-DRG-IC-10011	F72-DCS-413 415V SWITCHROOM DCS PANEL GENERAL ARRANGEMENT
2000-F72-TER-IC-10011	F72-DCS-413 415V SWITCHROOM DCS PANEL COMMUNICATIONS TERMINATION DIAGRAM
2000-F72-TER-IC-10012	F72-DCS-413 415V SWITCHROOM DCS PANEL TERMINATION DIAGRAM SHEET 1 (TO SHEET 4 - 10015)
2000-F00-STD-EL-10001	GENERAL NOTES AND STANDARD DRAWINGS INDEX

REV	DATE	DESCRIPTION
1	030CT25	ADDED INSTRUMENTS
0	10FEB25	APPROVED FOR CONSTRUCTION

DRAW | CHECK | DESIGN | TECH APP | PROJ APP

NORTHERN STAR RESOURCES LIMITED

PRIMERO
primero.com.au | DESIGN | CONSTRUCT | OPERATE

PRIMERO PROJECT NUMBER: 23517

INFORMATION AND REPRESENTATIONS ON THIS DRAWING ARE THE INTELLECTUAL PROPERTY OF PRIMERO UNLESS SPECIFICALLY IDENTIFIED OTHERWISE. ALL RIGHTS INCLUDING USE RESERVED

PROJECT: NORTHERN STAR RESOURCES LTD
KCGM GROWTH PROJECT

TITLE: REAGENTS MIXING & STORAGE
F72-DCS-413 415V SWITCHROOM DCS PANEL
SCHEMATIC DIAGRAM

SHEET	SCALE	DRG No.	REVISION
A1	NONE	2000-F72-SCM-IC-10011	1

O:\CAD PROJECTS\235 NORTHERN STAR RESOURCES LTD\23517 KCGM GROWTH PROJECT\03 DELIVERABLES\IC\F72 - REAGENTS MIXING & STORAGE\2000-F72-SCM-IC-10011.DWG 10OCT25 3:52PM HOTSEAT04