GOLDROOM POTABLE WATER HEADER
2000-F66-PID-PR-10004
POTABLE WATER

66-3085-POT-SS4-50-TI

FAH 66435 · FSH 66435 · 50x25 · 25VB03S5 F66-11358 · F66-SE-433 ILR ELECTROWINNING AREA SAFETY SHOWER

TIP 2145 BL STAGE 1 / STAGE 2 · 25VB03S5 F66-11355

66-3088-POT-SS4-25-TI

FAH 66436 · FSH 66436 · 25VB03S5 F66-11357 · F66-SE-437 ELUATE CIRCULATION PLATFORM SAFETY SHOWER

66-4057-POT-SS4-25-TI

FAH 66437 · FSH 66437 · 25VB03S5 F66-11356 · F66-SE-438 CIL4 ELECTROWINNING AREA SAFETY SHOWER

TIP 1058 BL
POTABLE WATER SUPPLY RINGMAIN
BROWNFIELDS 03-04 · GREENFIELDS
75-0613-POT-PE8-90
80VBFD1L2 F75-12928
POTABLE WATER

66-3081-POT-SS4-25-TI

FAH 66438 · FSH 66438 · 25VB03S5 F66-12763 · F66-SE-467 GOLDROOM SAFETY SHOWER

PE8 SS4 · 13-2617-POT-SS4-50-TI · 50x25 · 25VB03S5 F13-14125 · F13-SE-492 SAG MILL DECK SAFETY SHOWER

F13-SE-448 GROUND FLOOR SAG MILL SAFETY SHOWER · 25VB03S5 F13-11947 · 13-0716-POT-SS4-50-TI · 50x25

PE8 SS4 · 13-0616-POT-SS4-25-TI · 50x25 · 25VB03S5 F13-11360 · FAH 13208 · FSH 13208 · F13-SE-408 MILL DECK SAFETY SHOWER

F14-SE-406 CLASSIFICATION UPPER LEVEL SAFETY SHOWER 1 · 25VB03S5 F14-11362 · 14-0620-POT-SS4-25-TI · 13-0619-POT-SS4-25-TI

13-2618-POT-SS4-50-TI · 50x25 · 25VB03S5 F13-14126 · F13-SE-491 CPP ACCESS PLATFORM SAFETY SHOWER

13-0621-POT-SS4-25-TI · 25VB03S5 F14-11361 · 14-2619-POT-SS4-25-TI

F14-SE-407 CLASSIFICATION UPPER LEVEL SAFETY SHOWER 2 · F14-SE-497 GRAVITY SCREENS LOWER LEVEL SAFETY SHOWER · 25VB03S5 F14-14132

PE8 SS4 · 13-1817-POT-SS4-50-TI · 50x25 · 25VB03S5 F13-11875 · F13-SE-450 MILL BOND DECK SAFETY SHOWER

13-2620-POT-SS4-25-TI · 25VB03S5 F13-14131 · F13-SE-493 BALL MILL FEED BOX 1 SAFETY SHOWER

F14-SE-496 CONC FEED BOX LEVEL SAFETY SHOWER · 25VB03S5 F14-14121 · 14-2624-POT-SS4-25-TI · 50x25

F14-SE-405 CLASSIFICATION LEVEL SAFETY SHOWER · 25VB03S5 F14-14122 · 14-2623-POT-SS4-50-TI · 50x25

SWAP ORDER OF THESE PLEASE

PE8 SS4 · 14-0746-POT-SS4-25-TI · FAH 14003 · FSH 14003 · 25VB03S5 F14-11876 · F14-SE-449 ILR AREA SAFETY SHOWER

F14-SE-495 GRAV CONC UPPER LEVEL SAFETY SHOWER · 25VB03S5 F14-14123 · 14-2622-POT-SS4-50-TI · 50x25

F14-SE-494 GRAC CONC LOWER LEVEL SAFETY SHOWER · 25VB03S5 F14-14124 · 14-2621-POT-SS4-50-TI · 50x25

FSH 13207 · FAH 13207 · F14-SE-404 GROUND FLOOR ILR SAFETY SHOWER · 25VB03S5 F14-11364 · 14-0618-POT-SS4-25-TI

PE8 SS4 · 13-0617-POT-SS4-25-TI · 25VB03S5 F13-11365 · F13-SE-403 GROUND FLOOR BALL MILL SAFETY SHOWER

F13-SE-501 OSA CONTAINER SAFETY SHOWER · 25VB03S5 F13-14127 · 13-2625-POT-SS4-25-TI · 50x25

F13-SE-498 TRASH SCREEN SLAB SOUTH SAFETY SHOWER · 25VB03S5 F13-14128 · 13-2626-POT-SS4-25-TI · 50x25

F13-SE-499 FLOTATION SAMPLER SAFETY SHOWER · 25VB03S5 F13-14129 · 13-2627-POT-SS4-25-TI · 50x25

F13-SE-463 TRASH SCREEN SLAB NORTH SAFETY SHOWER · 25VB03S5 F13-11525 · 13-2227-POT-SS4-25-TI

F13-SE-500 TRASH DEWATERING SCREEN SAFETY SHOWER · 25VB03S5 F13-14130 · 13-2628-POT-SS4-25-TI · 50x25

SS4 PE8 · 13-0810-POT-SS4-50-TI · 25VB03S5 F13-11359 · 50x25 · F13-SE-428 RECYCLE CRUSHER AREA SAFETY SHOWER

12-0040-POT-PE8-63-TI · A/G · U/G · 00-0809-POT-PE8-063 · 24-0808-POT-PE8-63-TI · 13-1736-POT-PE8-63-TI · NOTE 2

PE8 SS4 · 12-0623-POT-SS4-25-TI · 25VB03S5 F12-11366 · F12-SE-402 PRIMARY CRUSHER 2 AREA SAFETY SHOWER 2

PE8 SS4 · 12-0624-POT-SS4-25-TI · 25VB03S5 F12-11367 · F12-SE-401 PRIMARY CRUSHER 2 AREA SAFETY SHOWER 1

PE8 SS4 · 13-1734-POT-SS4-25 · 25VB03S5 F13-11368 · F13-SE-447 COS RECLAIM AREA SAFETY SHOWER 2

PE8 SS4 · 13-0655-POT-SS4-50-TI · 50x25 · 25VB03S5 F13-11369 · F13-SE-446 COS RECLAIM AREA SAFETY SHOWER 1

50VB03S5 F13-11373

50VB03S5 F24-11374 · 50VBFD1L2 F24-11397 · 50VB03S5 F24-11375

72-0630-POT-SS4-25-TI · FAH 72171 · FSH 72171 · 25VB03S5 F72-11393 · F72-SE-427 PAX AREA SAFETY SHOWER 1

72-1667-POT-SS4-25-TI · FAH 72176 · FSH 72176 · 25VB03S5 F72-11394 · F72-SE-453 PAX AREA SAFETY SHOWER 2

72-0632-POT-SS4-25-TI · FAH 72166 · FSH 72166 · 25VB03S5 F72-11392 · F72-SE-422 FLOCCULANT AREA SAFETY SHOWER

72-0631-POT-SS4-25-TI · FAH 72167 · FSH 72167 · 25VB03S5 F72-11391 · F72-SE-423 FROTHER AREA SAFETY SHOWER

72-1382-POT-SS4-25-TI · FAH 72173 · FSH 72173 · 25VB03S5 F72-11390 · F72-SE-435 COPPER SULPHATE AREA SAFETY SHOWER 1

72-1666-POT-SS4-25-TI · FAH 72174 · FSH 72174 · 25VB03S5 F72-11389 · F72-SE-436 COPPER SULPHATE AREA SAFETY SHOWER 2

17-1711-POT-SS4-50-TI · 50x25 · 25VB03S5 F17-11370 · F17-SE-439 FLOTATION TAILINGS THICKENING SAFETY SHOWER 1

17-1712-POT-SS4-50-TI · 50x25 · 25VB03S5 F17-11371 · F17-SE-440 FLOTATION TAILINGS THICKENING SAFETY SHOWER 2

17-1713-POT-SS4-50-TI · 50x25 · 25VB03S5 F17-11372 · F17-SE-441 FLOTATION TAILINGS THICKENING SAFETY SHOWER 3

16-0643-POT-SS4-50-TI · 16-0644-POT-SS4-50-TI

50x25 · 25VB03S5 F16-11382 · F16-SE-409 FLOTATION AREA SAFETY SHOWER 1

FAH 16002 · FSH 16002 · 50x25 · 25VB03S5 F16-11381 · F16-SE-410 FLOTATION AREA SAFETY SHOWER 2

TIP 1051 BL
GREENFIELDS · BROWNFIELDS
75-0613-POT-PE8-90
06-15
80VBFD1L2 F75-13512
EVENT POND SAFETY SHOWER
2000-F75-PID-PR-25010
POTABLE WATER

PE8 SS4 · 23-0812-POT-SS4-25-TI · 50x25 · 25VB03S5 F23-11387 · FAH 23505 · FSH 23505 · F23-SE-429 FINAL TAILS AREA SAFETY SHOWER 1

PE8 SS4 · 23-2230-POT-SS4-25-TI · 50x25 · 25VB03S5 F23-11516 · FAH 23506 · FSH 23506 · F23-SE-452 FINAL TAILS AREA SAFETY SHOWER 2

PE8 SS4 · 24-2309-POT-SS4-25-TI · 50x25 · 25VB03S5 F24-11519 · F24-SE-468 RAW WATER AREA SAFETY SHOWER

PE8 SS4 · 72-3015-POT-SS4-50 · OXYGEN PLANT 2000-F72-PID-PR-10011 POTABLE WATER

PE8 SS4 · 18-1707-POT-SS4-50-TI · 50x25 · 25VB03S5 F18-11377 · F18-SE-442 CLEANER & CLEANER-SCAVENGER FLOTATION AREA SAFETY SHOWER 1

18-1708-POT-SS4-50-TI · 50x25 · 25VB03S5 F18-11378 · F18-SE-443 CLEANER & CLEANER-SCAVENGER FLOTATION AREA SAFETY SHOWER 2

18-1709-POT-SS4-50-TI · 50x25 · 25VB03S5 F18-11379 · F18-SE-444 CLEANER & CLEANER-SCAVENGER FLOTATION AREA SAFETY SHOWER 3

PE8 SS4 · 18-1710-POT-SS4-50-TI · 50x25 · 25VB03S5 F18-11376 · F18-SE-445 CLEANER & CLEANER-SCAVENGER FLOTATION AREA SAFETY SHOWER 4

NOTES:

1. ALL STAGNANT SECTIONS OF SAFETY SHOWER PIPEWORK EXPOSED TO DIRECT SUNLIGHT TO BE INSULATED. SITE TO CONFIRM EXTENTS OF INSULATION. INSULATION NOT REQUIRED FOR RINGMAIN.
2. INSULATION NOT REQUIRED FOR COS RECLAIM TUNNEL.

DRG No.	REFERENCES
2000-F00-PID-PR-10007	LEGEND SHEET 7 - PIPING AND INSTRUMENTATION DIAGRAM
2000-F00-PID-PR-10006	LEGEND SHEET 6 - PIPING AND INSTRUMENTATION DIAGRAM
2000-F00-PID-PR-10005	LEGEND SHEET 5 - PIPING AND INSTRUMENTATION DIAGRAM
2000-F00-PID-PR-10004	LEGEND SHEET 4 - PIPING AND INSTRUMENTATION DIAGRAM
2000-F00-PID-PR-10003	LEGEND SHEET 3 - PIPING AND INSTRUMENTATION DIAGRAM
2000-F00-PID-PR-10002	LEGEND SHEET 2 - PIPING AND INSTRUMENTATION DIAGRAM
2000-F00-PID-PR-10001	LEGEND SHEET 1 - PIPING AND INSTRUMENTATION DIAGRAM

REV	DATE	DESCRIPTION	DRAW	CHECK	DESIGN	TECH APP	PROJ APP
2	05SEP25	SAFETY SHOWERS ADDED					
1	10JUL25	SAFETY SHOWERS UPDATED; INSTRUMENT TAGS ADDED					
0	18DEC24	APPROVED FOR CONSTRUCTION					

NORTHERN STAR RESOURCES LIMITED

PRIMERO
primero.com.au | DESIGN | CONSTRUCT | OPERATE

PRIMERO PROJECT NUMBER: 23517

INFORMATION AND REPRESENTATIONS ON THIS DRAWING ARE THE INTELLECTUAL PROPERTY OF PRIMERO UNLESS SPECIFICALLY IDENTIFIED OTHERWISE. ALL RIGHTS INCLUDING USE RESERVED

PROJECT: NORTHERN STAR RESOURCES LTD
KCGM GROWTH PROJECT

TITLE: AIR & WATER SERVICES
POTABLE WATER - SHEET 1
PIPING AND INSTRUMENTATION DIAGRAM

SHEET	SCALE	DRG No.	REVISION
A1	NTS	2000-F24-PID-PR-10005	2

O:\CAD PROJECTS\235 NORTHERN STAR RESOURCES LTD\23517 KCGM GROWTH PROJECT\03 DELIVERABLES\PRI\PID\2000-F24-PID-PR-10005_2.DWG 04SEP25 7:02AM ANNE.HOYNE